

772

VIRGINIA ELECTRIC AND POWER COMPANY
RICHMOND, VIRGINIA 23261

July 2, 1979

Norman C. Moseley, Director Division of Reactor Operations Inspection Office of Inspection and Enforcement U. S. Nuclear Regulatory Commission Washington, D. C. 20555	Serial No. 90A PO/DLR:baw Docket No.: 50-338 License No.: NF -4
--	--

Subject: IE Bulletin 79-01
North Anna Power Station Unit No. 1

Dear Mr. Moseley:

This letter is in response to IE Bulletin 79-01, "Environmental Qualification of Class IE Equipment."

In response to IE Bulletin 79-01, we directed our architect-engineer (A-E) and our NSSS supplier to review the environmental qualification of all class IE electrical equipment at North Anna Units No. 1 and 2.

This review by our A-E has been completed for Unit No. 1. Results are included as Table 1, which contains all class IE equipment, both safety related and non-safety related, that was procured by the A-E.

Only two potential qualification problems have been identified:

1. Chiller Equipment

The chiller equipment room contains control and relay room air conditioning equipment. The chiller equipment room is located adjacent to the turbine building and has a ventilation duct which is open to the turbine building. Under a postulated condition such that a steam line break in the turbine building directs a jet of steam directly into the area of the ventilation duct, the temperature in the chiller equipment room could reach 211°F. We have no information indicating qualification of the chiller equipment under these conditions. Chiller equipment affected is listed on pages 1, 2, 3 and 10 of Table 1.

2. Safeguards Building Ventilation Fans

The emergency ventilation fans located in the safeguards building, designed as seismic Class I, are provided for ventilation of the recirculation spray and safety injection pumps area in the unlikely event the ventilation exhaust system is disabled. The ventilation exhaust system is run by two seismic Class I fans located in the auxiliary building and has the capability of diverting the effluent through the common iodine filter bank. Ventilation is designed to limit temperatures during warm weather to a maximum of 120°F and

503 284 790450
7908080 OFFICIAL COPY
109 Q

during cool weather to a minimum of 75°F. The spaces containing the recirculating spray and safety injection pumps and their valve rooms are subject to potential radioactive contamination from gland leakage. Our A-F has estimated that under accident conditions the radiation dose to the emergency ventilation fans could reach approximately 10^6 rads. We have no information on the qualification of these fans to such a radiation exposure.

We will continue to pursue qualification or an alternate resolution of these two outstanding items and will inform you of our actions on or about July 31, 1979.

Qualification data for safety-related equipment provided by the NSSS vendor are included in documents which have previously been submitted to the NRC as vendor proprietary. In many cases the non-proprietary versions of these documents which we have received are not sufficiently detailed to determine qualification. We have made arrangements to receive more detailed documents and will forward qualification data in a subsequent submittal on or about July 31, 1979.

IE Bulletin 79-01A was received following the final preparation of the attachment. Several ASCO solenoid valves previously identified as not qualified have been replaced or will be replaced as soon as possible. These valves were located in the RCS sampling system. Our letter, serial no. 466, dated June 14, 1979, and addressed to Mr. Victor Stello provides additional information.

Very truly yours,

C. M. Stallings

C. M. Stallings
Vice President-Power Supply
and Production Operations

cc: James P. O'Reilly, Director
Office of Inspection and Enforcement
Region II

503 285

North Anna Power Station Unit No. 1
 Environmental Qualification of A-E Supplied
 Class 1E Equipment

Table I

Equipment Description & Mark No.	Description of Accident Environment	Environment to Which Equip. Is Qualified	Manner of Qualification	Qualification Document
Control & Relay Room A/C Chillers Storagehouse: T-EV-1--A,B,C; D, NA-247; located in chiller room.	MSLB in turbine bldg. Equipment outside crane wall exposed to: 1. High ambient temperature 211°F for duration of steam discharge in vicinity of chiller room air intakes - 30 minutes. 2. High ambient moisture content-saturated steam, 100% RH for duration of steam discharge - 30 minutes.	None	None	None
Line Pumps - Air Conditioning Bingham-Willamette Company: EV-P-20A,B,C; T-EV-P-11A,B,C; D, NA-276; located in Chiller Room.	MSLB in turbine bldg. & equipment outside crane wall exposed to: 1. High ambient temperature 211°F for duration of steam discharge in vicinity of chiller room air intakes - 30 minutes. 2. High ambient moisture content-saturated steam, 100% RH for duration of steam discharge - 30 minutes.	None	None	None

Poor Orientation

503

285

Equipment Description & Model No.

Air Conditioning Self-Cleaning
Dryer - Elliot Company;
T-EV-S-TA,8; P.O. EA-159; located in
Chiller Room.

Description of Accident Environment

MSLB in turbine bldg. Equipment
outside crane wall exposed to:

1. High ambient temperature 211°F
for duration of steam discharge in
vicinity of chiller room air
intakes - 30 minutes.
2. High ambient moisture content-
saturated steam, 100% RH for
duration of steam discharge - 30
minutes.

Environment to which Equip. Is Exposed

None

Manner of Qualification

None

Qualification Documents

None

Propeller Fan - Aerovent Fan
Company, Incorporated; T-HW-Y-28;
P.O. EA-249; located in Chiller Room.

Description of Accident Environment

MSLB in turbine bldg. Equipment
outside crane wall exposed to:

1. High ambient temperature 211°F
for duration of steam discharge in
vicinity of chiller room air
intakes - 30 minutes.
2. High ambient moisture content-
saturated steam, 100% RH for
duration of steam discharge - 30
minutes.

Environment to which Equip. Is Exposed

1. High ambient temperature 211°F
at saturated atmosphere

andor's reply to TLX inquiry

TLX-3-29-79 - W. B. Schumacher
J. E. Krechting

Poor Original

700 207

Incident Description & Part No.
 GOO_Operated Valve - Fisher
 Company - Continental
 Division - P.O. - Natick 08538-
 0008, located in charcoal filter
 room from Chiller Room.

Area of automatic shutdown
 assembly

Description of Accident Environment
 KSLB in turbine bldg. Equipment
 outside crane wall exposed to:
 1. High ambient temperature 21°F
 for duration of steam discharge
 in vicinity of chiller room air
 intakes - 30 minutes.
 2. High ambient moisture content -
 saturated steam, 100% RH for
 duration of steam discharge -
 30 minutes.

Qualification Document	Manner of Qualification
None	None

503 288

POOR ORIGINAL

Classification Documents
General Cable Letter dated 12-22-71

Number of Qualifications

Environment to which FWDN is qualified

Description of Accident Environments

Loss of Localt Accidents LOCAL

2 x 10⁶ rads

Radiation: 1 x 10⁶ rads (based on 6 months LOCAL). In addition the 40 year radiation dose of $\pi \times 10^6$ rads must be considered for a total possible radiation dose of 1.0 x 10^6 rads.

-1 alum. power cable
-1 metal Cable
-1 Tripick 1000 MCN
-8 3/c 500 V/H alum. AFSCF
-4 3/c 1250 MCN alum. AFSCF
-5 3/c 1250 MCN st. AFSCF
-10 3/c 2000 MCN
-12 3/c 1500 MCN alum. AFSCF
-13 3/c 8/0 ANC. alum AFSCF
-14 Triples 8/0 ANC.
-9 3/c 1500 MCN

Item Description & Mark No.

503 289

POOR ORIGINAL

Equipment Description & Part No.

P.O. MA-256/1254
 600 V Alum. Power Cable
 (General Cable)
 MC8-5 Triplex 500 MCM
 MC8-7 Triplex 250 MCM
 MC8-11 Triplex 2/0 AWG
 MC8-12 Triplex 1 AWG

Description of Accident Environment
 Loss-of-Coolant Accident LOCAL
 28°F
 Reduce from 200°F
 to 150°F
 150°F
 15 psig
 Reduce from 45
 to 0 psig
 0 psig
 1.2 x 10⁵ rads
 Spray: 0-4 hrs. Solution of boric acid (2000-400 ppm boron) buffered to a pH of 8.5 to 9.1 with NaOH. 24 hrs similar solution with a pH of 7 to 9

Environment to which Equip. Is Qualified

Qualification Test
 Qualification Test - Sequential
 General Cable Letter dated
 12-22-71

Irradiated to
 100 psig & 3.0°F for 4 hrs
 62 psig & 310°F for 1 hr
 20 psig & 260°F for 43 hrs
 2.5 psig & 240°F for 5 days

Spray: Throughout test cycle solution consisting of a 2000 ppm solution of boron as boric acid buffered with NaOH to a pH of 9.0
 Irradiated an additional 1.65 x 10⁵ rads bringing the total exposure to 2 x 10⁵ rads

POOR ORIGINAL

503 290

Environment Description & Mark. No.

P.O. MA-128/1128
600 V Cu. Power Cable
Oxonite

MCA-18 3/8 250 MCM
MCA-21 3/0 2/0 AWG
MGB-15 Triplex #8 AWG
MGB-16 Triplex #6 AWG
MGB-17 3/0 #8 AWG
MGB-18 3/0 #10 AWG
MGA-19 3/0 #12 AWG

Description of Accident EnvironmentLoss-of-Coolant Accident (LOCA)

288°F 0 to 30 Min
Reduce from 288°F 30 to 60 Min
to 150°F
150°F >60 Min
85 psig 0 to 30 Min
Reduce from 45 30 to 60 Min
to 0 ps
0 psig >60 Min
 7.2×10^7 rads

Spray:
0-4 hr Solution of boric acid
(2000-2100 ppm boron) buffered to
a pH of 8.5 to 11 with NaOH
>4 hr Similar solution
with a pH of 7 to 9

Main Steam Line Break (MSLB)

830°F 0 to 2 Min
280°F 2 to 60 Min
151°F >60 Min
40 psig 0 to 60 Min
8 psig >60 Min
 3×10^7 rads

Environment to which simile is QualifedLoss-of-Coolant Accident (LOCA)

Aged 168 hr at 121°C
Irradiated to 2×10^7 rads

PWR exposure:
80 psig at 324°F For 4 hr
16 psig at 252°F For 7 days

Spray: 10,000 ppm boric acid
Buffered with NaOH to a pH of 10.5
throughout the PWR exposure period

Boiling Water Reactor Exposure (BWR)
A series of transient cycles each consisting of a rise to a specified press and temp for a specified time and a gradual return to initial conditions.
Following transient cycles 100 day exposure to live steam 0 psig, 212°F

BWR exposure includes a transient cycle at 104 psig at 345°F for 3 hours and 20 min.

MSLR

Same as "Description of Accident Environment"

Manner of Qualification"Test - SequentialTest - Analysis

Maximum calculated surface temperature during limiting MSLB is 335°F which does not exceed qualification temperature of 345°F given in PWR exposure portion of LOCA qualification.

Pressure and Radiation - Test
Refer to LOCA qualification.

Qualification Document

Oxonite's Engineering Report No. 141 dated 2/29/72

Additional Supporting Documents

Outline of Franklin Institute Research Laboratory Report F-CD-698

IEEE Transaction Paper T-74-048-4

PWR Qualification Documents

FSAR Section 3C and response to Comment 7.17 (Note to be revised to include this item).

Poor Original

503

162

POOR ORIGINAL

Equipment Description & Mark No.
 P.O. NA-359/1359
 High Temperature Cable
 Cerro Wire and Cable Company

Description of Accident Environment

Loss of Coolant Accident (LOCA)

NCA-15	Triplex 250 MCM
NCA-17	Triplex #2/0 AMG
NCA-33	6/0 2-#8 and 4-#12
NCA-61	7/0 #12 AMG
NCA-38	8/0 #16 AMG
NCA-37	2/0 #8 AMG

280°F	0 to 30 Min
Reduce from 280°F to 150°F	30 to 60 Min
150°F	>60 Min
45 psig	0 to 30 Min
Reduce from 45 to 0 psig	30 to 60 Min
0 psig	>60 Min
7.2 x 10 ⁷ rads	

Spray:

0-4 hr. Solution of boric acid (2000-2900 ppm boron) buffered to a pH of 8.5 to 11 with NaOH >4 hr. Similar solution with a pH of 7 to 9

MSLB

430°F	0 to 2 Min
280°F	2 to 60 Min
165°F	>60 Min
40 psig	0 to 60 Min
0 psig	>60 Min
3 x 10 ⁷ rads	

Environment to Which Equip. Is Qualified

LOCA

Irradiated to 2×10^7 rads
 50 psig and 276°F 12 hr
 Spray: Last 2 hr of 12 hr period with a solution of borated water containing approximately 1,720 ppm of boron as boric acid

Reduced to 5 psig and 164°F over an unspecified time with spray continuing

160°F at 5 psig for the remainder of the 7 day period without spray
 F-C 750 indicates that in an earlier test the spray was buffered with NaOH to pH of 9

MSLB

Same as "Description of Accident Environment"

Method of Qualification

Test - Sequential

Qualification Document

Franklin Institute Research Laboratory Report F-C2857

Cerro's Supplement to F.I.R.L. Report F-C2857

Franklin Inst. Lite Research Laboratory Repor F-C2750

Cerro's Supp'ement to F.I.R.L. Report F-C2750

PSAR Section 3C and response to Comment 7.17

Rockbestos' letter dated 8/25/77

LOCA qualification documents

Temperature - Analysis

Maximum calculated surface temperature during limiting MSLB is 335°F which does not exceed qualification temperature of 460°F given in Rockbestos' (formerly Cerro) letter dated 8/25/77

Pressure and Radiation - Test

Refer to LOCA Qualification

Equipment Description & Part No.
9.0. MA-312/312
600 V Control Cable
SEICO Wire and Cable Company.

Description of Accidents/Environmental

Environment to which Insulator Is Subjected

Loss of Current Carrying Capacity (LCCP)

Manner of Qualification
Test - Sequential

LCCP

Specimen	Condition	Test	Result
NECA-19	2/0 ANG	240°F	Irradiated to 2 x 10 ⁶ rads
NECA-34	1/0 ANG	Ref. 0 from 240°F	50 psig and 276°F
NECA-35	2/0 ANG	0 to 30 Min	Spray: Last 2 hr of 12 hr period with a
NECA-36	3/0 ANG	310°F	solution of borated water containing approximately 1,720 ppm of boron as boric acid
NECA-37	5/0 ANG	150°F	Reduce from 8%
NECA-38	8/0 ANG	4.5 psig	0 to 30 Min
NECA-28	7/0 ANG	7/0 ANG	0 to 10 Min
NECA-29	9/0 ANG	0 psig	Reduce to 0 psig
NECA-30	11/0 ANG	0 psig	Reduce to 5 psig and 160°F over an unspecified time with spray continued
NECA-48	12/0 ANG	7.2 x 10 ⁶ rads	160°F at 5 psig for the remainder of a 7 day period with no spray
NECA-49	2/0 ANG	240 Min	0-1 hrs Solution of boric acid (2.000-2.100 ppm boron) buffered to a pH of 8.5 to 9.1 with NaCl
NECA-50	3/0 ANG	0 psig	24 hr similar solution with a pH of 7 to 9
NECA-77	4/0 ANG		
NECA-83	2/0 ANG		
NECA-84	2/0 ANG		
NECA-85	2/0 ANG		
NECA-86	2/0 ANG		

HTSL

Specimen	Condition	Test	Result
NECA-19	2/0 ANG	0 to 2 Min	Thermally aged for 1300 hrs @ 150°C.
NECA-34	1/0 ANG	2 to 60 Min	Irradiated at a rate of 0.30 x 10 ⁶ rads per hr for total dose of .01 x 10 ⁶ rads.
NECA-35	2/0 ANG	0 to 60 Min	Spray: Solution of 4.00 ppm Boron and hydrazine solution maintained at a pH value of between 8.6 and 10.0 for 349 hrs.
NECA-36	3/0 ANG	240 Min	

HTSL

Specimen	Condition	Test	Result
NECA-19	2/0 ANG	0 to 13 min	Report 13-1047-Eds-13-2
NECA-34	1/0 ANG	13 to 15 min	Test was performed in Eds-13-2
NECA-35	2/0 ANG	15 to 20 min	of a similar construction as
NECA-36	3/0 ANG	20 to 25 min	that supplied in P.O. No. 312
NECA-37	4/0 ANG	25 min to 3.6 hrs	and 1312
NECA-38	5/0 ANG		
NECA-39	6/0 ANG		
NECA-40	7/0 ANG		
NECA-41	8/0 ANG		
NECA-42	9/0 ANG		

POOR ORIGINAL

503 293

Qualification Document

Franklin Institute Research Laboratory Report F-C2857
Cerro's Supplement to F.T.R.L.
Report F-C2857

Rockbestos Company
Report 13-1047-Eds-13-2
Test was performed in Eds-13-2
of a similar construction as
that supplied in P.O. No. 312
and 1312

Equipment Description & Part No.

P.O. MA-265/1265
 300 V Instrument Cable
Boston Insulated Wire and Cables
NCA-40 4/0 No. 16 AWG
 NCA-55 45/c No. 16 AWG
 NCA-67 75/c No. 16 AWG
 NCA-68 72/c No. 16 AWG
 NCA-69 3/c No. 16 AWG
 NCA-70 18/c No. 16 AWG
 NCA-35 2/c No. 16 AWG
 HCD-39 3/c No. 16 AWG

Description of Accident Environment

LOCA
 280°F
 Reduce from 280°F
 to 150°F
 150°F
 45 psig
 Reduce from 45
 to 0 psig
 0 psig
 7.2 x 10⁷ rads
 Spray:
 0-4 hrs solution of boric acid
 (2000-2100 ppm boron) buffered
 to a pH of 8.5 to 11 with NaOH
 >4 hrs similar solution with
 a pH of 7 to 9

Environment to which Equip. Is Qualified

LOCA
 Irradiated to 1 x 10⁸ rads
 280°F at 45 psig 60 min
 205°F at 0 psig 24 hrs
 Spray: Throughout 25 hr period
 Solution of 0.20 molar boron as boric
 acid with the pH adjusted to 8-8.5 with
 a 0.019 molar solution of NaOH

Manner of Qualification

Test - Sequential

Qualification Document

B.I.W. Letters dated
 1-17-72
 12-14-71

POOR ORIGINAL

503 294

Main Beam Line Break (MSLB)

830°F
 280°F
 165°F
 80 psig
 0 psig
 1 x 10⁷ rads

MSLB

Same as "Description of Accident
 Environment"

Temperature - Analysis
 Maximum calculated surface
 temperature during limit.
 MSLB is 343°F which does
 not exceed qualification
 temperature of 460°F given
 in B.I.W. letter dated
 12-12-76.
 Pressure and Radiation - Test
 refer to LOCA qualification

PSAR Section 3C and response
 to comment 7.17

B.I.W. letter dated 10-12-76
 LOCA Qualification documents

Classification Document

Franklin Institute Research
Laboratory Report P-I.R.L.
Report P-C257
Cerro's Supplement to P.I.R.L.
Report P-C257

Manuf. of Qualification

Test - Sequential

Environment to which Equip. is Qualified

Description of Accident Environment

Environment Description & Test No.

P-0. MA-257
Thermocouple Extension Wire
(CERRO MILLE SP1 CABLE)
NCB-48 1 pair No. 16 Copper-
NED-49 1 pair No. 16 Iron-
Constantan
Constantan
Cable
Loss of Coolant Accident (Local)
180°F 0 to 30 min
Reduce from 280°F 30 to 60 min
to 150°F 30 to 60 min
150°F 0 to 30 min
Spray: last 2 hrs of 12 hr period
solution of borated water containing
approximately 1720 ppm of boron as boric
acid
Reduce to 5 psig and keep over an
unspecified time with spray continued.
100°F at 5 psig for the remainder of
7 day period without spray.
P-C2750 indicates that in an earlier
test the spray was buffered with NaOH
to a pH of 9
pH of 7 to 9

Classification Document

Franklin Institute Research
Laboratory Report P-I.R.L.
Report P-C257
Cerro's Supplement to P.I.R.L.
Report P-C257

POOR ORIGINAL

503 295

Relevant Description & Part No.	Description of Accident Environment	Environment to which Envir. is Parallel	Number of Simulation	Qualification Document
P.O. NO-1375/1375 5 kw Allis - Power Cable <u>Chassis</u>	Radiation	4.2×10^7 rads (based on 6 month LOCA). In addition, the 40 year radiation dose of 3×10^7 rads must be considered for a total possible radiation dose 7.2×10^7 rads.	2 x 10 ⁶ Rads	ORNL's Engineering Report No. 141 dated 2/29/72 Additional Supporting Documents Outline of Franklin Institute Research Laboratory Report P-C1694 TRE Transaction Paper T74 044 4

POOR ORIGINAL

503 296

Equipment Description & Model No.
P.O. NO-388/1388
600 v Aluminum Power Cable
Okonite

NCS-5 Triplex 500 MCM
NCS-7 Triplex 250 MCM
NCS-11 Triplex #2/0 AWG.
NCS-12 Triplex #1 AWG.

Description of Accident Environment
Loss-of-Coolant Accident (LOCA)

280°F 0 to 30 min
Reduce from 280°F to 150°F 30 to 60 min
150°F >60 min
85 psig 0 to 30 min
Reduce from 85 to 0 psig 30 to 60 min
0 psig >60 min
7.2 x 10⁶ rads

Spray:
0-4 hr Solution of boric acid
(2,000-2,100 ppm boron)
buffered to a pH of 8.5 to 11
with NaOH.
>4 hr Similar solution with a
pH of 7 to 9.

Environment to Which Equip. Is Qualified

LOCA

Aged 168 hr at 121°C
Irradiated to 2 x 10⁶ rads

PWR Exposure:
324°F at 80 psig 0 to 8 hr
252°F at 16 psig for 7 days
Spray: 10,000 ppm boric acid buffered
with NaOH to a pH of 10.5 throughout the
PWR exposure period.

Boiling Water Reactor Exposure:
A series of transient cycles each
consisting of a rise to a specified
pressure and temperature for a specified
time and a gradual return to initial
condition. Following transient cycles
100 day exposure to live steam
0 psig @ 212°F.

Manner of Qualification

Test - Sequential

Qualification Document

Okonite's Engineering Report
No. 141 dated February 29, 1972

Additional Supporting Documents

Outline of Franklin Institute
Research Laboratory Report F-C3694

IEEE Transaction Paper T 78-046-8

POOR ORIGINAL

503 297

Description of Accident Environment

P.O. 12-1392/1392
300 V Instrument Cable
(CEFO Wire and Cables)

NCA-67 19/c No. 16 AWG.
NCA-48 12/c No. 16 AWG.
NCA-73 18/c No. 16 AWG.
NCA-35 2/c No. 16 AWG.
NCB-19 3/c No. 16 AWG.

Environment to which Guide is Qualified

LOCK
210°F
Reduce From 280°F
to 150°F
15.0°F
0 psig
0 to 30 min.
Reduce from 45
to 0 psig
30 to 60 min.
0 psig
260 min
7.2 x 10⁷ rads

Spray
0-6 hrs solution of boric acid
(2000-2100 ppm boron) buffered to
pH of 8.5 to 11 with NaOH >8 hrs
similar solution with a pH of 7
to 9

Qualification Document

Rockbestos (formerly Corro)
Letter dated 2-21-79 and its
attached report

Manner of Qualification

Test - Sequential

LOCK
Rise 1300 hrs - 8 150°C
Irradiated to 2 x 10⁷ rads
30 to 60 min.
260°F & 70 psig 0 to 10 sec
rise to 346°F & 10 sec to 5 min
313 psig
313 psig 5 min to 3 hr
Reduce to 140°F 5 min to 5 hr & 10 sec
260°F & 113 psig 5 hr to 5 hr & 10 sec to 5 hr
rise to 346°F + 5 min
346°F & 113 psig 5 min to 8 hrs
313 psig & 93 psig 8 hr to 11 hr
313 psig & 63 psig 11 hr to 15 hr
265°F & 26 psig 15 hr to 8 day
212°F & 0 psig 4 day to 30 day

Spray

Set 14 hrs of 30 day period - solution
of the following composition
0.18 molar BaSO₄
0.04 molar Na₂SO₄
NaOH to make pH between 9-11
Following above 10 day LOCA period and
additional period of 100 day at 200°F.

TEST

LOCK
0 to 2 mils
2 to 6 mils
360 mils
0 to 60 mils
40 psig
0 psig
3 x 10⁷ rads

To Temperature - Analysis
Na-Li melt calculated surface
temperature during limiting
period is 343° which does not
exceed qualification temperature of
Rockbestos (formerly Corro)
Letter dated 4-25-77
Pressure and Radiation = Test
Refer to LOCA Qualification

PCAR Section 3C and response
to comment 7-17
Rockbestos letter dated
4-25-77
LOCA qualification document

POOR ORIGINAL

503 298

Incident Location & Part, No.	Description of Accident Environment	Environment to which sample is qualified	Manner of Qualification	Qualification Document
P.O. MA-408/1-18 Thermocouple, Irradiation Heat Resistance Test Article MA-408-1C	LOOSELY CIMENTED, SOLVENT [LOCAL]	LOCK	Test - Sequential	B.I.W. letters dated: 2-7-75 1-17-72 12-14-71
ITEM #6 1 pair #16 copper GOLDBAR	280°F Surface from 280°F 0 to 30 Min to 150°F 30 to 60 Min 150°F 260 Min Reduce from 85 to 0 Paig 0 Paig 7.2 X 10 ⁶ Rads 7.2 X 10 ⁶ rads	Irradiated to 1 X 10 ⁶ rads 280°F at 45 Paig 60 min 205°F at 0 Paig 24 hrs		

Solid with the pH adjusted to 8-8.5 with
a 0.019 molar solution of NaOH for
2.5 hr period.

SPRAY:

0-4 hrs. Solution of boric acid
(1000-2100 pps boron) buffered to
a pH of 8.5 to 11 with NaOH
24 hr. similar solution
with a pH of 7 to 9

POOR ORIGINAL

503-299

Incident Description & Mark No.	Description of Accident Environment	Environment to which Equid. is Exposed	Manner of Irradiation	Irradiation Document
7-D. WA-422/1822 Triangular Cab & Insulated Wire & Cable	280°F Reduce from 280°F to 150°F 150°F 45 psi Reduce from 45 to 0 psig 0 psig 7.2 x 10 ¹⁹ rads	0 to 30 min: 30 to 60 min: >60 min: 0 to 30 min: 30 to 60 min: 360 min	Irradiated to 2 x 10 ¹⁹ rads 300°F ± 60 psig Reduce to 252°F ± 16 psig 252°F ± 16 psig	0 to 15 min 0 to 15 min 15 to 45 min 45 min to 13 day
ELA-72 Triam	0 psig	30 to 60 min	Spray:	B.Y.W. Engineering Company No. 2465-12 Rev. 4 specifically test h.e. 75C008)

Throughout 13 day period - A solution of 2,700 ppm boric acid buffered to a pH of 8 to 8.5 with NaOH.

Following above, an additional 17 days exposure to 200°F ± 0 psig.
at 7 to 9°.

POOR ORIGINAL

503 300

IDENTIFICATION & MARK NO.

CU-408/104

CU - Power Cable-Bent Tracing
Set

Description of Accident Environment

Loss of Coolant Accident (Local)

280°F Reduce from 280°F 0 to 30 min
to 150°F 30 to 60 min
150°F 360 min
0 to 30 min
0 to 0 psig
Reduce from 85 30 to 60 min
0 psig 360 min
7.2 x 10⁶ rads
Spray:
0-4 hr Solution of boric acid
14,000-2,100 ppm boron buffered
to a pH of 8.5 to 11 with NaOH.
24 hr Similar solution with a
pH of 7 to 9.

Environment to which LCCP is Qualified

LCCP

Aged 16 days at 250°F
Irradiated to .5 x 10⁶ rads and aged at
280°F for 7 days
For 31 day period
280°F/70 psig 0 to 10 sec
Rise to 340°F/
113 psig 10 sec to 5 min
340°F/113 psig 5 min to 3 hr
Reduce to 340°F 3 hr to 5 hr
280°F/70 psig 5 hr to 5 hr
and 10 sec
Rise to 340°F/
113 psig 5 hr and 10 sec to
340°F/113 psig 5 hr and 5 min
335°F/95 psig 5 hr and 5 min
to 8 hr
310°F/49 psig 8 hr to 11 hr
260°F/28 psig 11 hr to 15 hr
210°F/0 psig 15 hr to a day
a day to 31 day

MANNER OF QUALIFICATION

TEST = SEQUENTIAL

Qualification Document
Pratt & Whitney Research Laboratory
Report P-C-169
Additional Supporting Data
TID Transaction Paper T 76 044 04

Spray:
Continuously for 31 day period solution of
2,000 ppm boron as boric acid buffered
with NaOH to a pH of 9-11.
Irradiated to 1.5 x 10⁶ rads during the
31 day period. Total 3 x 10⁶ rads

POOR ORIGINAL

503 501

<u>Equipment Description & Mark No.</u>	<u>Description of Accident Environment</u>	<u>Environment to Which Equip. Is Qualified</u>	<u>Manner of Qualification</u>	<u>Qualification Document</u>
Motor Operated Valves - Elliot Company; 1-HOV-IV-115-1, 2-HOV-IV-115-2; P.O. NA-299; located in Chiller Room as components of self-cleaning strainers.	MSLR in turbine bldg. Equipment in Chiller Room exposed to:	None	None	None
	<ol style="list-style-type: none"> 1. High ambient temperature 211°F for duration of steam discharge in vicinity of chiller room air intakes - 30 minutes. 2. High ambient moisture content-saturated steam, 100% RH for duration of steam discharge - 30 minutes. 			
Miller Room Pump Pumps - Johnson Pump Company; 3-DB-P-10A, 03; P.O. NA-421; located in Chiller Room.	MSLR in turbine bldg. Equipment in chiller room exposed to:	<ol style="list-style-type: none"> 1. High ambient temperature 211°F at saturated atmosphere 2. High ambient temperature 211°F for duration of steam discharge in vicinity of chiller room air intakes 30 minutes. 3. High ambient moisture content-saturated steam, 100% RH for duration of steam discharge - 30 minutes. 	Vendor reply to TLX inquiry	TLX 3-28-79 - John Anderson to J. E. Krechting

Poor Original

503 302

Description & Work No.	Description of Accident Environment	Environment to which Equip. is Qualified	RODOS of Qualification	Qualification Document
<u>Centrifugal Fans - Buffalo Forge Co., P.O. MA-278</u>	LOCA - Fan motors exposed to: 1. Radiation Zone IV 40 yr dose + LOCA dose = 880 + 160 = 1040 rads	Radiation Dose of 7×10^6 rads	None	TEK-3-29-73 - W. B. Schmeidler J. E. Kretschmer
<u>4-40-hp located in Auxiliary Bldg., El. 2911-10*</u>				
<u>Axial Flow Fans - JOY Mfg. Co., P.O. No. MA-201; 1-KV-Y-71A-B</u>	LOCA - Fan motors exposed to: 1. Radiation 40 yr dose - 7×10^6 rads	None		
<u>located in Safeguards Bldg., El. 2677-6</u>				
		None		

POOR ORIGINAL

503 303

Environment Description & Part No.	Description of Accident Environment	Environment to which FwdP is Qualified	Number of Qualification Test	Classification Document
-O. N. N. 313/713 Reactor Confinement Electrical Termination - CDRX	<u>Loss of Coolant Accident (LOC)</u>			Conax Corp. Test Report IFS-107
Conaxtron Inc. No. W553 Polyulfone Terminal Block	280°F Reduce from 280°F to 150°F 150°F 45 psig Reduce from 45 to 0 psig 0 psig 7.2×10^7 rads	0 to 30 min 30 to 60 min 260 min 0 to 30 min 30 to 60 min 260 min Spray = 0 to 8 hours / acid (2000-2100 ppm) / a pH of 8.5 to 11.0 w/c NaOH. Beyond 8 hours a similar solution with a 7 to 9.	Radiation: 2.5 \times 10 ⁷ rads minimum 251°F \pm 25 psig 282°F \pm 45 psig 285°F \pm 45 psig 290°F \pm 57.5 psig 292°F \pm 68 psig 289°F \pm 69 psig 300°F \pm 56 psig 293°F \pm 67 psig 297°F \pm 47 psig Range Thermo aging 300°F for 74 hr	
Main Steam Line Break (MSLB)			SPRAXI	
	430°F 280°F 150°F 40 psig 0 psig 3×10^7 rads	0 to 7 min 2 to 60 min 260 min 0 to 60 min 260 min	Solution boron 1.60% ppm Buffered to 7.7 pH at +190°F, 10 ppm for 30 min. 140°F \pm 0 psig POR \pm 10 bar	

POOR ORIGINAL

503 304

Equipment Description & Part No.

Classification KAS-90-32

No. MA-43

Description of Accident Environment

Loss-of-Content Accident LOCAL

SEL Transmitter

280°F	0 to 30 min
Reduce from 280°F to 150°F	30 to 60 min
150°F	260 min
45 psig	0 to 30 min
Reduce from 45 to 0 psig	30 to 60 min
0 psig	>60 min
7.2×10^5 rads	

Spray = 0 to 8 hours solution of boric acid (2000-2100 ppm boron) buffered to a pH of 8.5 to 11.0 with NaOH. Beyond 8 hours similar solution with a pH of 9.

Rain Screen Line Break (PSLB)

430°F	0 to 2 min
280°F	2 to 40 min
145°F	>40 min
40 psig	0 to 60 min
0 psig	>60 min
3×10^5 rads	

Environment to Which Equip. Is Qualified

Name of Classification

ORIGIN - UN Document

Franklin Institute
Research Laboratories
(PRBL) Report P-CBJS
Incomel Inc. Test
Report Dated Nov. 1975

LOCs

2821°F	0 to 60 min
282150°F	60 to 180 min
150°F	180 min to 14 days
45 psig	0 to 60 min
450 psig	60 to 150 min
13.5 psig	150 min to 14 days

Radiation Exposure 2×10^5 rads

Spray = 15,000 ppm boric acid buffered to a pH of 10.5 with NaOH solution for 8 hours. Spray density = 0.15 gpa per ft².

KSLB

as above

POOR ORIGINAL

503 305

2-27

Equipment Description & Part No.

NAMCO Model EA-180
Limit Switch's
Located on the following
Control Valves

TV-80 100B, D, F
CC 101B
CC 102B, D, F
CC 105A, B, C
DA 100B
DG 100B
RM 100C
VG 100B
SS 100A
SS 101A
SS 102A
SS 103A
SS 106A
SS 112A

Description of Accident Environment**Loss-of-Coolant Accident (LOCA)**

280°F	0 to 30 min
Reduce from 280°F	
to 150°F	30 to 60 min
150°F	>60 min
45 psig	0 to 30 min
Reduce from 45	
to 0 psig	30 to 60 min
0 psig	>60 min
7.2×10^7 rads	

Spray:
0-4 hrs solution of boric acid
(2000-2100 ppm boron) buffered
to pH of 8.5 to 11 with NaOH
> hrs similar solution with a
pH of 7 to 9

Main Steam Line Break (MSLB)

230°F	0 to 2 min
280°F	2 to 60 min
165°F	>60 min
40 psig	0 to 60 min
0 psig	>60 min
3×10^7 rads	

Environment to Which Equip. Is Qualified**LOCA**

Heat aging at 300°F for 200 hrs mechanical
aging 100,000 cycles under electrical load

380°F	0 to 3 hrs
Reduce from 380°F	
to 120°F	3 to 5 hrs
SEQUENCE REPEATED	
250°F	to 3.5 days
200°F	3.5 to 30 days
70 psi	0 to 8 hrs
10 psi	8 hrs to 30 days

Radiation Exposure 2.04×10^8 rads

Spray: Boric acid and water buffered to
a pH of 10-11 with NaOH solution for 4
days, water spray for 26 days spray
density = .015 gpm/ft²

MSLB

Maximum surface temperature is 285°F per
ESG calculation 11712-ES-197-0 dated
3-16-78 and is well below qualification
temperature
Radiation Exposure see LOCA Test.

Manner of Qualification

Sequential Test -

Heat Aging
Mechanical Aging
Radiation Exposure
Seismic Testing
LOCA Test

Qualification Document

Report Entitled:

*Qualification of NAMCO controls
limit switch Model EA-180 to IEEE
Standards 344 (*75) 323 (*74)
and 382 (*72)*
dated 3-3-78 and revised 4-7-78

ESG Calculation 11712-ES-197-0
dated 3-16-78

Calculation

POOR ORIGINAL

Environment Description & Number	Description of Accident Environments	Environment to which group is qualified	anner of Qualification
P.O. RA-176/1976 Motor control Centers Loss of Control	Loss of Control Accident LOCAL	Test	Classification Document Klochner-Moeller - tier dated 3/16/79
	Radiation: 3×10^6 rads (based on 6 month LOCA). In addition, the 80 year radiation dose of 8×10^6 rads must be considered for a total possible radiation dose of $1.04 \times$ 10^6 rads.	Minimum total integrated doses of $1.4 \times$ 10^6 rads of gamma source radiation.	

POOR ORIGINAL

503 307

Event_Precision & Mark No.	Description_of_Accident_Environment	Environment_to_which_Equip._Is_Qualified	Number_of_Qualification	Qualification_Document
No. 0194 (Planned a Water Type Safety Valve)	Loss-of-Coolant_Accident [LOCA]	Radiation: 1×10^4 rads (based on 6 month LOCA). In addition, the 40 year radiation dose of 8×10^4 rads must be considered for a total possible radiation dose of 1.04×10^5 rads.	3.0 $\times 10^4$ rads gamma Radiation at Leucadia Inc., Parcypar, NJ Report No. R0003	
No. 0284 (Component Cooling Exchanger) 7 No. 1 (Big Tunnel Area)	Radiation Level: 80 yr integrated = 2×10^7 rads	Same as above		
No. 03-153A, B (Fuel Pool Cooled by HHD "Lower Level")	Radiation: 1×10^4 rads (based on 6 month LOCA). In addition, the 40 year radiation dose of 8×10^4 rads must be considered for a total possible radiation dose of 1.04×10^5 rads.	40 yr integrated = 2×10^7 rads		
No. 03-153A, B, C, D (Containment Isolation)	No. 03-153A, B (Containment Iso. Isolation)	Radiation: 1×10^4 rads (based on 6 month LOCA). In addition, the 40 year radiation dose of 8×10^4 rads must be considered for a total possible radiation dose of 1.04×10^5 rads.		
No. 0127 (Recirculation Spray System)	No. 0127 (Recirculation Spray System)	Radiation Level 10s rads	Letter from Vendor C. Bell (GT) March 10, 1979	

POOR ORIGINAL

503 303

Equipment Description & Part No.
P.O. No. 113/1113
Reactor Containment Electrical
Penetration - Open

Description of test environment

Environment to which equiv. is qualified

Plan of Qualification
Penetration Document

Item 1 of 2
Penetration Assemblies
Type IA - Instrumentation
IB - Control
IC, IID, IIB, INC, IID and
III - Low Voltage Power
III - Triaxial
IV - Thermocouples

Loss of Coolant Accident (LOCA)

280°F
Reduce from 280°F 0 to 30 min
to 150°F
150°F
30 to 60 min
360 min
0 to 30 min
Reduce from 45 to 0 psig
0 psig
4.2 x 10³ psig
Sprays
0-1 hr solution of boric acid (2,000-
2,100 ppm boron) buffered to a pH of
8.5 to 11.0 with NaOH beyond 4 hrs
similar solution with a pH of 7 to 9.

Penetration assemblies were tested by

Conex report Maximum Emergency
Environmental Test Report for
Electrical Penetration Assemblies
No. IP5-73-A dated 5/13/75
Radiation Test Almaraz Service
test CONEX Report IP5-117.

Chemical Spray - From 0-30 min, no chemical
spray was introduced from 20 min to 10 days
assembly was subjected to spray solution:
Boron content was "23 molar as H₃BO₃,
NaOH = 10⁻⁴ to 4 x 10⁻³ molar
pH = 5.0 to 8.0

Pressure and Temperature

Pressure 205 psig @ 200°F 0 to 30 min
Decrease from 45 psig to 0 psig 0 to 30 min
and 280°F to 245°F 30 to 60 min
150°F + 20°F @ 0 psig 1 hr to 10 days
- 4°F

Radiation

1 x 10⁴ rads gamma radiation min max

POOR ORIGINAL

503 309

Reported Condition & Mark No.
Form 2 of 2

Splices (Field and Factory)

Description of Accident Environment
Loss of Coolant Accident (LOCA)

280°F	0 to 30 min	Chemical Spray - From 0+ ~270 hr spray continuously with a solution of the following contents:
Reduce from 280°F to 150°F	30 to 60 min	Boron content = .23 molar (3,900 ppm) NaOH content = 10^{-4} to 4×10^{-2} Molar
150°F	260 min	pH = 7.7 to 7.8
45 psig	0 to 30 min	
Reduce from 45 to 0 psig	30 to 60 min	Temperature and PRESSURE
0 psig	>60 min	210°F & 45* psig
8.2 x 10 ⁻² Rads		Reduce from 45 to 0 psig
Spray:		30 to 60 min
0 to 4 hrs solution of boric acid (2,000-2,100 ppm boron) buffered to a pH of 8.5 to 11.0 with NaOH beyond a 1/2 molar solution with a pH of 7 to 9.		Reduce from 280°F to 140°F Raised from 140°F 150°F

Radiation

Environment to which Equipment Is Qualified

Chemical Spray - From 0+ ~270 hr spray continuously with a solution of the following contents:
Boron content = .23 molar (3,900 ppm)
NaOH content = 10^{-4} to 4×10^{-2} Molar
pH = 7.7 to 7.8

Temperature and PRESSURE

210°F & 45* psig
Reduce from 45 to 0 psig
30 to 60 min

Reduce from 280°F to 140°F
Raised from 140°F
150°F

Manner of Qualification

Splices were made using various representative cable types and sizes which had been attached to a prototype generator assembly. The prototype was first subjected to radiation exposure, then temperature pressure and chemical spray concurrently.

Radiation: Almarat Service Test
Conax Report: LPG-137

Conax Report: LPG-137

POOR ORIGINAL

503 310

P.O. M-112/131
SECTION CO-11
ELECTRICAL

DESCRIPTION OF ACCIDENT ENVIRONMENTS

ENVIRONMENT IN WHICH EQUIP. IS QUALIFIED

ITEM	MAIN LINE LINE BREAK (PSIG)	ITEM	MAIN LINE LINE BREAK (PSIG)
Type IIA - Instrumentation	0 to 2 min	280 psig	0 to 30 min
Type IIB - Control	2 to 60 min	Range 292 psig	to 220°F
Type IIC - IIA, IIB, IIC, IIB AND IIE - Low Voltage Power	16.5 psig	Range 220°F	30 to 60 min
	0 psig	Range 245 psig	to 165°F
	3.4 x 10 ⁻⁴ rad/s	(None 1)	60 to 1200 hr
		Range 6.7 to 56 psig	
		0 psig	0 to 30 min
		2.3 x 10 ⁻⁷ rad/s gamma radiation minimum	230 min

NOTE 1 - Temperature Qualification by analysis per Qualification Document #2.

QUALIFICATION DOCUMENTS

- (P-73)
1. QDRX Report "Maximum Emergency Environmental Test Report for Electrical Penetration Assemblies No. 1P-73" dated May 13, 1973.
 2. PSR Appendix 3C "Safety Related Equipment Temperature Transients During the Limited Main Steam Line Break" and IFC Comment 2-17 of the same subject.

POOR ORIGINAL

503

Document Description & Mark No.

P.O. 10-111111
Reactur Current Electrical

TEST LIST - CO-AN
Item 1 of 2
Splices (field and factory)

MINIMUM LINE BREAK TEST

0.00°F	0 to 2 min
24.0°F	2 to 60 min
16.5°F	260 min
40 psig	0 to 60 min
0 psig	260 min
3.4 x 10 ⁻⁶ rads	

Range 10°F	0 to 30 sec
253°F	0 to 30 sec
to 280°F	1 to 2 min
282.4°F	2 to 30 min
Range 110°F	
to 248°F	30 to 60 min
Range 110°F	80 min to 240 hr
to 150°F	0 to 30 sec
0 to 24 psig	1 to 30 min
45 psig	30 min to 240 hr
0 psig	
2.5 x 10 ⁻⁶ rads gamma radiation minima	

Description of Accident Incidents

DOC 11

Planer of Qualification

DOC 11

Classification Document

DOC 11

Classification Report

DOC 11

Report on Electrical Terminations

DOC 11

Subjected to Design Basis Accident

ENVIRONMENT NO. 175-103

dated October 5, 1973.

PSAB Appendix 1C Safety Related

Equipment Temperature Test Data

During the Limited Main Steam

Line Break and NRC Comment 7-17

of the same subject.

POOR ORIGINAL

503 312

NOTE 1 - TEMPERATURE
Qualification by analysis per Qualification
Document #2.

Equipment Description & Mark No.

P.O. PA-312

Inside Recirc. Spray Pump Motor
General Electric - 300 hp, 460 V,
1,175 R.P.M., Class B insulation,
Model: 5K637S-J1B

Description of Accident Environment

Loss-of-Coolant Accident (LOCA)

280°F	0 to 30 min
Reduce from 28°F	
to 150°F	30 to 60 min.
150°F	>60 min.
45 psig	0 to 30 min
Reduce from 45	
to 0 psig	30 to 60 min
0 psig	>60 min
7.2×10^7 rads	

Spray: 0 to 4 hr solution of boric acid (2000-2100 ppm boron) buffered to a pH of 8.5 to 11.0 with NaOH. Beyond 4 hrs similar solution with a pH of 7 to 9.

Environment to which Equip. Is Qualified

Loss-of-Coolant Accident (LOCA)

Pressure and Temperature - 45 psig at 475-500°F from 0-30 min. Pressure was reduced to 0 psig at 100°F +5°F within next 30 min. During this 60 min steam exposure motor was sprayed with chemical solution at 20 gpm. Motor was at full load throughout. Four cycles were run as described above, stopping motor between each cycle to take readings. At the fifth cycle till end of 7 day temp reduced to 150°F at 0 psig and sprayed continuously with chemical solution.

Radiation - Motor was exposed to an equivalent dose of 2×10^8 rads at a dose rate of 10.5×10^8 rads/hr

Chemical Spray - Spray continuously 0-7 days with a water solution of boric acid, lithium hydroxide and sodium hydroxide with the following concentrations:

Boron = 0.23 molar (as boric acid)
lithium hydroxide = 1.0×10^{-4} molar
sodium hydroxide = 1.0×10^{-2} molar

The above will result in a pH of 5.5 to 6.5.

Manner of Qualification

Motor was tested sequentially by first subjecting it to the cumulative radiation dose and then the steam/chemical spray with elevated temperature and pressure.

Qualification Document

Topical Report on G.E. Vertical Induction Motors Inside Contain Recirculation Spray Pump Motors Surry Power Station - Second Addendum to Cover Sheet Aging, Radiation Exposure, Vibration, Steam/Chemical Spray Exposure Qualification Test - Docket No 50-280 and 50-281 by M. W. Shee Vertical Motor Products Section General Electric Company, San Jose, California June 12, 1973 (pages 36 to 68)

POOR ORIGINAL

<u>Equipment Description & Mark No.</u>	<u>Description of Accident Environment</u>	<u>Environment to Which Equip. Is Qualified</u>	<u>Manner of Qualification</u>	<u>Qualification Document</u>
KA-255				
Inside Recirc. Spray Pump Motor General Electric 100 hp, 460 v, 7.15 S.P., Class H Insulation, Model: SX6319XJ18	Main Steam Line Break (MSLB) 830°F 0 to 2 min 280°F 3 to 60 min 115°F >60 min 80 psig 0 to 60 min 8 psig >60 min 3×10^7 rads	Main Steam Line Break (MSLB) Temperature - Motor was qualified to the design environment by analysis. Pressure - See LOCA qualification for this motor. Radiation - Motor was exposed to an equivalent air dose of 2×10^4 rads at a dose rate of $<0.5 \times 10^4$ rad/hr.	The motor was qualified by utilizing the LOCA qualification test results i.e., radiation exposure, temperature, pressure. A heat transfer calculation was performed (Ref. FSAF, Sec Ion 3C) to obtain the maximum surface temperature that will be experienced during a MSLB. This value (271°F) was then compared to the value (280°F) that the motor was tested for. Since the motor was qualified for the LOCA at a temperature of 280°F, the lower surface temperature of 271°F proved the acceptable operation of the motor during a MSLB.	1. Final Safety Analysis Report - Section 3C, (pages 1 to 21) 2. Topical Report on GE Vertical Induction Motors - Inside Containment Recirculation Spray Pump Motors - Surry Power Station - Second Addendum to Cover Heat Aging, Radiation Exposure, Vibration, and Steam/Chemical Spray Exposure Qualification Tests - Docket Number 50-280 and 50-281 by M. W. Sheets Vertical Motor Products Section, General Electric Company - San Jose, California June 12, 1973 (pages 36 to 68)

Poor Original

503

314

Accident Description & Hatch #s

	Description of Accident Environment	Description of Qualification	Environment in which Employee Is Qualified	Manner of Qualification
ENV-BD	100A, B, C, D, E, F CC 100A, B, C CC 101A, B CC 102A, B, C, D, E, F CC 103A, B CC 104A-1, B-2, B-3, B-4	Loss of Coolant Accident (LOCAL) 200°F Reduce from 280°F to 150°F	LOCK 460°F Reduce from 460°F to 300°F Reduce from 340°F to 240°F	Sequential Test Radiation allowed by: Environmental Exposure
CC 105A, B, C CV 150A, B, C, D DA 100A, B DE 100A, B LN 100A, B, C, D, E, F, G, H LR 101A, B RH 100A, B SI 100A, B SL 101A, B SS 102A, B SS 103A, B SS 104A, B SS 105A, B SS 106A, B SS 107A, B SS 112A, B WG 100A, B	C-1, C-2 45 psig Reduce from 45 to 0 psig 0 psig 7.2 x 10 ³ rads Spray 0-4 hrs 0-200 ppm boron buffered to (2000-200 ppm boron) buffered to a pH of 8.5 to 11 with NaOH 24 hrs similar solution with a pH of 7 to 9	150°F 260 min 0 to 20 min 30 to 60 min 150°F 45 psig Reduce from 45 to 0 psig 0 psig 7.2 x 10 ³ rads Spray 0-4 hrs 0-200 ppm boron buffered to (2000-200 ppm boron) buffered to a pH of 8.5 to 11 with NaOH 24 hrs similar solution with a pH of 7 to 9	150°F 129 psia 118 psia Reduce from 118° to 25 psia 32 to 34 min 52 min to 14 days	52 min to 14 days 0 to 2 min 2 to 12 min
			Radiation Exposure 5 x 10 ³ rads	
			NEIF Encompassed by above LOCK Test	

POOR ORIGINAL

MB 111A,ab

503 315

Classification & Mach No.

Q. No. EA-11
U.S.A.C. AF
AC-5-03 (181)
AC-5-08 (121)
AC-5-01 (181)
AC-5-02 (121)

Description of Accident Environment

Loss-of-Coolant Accident (LOCA).
Location: "1 x 10⁻⁶ rads.
Based on 6 month LOCA".
In addition, the 40 year radiation
dose of 1 x 10⁻⁶ rads must be
considered for a total possible
radiation dose of 1.0 x 10⁻⁶ rads.

Environment to which Propn. is Classified

Loss-of-Coolant Accident
Facility - 1 x 10⁻⁶ rads

Manner of Qualification

Tested

Classification Document

Loss of Coolant Accident
Letters dated 3/21/79 and
4/25/79 certifying compliance
with Title 10 of Imperial Corp

POOR ORIGINAL

505 31

<u>Equipment Description & Mark No.</u>	<u>Description of Accident Environment</u>	<u>Environment to Which Equip. Is Qualified</u>	<u>Manner of Qualification</u>	<u>Qualification Document</u>
Marathon Series 200 and 1500 terminal blocks (Phenolic)	<u>Loss-of-Coolant Accident (LOCA)</u> Radiation: 1×10^6 rads (Based on 6 month LOCA). In addition, the 40 year radiation dose of 4×10^4 rads must be considered for a total possible radiation dose of 1.08×10^6 rads.	Radiation: Unfilled Phenolic can withstand a gamma exposure dose over 1×10^6 rads before there is any significant effect on the phenolic.	Terminal Block material was compared with identical material for the effects high level radiation	REIC Report No. 23 Radiation Effect Information Center, Columbus, Ohio. Buchanan Product Manual Insert 2.1 Rev. 8/23/76
Connectron Type NSZ-3, NSS-3 and PSU's Terminal Blocks. (Nylon)		Radiation: Nylon has been test to a gamma exposure dose over 10^6 rads with no effect.		
Thermo-Electric Terminal Block No. 3225 (Thermosetting Phenolic)				
GE Terminal Blocks EB5 and EB25 (Phenolic)				
Westinghouse Type TBLA Terminal Blocks (Nylon)				

POOR ORIGINAL

503 317

Resident Description & Part No.

Resistive Film Field Purchased

Loss-of-Coolant Accident - LOCAL

Glonite Termination Tape Field Purchased

q-95 Insulating Tape

q-15 Jacketing Tape

Experiments to Which Equipment Qualified

LOCA	Manner of Qualification
800°F Reduce from 280°F to 150°F	0 to 30 min 30 to 60 min 260 min 0 to 30 min 16 psig/252°F for 7 days
45 psig Reduce from 45 to 0 psig	30 to 60 min 260 min
0 psig 7.2 x 10 ³ rads	16 psig/252°F for 8 hours Spray 10,000 rpm boric acid buffered with NaOH to a pH of 10.5 throughout the PWR exposure period.
SPCR Exposure:	A series of transient cycles each consisting of a rise to a specified press. and temp. for a specified time and a gradual return to initial conditions. Following transient cycle 100 day exposure to live steam 0 psig, 212°F
HSI	Maximun calculated surface temperature during limiting KSL is 270°F which does not exceed qualification temperature of 315°F given in Geonite Engineering Report No. 141.
Main Steam Line Break (PSL)	0 to 2 min 2 to 60 min 240 min 0 to 60 min 260 min

Qualification Document

Oxonite's Engineering Report
No. 141 dated February 29, 1972

Manner of Qualification

Test - Sequential

SEN Calculation ES-107
Transient Temperature Transient
for Oxonite Tape Splices

Temperature - Analysis

Maximum calculated surface temperature during limiting KSL is 270°F which does not exceed qualification temperature of 315°F given in Geonite Engineering Report No. 141.

Pressure and Radiation - Test

Refer to LOCA qualification

POOR ORIGINAL

503 318

Equipment Description & Mark No.

Raychem heat shrinkable field
splicing material w/CSF type coated
with Type-N adhesive

Raychem high voltage terminations
HVT

Raychem high voltage bus connectors
HVBC

Description of Accident Environment

Loss-of-Coolant Accident (LOCA)

Radiation: 1×10^4 rads (based on 6 month LOCA). In addition, the 40 year radiation dose of 4×10^4 rads must be considered for a total possible radiation dose of 1.04×10^4 rads.

Radiation: 1×10^4 rads (based on 6 month LOCA). In addition, the 40 year radiation dose of 4×10^4 rads must be considered for a total possible radiation dose of 1.04×10^4 rads.

Radiation: 1×10^4 rads (based on 6 month LOCA). In addition, the 40 year radiation dose of 4×10^4 rads must be considered for a total possible radiation dose of 1.04×10^4 rads.

Environment to which Equip. Is Qualified

Postulated loss-of-coolant accident with a radiation exposure of 7.5×10^4 rads plus an additional 5×10^4 rads of gamma irradiation for a total qualified dose of 3×10^5 rads

Irradiation of the materials in a cobalt 60 gamma source at 0.50 mrads per hour to total doses of 3×10^4 rads

Irradiation of the material with 8×10^4 rads

Manner of Qualification

Combined thermal and radiation aging period followed by a simultaneous exposure to steam, chemical spray and gamma radiation

Sequence of test 1st thermal aging then irradiation

Qualification Document

Raychem Technical Report F-C4033,
Jan. 1975

Raychem Report #71100 Revision 1

Sequence of test 1st thermal aging followed by irradiation

Letter from Raychem dated 4/28/75
and EPRIET PRO Raychem Report
ER1508/3

POOR ORIGINAL

503 319