



Commonwealth Edison  
One First National Plaza, Chicago, Illinois  
Address Reply to: Post Office Box 767  
Chicago, Illinois 60690

JE. R. A. TERA

July 2, 1979

Mr. James G. Keppler, Director  
Directorate of Inspection and  
Enforcement - Region III  
U.S. Nuclear Regulatory Commission  
799 Roosevelt Road  
Glen Ellyn, Illinois 60137

SUBJECT: Dresden Station Units 1, 2 and 3  
Quad Cities Station Units 1 and 2  
Zion Station Units 1 and 2  
Response to IE Bulletin No. 79-11  
NRC Docket Nos. 50-10/237/249,  
50-254/265, and 50-295/304.

REFERENCE (a): May 22, 1979 letter from James G. Keppler  
to Byron Lee, Jr. transmitting IE Bulletin  
No. 79-11.

Dear Mr. Keppler:

Reference (a) transmitted IE Bulletin No. 79-11  
regarding "Faulty Overcurrent Trip Device In Circuit Breakers  
for Engineered Safety Systems". Commonwealth Edison Company's  
response to that Bulletin for Dresden, Quad Cities and Zion  
Stations follows.

Investigations at Dresden, Quad-Cities and Zion  
Stations have shown that no Westinghouse DB-50 and DB-75  
Circuit Breakers are used in safety-related systems at these  
stations. In addition, none of these breakers are currently  
stored at these stations for use as spares.

Please address any additional questions that you might  
have regarding this matter to this office.

Very truly yours,

Cordell Reed  
Assistant Vice-President

509 222

JUL 6 1979

7908080 523 7