UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

TERA NRC PDR

Docket Nos. 50-373
and 50-374

JUN 0 5 1979

Mr. L. O. DelGeorge
Nuclear Licensing Administrator
Commonwealth Edison Company
Post Office Box 767
Chicago, Illinois 60690

Dear Mr. DelGeorge:

SUBJECT: UTILIZATION OF ASME CODE CASE N-240

In your letter of May 21, 1979, you indicated that you intended to apply the approved ASME Code Case N-240, exempting certain piping-subject to the requirements of the ASME Code from hydrostatic testing in your La Salle Station, and you requested our acceptability of this code case for immediate use. We find this code case to be acceptable and may be referenced in your Final Safety Analysis Report.

Sincerely,

Olan D. Parr, Chief
Light Water Reactors Branch No. 3
Division of Project Management

cc: Mr. Byron Lee, Jr.
Vice President
Commonwealth Edison Company
P. O. Box 767
Chicago, Illinois 60690

Richard E. Powell, Esq.
Isham, Lincoln & Beale
One First National Plaza
Suite 2400
Chicago, Illinois 60670

Dean Hansell, Esq.
Assistant Attorney General
State of Illinois
188 West Randolph Street
Suite 2315
Chicago, Illinois 60601

524 344

639

7908080