



Portland General Electric Company

Charles Goodwin, Jr. Assistant Vice President

June 12, 1979

Trojan Nuclear Plant
Docket 50-344
License NPF-1

Mr. R. H. Engelken, Director
U.S. Nuclear Regulatory Commission
Region V
Suite 202, Walnut Creek Plaza
1990 N. California Blvd.
Walnut Creek, California 94596



Dear Sir:

Enclosed is our response to IE Bulletin 79-01 concerning environmental qualifications of Class IE equipment at the Trojan Nuclear Plant. This Bulletin and IE Circular 78-08 required examination of all installed safety-related electrical equipment and the determination that proper documentation exists to assure that this equipment would function under postulated accident conditions. Supplemental information requested at the PGE/Westinghouse/NRC meeting in Washington, D. C. on June 8 concerning this subject will be transmitted by June 15, 1979.

If you have any questions or concerns, please contact me.

Sincerely,

C. Goodwin, Jr.
Assistant Vice President
Thermal Plant Operation and
Maintenance

CG/SML/4kk3A27

Enclosure

c: Mr. Lynn Frank, Director
State of Oregon
Department of Energy

533 283

7908090 601 Q

72-142

ENCLOSURE 1

Response to NRC IE Bulletin No. 79-01
Environmental Qualification of Class 1E Equipment

1. Complete the re-review program described in IE Circular 78-08 within 120 days of receipt of this Bulletin.

PGE Response

The re-review program described in IE Circular 78-08 is complete per the attached document with the exception of PGE's response to an NRC request for supplemental information concerning the short-term trip capabilities and long-term monitoring capabilities of certain installed in-Containment Barton and Foxboro signal transmitters (pressurizer level, RCS wide range pressure, steam generator level, reactor coolant hot/cold leg temperature RTDs) and means for providing interim backup monitoring. This request was made at a joint NRC/Westinghouse/PGE meeting held in Washington D.C. on June 8, 1979. PGE's response will be provided in a supplement to this submittal, as stated in the cover letter.

2. Determine if the types of stem mounted limit switches described above are being used or planned for use on safety-related valves which are located inside containment at your facility. If so, provide a written report to the NRC within the time frame specified and to the address specified in Item 4 below.

PGE Response

No NAMCO switches of these model numbers are in service in a Containment environment at the Trojan Nuclear Plant. As required by the previously issued IE Bulletin 78-04, unqualified NAMCO switches in the Trojan Containment were replaced if they were found to be performing any one of the following functions:

- a. Latch-in capability for valve actuation control circuitry,
- b. Interlocks with other safety-related valves, or
- c. Status panel indication in the control room.

Switches performing simple open-close indication at the valve control switches were not replaced.

3. Provide written evidence of the qualification of electrical equipment required to function under accident conditions [this written evidence should include: 1) component description; 2) description of the accident environment; 3) the environment to which the component or equipment is qualified; 4) the manner of qualification which should include test methods such as sequential, synergistic, etc; and 5) identification of the specific supporting qualification documentation].

533 284

For those items not having complete qualification data available for review, identify your plans for determining qualification either by testing or engineering analysis or a combination of these, or by replacement with qualified equipment. Include your schedule for completing these actions and your justification for continued operation.

PGE Response

Enclosed please find Attachment 3 entitled "Environment Qualification Review of Class I^E Electrical Equipment". The following comments are pertinent to this document.

- a. Trojan FSAR Figure 3.11-2 (LOCA temperature) and Figure 3.11-1 (LOCA pressure) are enclosed as Attachments No. 1 and 2, respectively, to assist in the evaluation of equipment temperature and pressure qualifications.
- b. As discussed in the cover letter, a supplement to this submittal will respond to NRC questions concerning short- and long-term qualification requirements and the capability of instruments performing a pressurizer level, RCS pressure, and steam generator level function. This supplement may identify necessary revisions to the Trojan FSAR.
- c. The qualification documentation for Rosemount Model 176KF and 176KS RTDs (pages 6 and 7) is the result of testing completed since the Trojan FSAR was completed. The FSAR will be revised to reflect this change.
- d. Some NAMCO stem-mounted limit switches (Model D2400 and Model D2400X identified on pages 18, 19, 20, 21 and 22) are not qualified for post-accident conditions. However, these switches only perform simple indication functions as discussed above, in item 2, and are therefore satisfactorily qualified for their non-accident environment conditions.
- e. The terminal boxes/terminal blocks listed on page 23 are utilized to provide field junction points for the reactor coolant hot/cold leg temperature and ΔT RTDs (Rosemount Model 176KF and 176KS). The qualification documentation referenced for these terminal boxes/terminal blocks is satisfactory except in the areas of peak pressure (40 psia versus 60 psia) and integrated radiation exposure (5×10^6 R versus 1×10^7 R). PGE judges that the difference in pressure has no significance with regard to terminal blocks. The difference in radiation qualification is of more consequence. These are a high-quality GE type EB-5 terminal block in a 1/16-in. thick steel enclosure. Similar provisions for terminating cable are found in other qualified Containment equipment. PGE sees no need for additional qualification data.

533 285

- f. The review of the environmental qualification of electrical equipment located outside the Containment references the industry standards that apply to specific types of electrical equipment. These industry standards are based on operating experience and consider the effects of the environment on the electrical equipment. Industry standards allow temperature rise limitation tests to be performed at the environmental conditions existing at the manufacturer's location. For example, proper testing of a motor at an ambient temperature of 30°C (in accordance with the industry standard, NEMA Standard MG1) and meeting appropriate temperature rise limitations will qualify the motor for service in temperatures of 10°C to 40°C. Equipment tested in accordance with these temperature rise limitations have demonstrated, by operating experience, satisfactory operation over a normal range of environment. The majority of electrical equipment (motors, switchgears, batteries, etc) at Trojan was tested within the requirements of current industrial standards. It is PGE's conclusion therefore that equipment tested to industry standards and which operates within a normal environment will function properly when required during actual operating conditions.
4. Report any items which are identified as not meeting qualification requirements for service intended to the Director, Division of Operating Reactors, Office of Nuclear Reactor Regulation, Nuclear Regulatory Commission, Washington D.C., with a copy to the appropriate NRC regional office within 24 hours of identification.

PGE Response

In response to IE Circular 78-08, PGE performed walk-downs of various Class I equipment inside Containment. PGE reported to the NRC that several splices and cables to the pressurizer level transmitters inside Containment were improperly made and thus were unqualified (Licensee Event Report 78-27). Those unqualified splices were immediately repaired.

The motor operator for valve MO-10010 was found to be below the post-LOCA Containment water level. This motor operator is not qualified for submerged operation. The valve is one of the Containment isolation valves for one of the redundant hydrogen vent systems. This motor operator was identified as not qualified for its intended purpose by telephone conversation between L. W. Erickson of PGE and C. Trammell of the NRC on May 18, 1979. Written notification was performed by letter from C. Goodwin, Jr., of PGE to A. Schwencer of the NRC dated June 1, 1979. Design and construction activities to relocate valve MO-10010 above the post-LOCA containment water level have been initiated and will be complete by June 24, 1979.

533 286

A meeting was held at 4 pm on Wednesday, September 13, 1978 in PGE offices to review the results of a two-day NRC inspection. At that meeting, P. Morrell of the NRC, Region V, requested that the following additional items be addressed in PGE's response to IE Circular 78-08:

1. Review Class 1E equipment that may be submerged or located where it could be affected by fuel pool boiling, or a steam line break outside Containment.

PGE Response

Attachment 4 identifies equipment that will become submerged during the loss of coolant accident. The qualification of items 1, 2 and 3 will be addressed by supplemental submittal as noted above. The remainder of these submerged items are not required for long-term ECCS function (see FSAR Section 15.4.1.6) with the exception of the cable in the cable tray. This cable is qualified by prototype test for long-term submerged operation. No Class 1E equipment is located where it will be affected by the fuel pool boiling environment (elevation 93 ft of the Fuel Building). Equipment that may be located in a main steam line break environment is discussed on the environmental preface page of Attachment 3.

2. Confirm that a LOCA constitutes the worst case environment for equipment inside Containment.

PGE Response

A Main Stream Line Break (MSLB) accident inside Containment results in superheated vapor conditions that could result in a higher Containment temperature than if a LOCA were to take place. However, in general, lower levels of Containment peak pressure will result. A superheat condition (with corresponding high Containment atmosphere temperature) should have no significant effect on electrical equipment temperatures because the equipment surface temperature should closely follow the Containment saturation temperature, which is substantially lower than the peak vapor temperature during the superheat phase of the accident. The reason for this is that energy transfer from the Containment atmosphere to heat sinks is significant only when the sink surface is cooler than the saturation temperature so that condensation can occur. If the equipment surface temperature were to become higher than saturation, then the low energy transfer mechanism of convection would govern heat transfer. Since the Containment peak pressure is at a maximum following the design basis LOCA, the Containment saturation temperature for a MSLB accident is no higher than would be the case for a LOCA. It is on these bases that the worst-case environment for Containment-mounted equipment is specified to result from the design basis LOCA.

3. Describe program for identifying items such as terminal blocks, connectors, splices, etc. inside Containment that are of specific NRC cause of shutdowns at other plants.

PGE Response

Representative Class IE equipment located in the Containment that must function as described in Tables 3.11-1 and 6.2-1 of the FSAR was selected for the environmental qualification survey. The circuits for this equipment were checked from the Containment penetration to the end device to insure that all components such as connectors, terminal blocks, and splices were in accordance with the design drawings.

Color-marked prints, showing the cable routing, were developed for the survey team to aid them in following the cables in the plant. The survey team developed a checkoff list for each circuit that identified the circuit and all its components between the Containment penetration and the end device. The checkoff list information was then compared with the design drawings to identify any "unqualified" components.

The survey was completed by December 19, 1978.

4. Confirm radiation qualification exposure for Class 1E items in the Control and Auxiliary Buildings.

PGE Response


Radiation qualification noted on Attachment 3.

5. Confirm that environmental testing was sequential and the effects cumulative.

PGE Response


Refer to the "Remarks" column for equipment in Attachment 3.

Based on the above, we have concluded that proper documentation exists to assume that the safety-related electrical equipment will function under the environmental conditions created by the postulated loss-of-coolant accident and main stream line break, as specified in the Trojan Final Safety Analysis Report. Supplemental information will be provided to address in-Containment signal transmitter qualifications and interim backup monitoring.



ATTACHMENT NO. 1

FSAR Figure 3.11-2 Environmental Conditions for Equipment Testing - Temperature as a Function of Time



ATTACHMENT NO. 2

FSAR Figure 3.11-1 Environmental Conditions for Equipment Testing - Pressure as a Function of Time

PORTLAND GENERAL ELECTRIC COMPANY
TROJAN NUCLEAR PLANT
ENVIRONMENT QUALIFICATION REVIEW
OF CLASS I ELECTRICAL EQUIPMENT

ATTACHMENT NO. 3

June 12, 1979

533 666
291

TROJAN NUCLEAR PLANT
ENVIRONMENT QUALIFICATION REVIEW OF CLASS I⁺ ELECTRICAL EQUIPMENT

ENVIRONMENT DEFINITIONS FOR QUALIFICATION REVIEW

Environment I - Containment during LOCA

Temperature: Figure 3.11-2 of Trojan FSAR (Attachment 1)
Pressure: Figure 3.11-1 of Trojan FSAR (Attachment 2)
Humidity: 100%
Chemical: Boric Acid or pH 4.9 or boric acid - sodium hydroxide mixture of pH 10.0.
Radiation: 2.1×10^7 rads (reference 3.11.3.1 of Trojan FSAR)

Environment II - Fuel and Auxiliary Bldg.

Temperature: 50 degrees F to 104 degrees F
Pressure: + 1/2 psia
Humidity: 20 - 100%
Radiation: 4.0×10^8
Chemical: None

Environment III - Control and Intake Structure

Temperature: 50 degrees F to 104 degrees F
Pressure: Normal
Humidity: 20 - 100%
Radiation: Normal (outside containment)
Chemical: None

Environment IV - Between Containment and Aux./Fuel Bldg.
(Outside Environment)

Temperature: -5 degrees F to 107 degrees F
Pressure: None
Humidity: 0 to 100%
Radiation: Normal (outside containment)
Chemical: Exposed to water spray from sprinkler system

Environment V - Control Room

Temperature: 50 degrees F to 110 degrees F
Pressure: Normal
Humidity: 20 to 85%
Radiation: Normal
Chemical: None

Definitions of terms used in this report:

Sustained Type I: (1) Thermal aging, (2) radiation application equivalent to the aging and accident doses [or aging dose only], (3) LOCA simulation involving pressure, temperature, and chemical spray, [(4) radiation equivalent to accident dose].

Sustained Type II: Same as Type I except no thermal aging.

Synergistic: (1) Combined thermal and radiation aging, (2) combined radiation and LOCA simulation.

Short Term Capability: Qualification tested in post-LOCA environment for less than 24 hr.

Long Term Capability: Qualification tested in post-LOCA environment for 24 hr or more.

Environment VI - Turbine Bldg (Class IE Structure Only)

Temperature: 50 degrees F to 115 degrees F
(Diesel Generator Rooms)
Pressure: Normal
Humidity: 20 - 100%
Radiation: Normal
Chemical: Exposed to water spray and Halon from fire protection systems (Diesel Generator Rooms and Auxiliary FW Pump Rooms)

Environment VII - Main Steam Line Rupture Outside Containment

The consequences of a steam line rupture would be limited to the Turbine Building and the Main Steam Support Structure as analysed in PGE-1004 dated January 1974. The Control, Fuel or Auxiliary Building would not be exposed to the effects of a steam line rupture.

Turbine Bldg.

Temperature: 214°F
Pressure: 1.0 psig
Humidity: 100%

The Class IE equipment located in the Turbine Building (switchgear, emergency diesel generators and auxiliary feedwater pumps) are located in compartments that would prevent any appreciable steam from entering these areas.

Main Steam Support Structure

Temperature: 225°F
Pressure: 4.3 psig
Humidity: 100%

The Main Steam Support Structure is divided into four individual compartments, and the conditions listed above pertain to the compartment where the rupture occurred. There are no safety-related electrical equipment necessary for a safe shutdown after a main steam line break that is located in this compartment.

TROJAN NUCLEAR PLANT

262

THILOAN NUCLEAR PLANT
ENVIRONMENTAL QUALIFICATION REVIEW OF CLASS IIE ELECTRICAL EQUIPMENT

Page 1

INSIDE CONTAINMENT

ITEM	DESCRIPTION	SPEC. NO.	LOCATION BLDG.	ENVIRONMENTAL SERVICE CONDITION	VENDOR DOCUMENTATION			METHOD OF QUALIFICATION AND REMARKS			
					TEMP. (°F)	PRESSURE (PSIA)	HUMIDITY %				
A701	Vertical turbine generator nacelle	E-20	Containment	5ft to 7ft	I & IV	300	60	100	1×10^8 R w/ NaOH	Boric acid Qualification by Test in Phenol Report No. 12-1236, August 23, 1972. Sequential Type I - Long-term capability	
-	Vertical turbine at exterior, available *	E-20	Containment	5ft to 7ft	I & IV	300	60	100	1×10^8 R w/ NaOH, pH 9.5-11.0	Boric acid Qualification by Type test in Phenol test report FC-402-3 (Franklin Institute Research Lab.) Synergistic Long-term capability.	
Y701-Sub Y702-Sub Y703-Sub Y704-Sub	Containment Air Cooler Exhaust Containment Motor	H-66	Containment	205ft	I	300	75	100	1×10^9 R	Boric acid solution, pH 9-10	Qualification by Type Test in American Air Filter test report AAFTR-7101 (also reference technical paper IEEE TIC38E-61-1971). Sequential Type I - Long-term capability.
X-118 2-113	Hydrogen Exhauster *	H-87	Containment	9ft	I	300	69	100	2×10^8 R w/ NaOH, pH 10	Boric acid Qualification by Type Test in West report KCAP, 7109-L supplement 2 and supplement 3, synergistic - Long-term capability.	
X-119A 2-114	Hydrogen Exhauster Exhaust Motor	F-09	Containment	215ft 215ft	I	300	75	100	1×10^9 R	Boric acid solution, pH 9-10	Qualification by Type Test in American Air Filter test (reference technical paper IEEE TIC38E-61). Sequential Type I - Long-term capability.
I-2	Control Cable, Control Cable, I-2-13, EP, 600V)	E-22	All	All	I	340	100	100	2×10^8 R	Boric acid w/ NaOH, pH 9.0	Qualification by Type test in Franklin Institute Research Lab. Report F-C3135, Sept. 1971. Sequential Type II - Long-term capability.
I-03	Control Cable, I-03-13, EP, 600V)	E-22	All	All	I	340	100	100	2×10^8 R		
N-05	Control Cable (5.5-116, EP, 600V)	E-22	All	All	I	340	100	100	2×10^8 R		
N-07	Control Cable (5.5-116, EP, 600V)	E-22	All	All	I	340	100	100	2×10^8 R		
N-14-N	Normal Containment Environment Indicators			9ft	Normal Containment Environment	300	100	100	5×10^5 R		Detectors are not required for Containment Accident situations. Environment parameters were developed by research and production tests by Westinghouse Electric Tube.

POOR ORIGINAL

533 293

THALIAN MULTIFAR PLANT
ENVIRONMENTAL QUALIFICATION REVIEW OF CLASS I E ELECTRICAL EQUIPMENT

Page 2

INSIDE CONTAINMENT

POINT IDENT	DESCRIPTION	SPEC	LOCATION	ENVIRONMENTAL SERVICE CONDITION	VENDOR DOCUMENTATION			NOTES OF QUALIFICATION AND REMARKS
					BLDG.	ELEV.	TEMP. (°K)	
P10	Power Cable General Cable, 3/fc-#14, EP, 600V)	E-22	All	All	340	100	100	2 x 10 ⁸ R Boric acid w/ NaOH, pH 9.6 Qualif by Type test in Franklin Institute Research Lab., Report P-Q3125, Sept. 1971 Sequential Type II.
P17	Power Cable General Cable, 3/fc-#12, EP, 600V)	E-22	All	All	340	100	100	2 x 10 ⁸ R Long-term capability
P22	Power Cable General Cable, 3/fc-#10, EP, 600V)	E-22	All	All	340	100	100	2 x 10 ⁸ R
P16	Power Cable General Cable, 3/fc-#10, EP, 600V)	E-22	All	All	340	100	100	2 x 10 ⁸ R
P23	Power Cable General Cable, 3/fc-#10, EP, 600V)	E-22	All	All	340	100	100	2 x 10 ⁸ R
P11	Power Cable General Cable, 1/fc-#22, EP, 600V)	E-22	All	All	340	100	100	2 x 10 ⁸ R
P10	Power Cable General Cable, 1/fc-#10, EP, 600V)	E-22	All	All	340	100	100	2 x 10 ⁸ R
P03	Power Cable General Cable, 1/fc-#10, EP, outlet)	E-22	All	All	340	100	100	2 x 10 ⁸ R
P05	Power Cable General Cable, 1/fc-#10, EP, 600V)	E-22	All	All	340	100	100	2 x 10 ⁸ R
P13	Power Cable General Cable, 1/fc-#8, EP, 600V)	E-22	All	All	340	100	100	2 x 10 ⁸ R
P18	Power Cable General Cable, 1/fc-#6, EP, 600V)	E-22	All	All	340	100	100	2 x 10 ⁸ R

533 294

Four Originals

TROJAN NUCLEAR PLANT
ENVIRONMENTAL QUALIFICATION REVIEW OF CLASS 1E ELECTRICAL EQUIPMENT

Page 5

INSIDE CONTAINMENT

EQUIPMENT NO.	DESCRIPTION	SPECIFIC NO.	LOCATION	TEMP. (°F)	PRESSURE (PSIA)	HUMIDITY	RADIATION	CHEMICAL	HEATING AND QUALIFICATION AND REFRAMES	
									TEST	
<u>INSIDE CONTAINMENT</u>										
101	Instrumentation cable American insulated wire, 1/8"-Ø16, EP 300V	E-23A	All	1	286	60	100	1 x 10 ⁸ R	Boric acid w/ NaOH, pH 9.0	Qualified by Type test in Franklin Institute Research Lab. Report F-C363, Aug. 1972. Sequential Type II. Long-term capability.
102	Instrumentation cable, 1/8"Ø16, 2/8"-Ø16, shield, EP 300V	E-23A	All	1	286	60	100	1 x 10 ⁸ R		Qualified by Type test in Franklin Institute Research Lab. Report F-C363, Aug. 1972. Sequential Type II. Long-term capability.
103	Instrumentation cable, 1/8"-Ø16, 2/8"-Ø16, shield, EP 300V	E-23A	All	1	286	60	100	1 x 10 ⁸ R		Qualified by Type test in Franklin Institute Research Lab. Report F-C363, Aug. 1972. Sequential Type II. Long-term capability.
104	Instrumentation cable, 1/8"-Ø16, 2/8"-Ø16, shield, EP 300V	E-23A	All	1	286	60	100	1 x 10 ⁸ R		Qualified by Type test in Franklin Institute Research Lab. Report F-C363, Aug. 1972. Sequential Type II. Long-term capability.
202	Instrumentation cable, 1/8"-Ø16, shield, EP 300V	E-23A	Containment	1	286	60	100	1 x 10 ⁸ R		Same as Cable 101.
203	Instrumentation cable, 1/8"-Ø16, shield, EP 300V	E-23A	Containment	1	286	60	100	1 x 10 ⁸ R		Same as Cable 101.
204	Instrumentation cable, 1/8"-Ø16, shield, EP 300V	E-23B	Containment	1	286	60	100	1 x 10 ⁸ R		Same as Cable 101.
301	Instrumentation cable - Triaxial cable, PE, 5kV	E-23B	Containment	1	307	50	100	3.5 x 10 ⁷ R by weight		Sequential Type II. Long-term capability. Source, intermediate and power range detectors, signal cable - not required for containment accident situations. Reference IEEE paper 68-1051 for qualification.
LT459	Proximity sensor, PE, 5kV	H1	Containment	71 ft	1	300	60	2 x 10 ⁸ R	1.5% Boric acid w/ NaOH, pH 9.25-10.0	Qualified by Type test in W Test Report WCAP-8561. Sequential Type II but separate testing for LOCA and radiation.
LT460	Pressure transmitter	H1	Containment	71 ft	1	300	60	2 x 10 ⁸ R		Short-term capability.
LT461	Pressure transmitter	H1	Containment	71 ft	1	300	60	2 x 10 ⁸ R		Qualified by Type test in W Test Report WCAP-8561.

533 295

POOR
ORIGINAL

TROJAN NUCLEAR PLANT
ENVIRONMENTAL QUALIFICATION REVIEW OF CLASS 1E ELECTRICAL EQUIPMENT

ITEM NUMBER	DESCRIPTION	SPEC NO.	BLDG.	LOCATION	ELEV.	ENVIRONMENTAL SERVICE CONDITION	VENDOR DOCUMENTATION			METHOD OF QUALIFICATION AND REMARKS
							TEMP. (°F)	PRESSURE (PSIA)	HUMIDITY (%)	
<u>INSIDE CONTAINMENT</u>										
PT 455	Pressurizer	MI	Containment	73 ft	I	286	60	100	2 x 10 ⁸ R	Post accident spray solution to Model 386 in W Test Report KCAP-7744. Also W letter to NRC dated July 25, 1975, on the corrosion effects of DBA on safety related transmitters and W letter to NRC, Oct. 1, 1975, on accuracy tolerances for accident condition. Sequential Type II. Short-term capability.
PT 456	Pressurizer Circuit	MI	Containment	71 ft	I	286	60	100	2 x 10 ⁸ R	Qualification per Franklin Institute Research Lab Report C-2923. Sequential Type II. Short-term capability.
PT 512	Steam Generator Circuit Flow	MI	Containment	73 ft	I	286	60	100	2 x 10 ⁸ R	Qualification per Franklin Institute Research Lab Report C-2923. Sequential Type II. Short-term capability.
PT 513	Steam Generator Circuit Flow	MI	Containment	50 ft	I	286	60	100	2 x 10 ⁸ R	Qualification per Franklin Institute Research Lab Report C-2923. Sequential Type II. Short-term capability.
PT 517	Steam Generator Circuit Flow	MI	Containment	50 ft	I	286	60	109	2 x 10 ⁸ R	Qualification per Franklin Institute Research Lab Report C-2923. Sequential Type II. Short-term capability.
PT 532	Steam Generator Circuit Flow	MI	Containment	50 ft	I	286	60	100	2 x 10 ⁸ R	Qualification per Franklin Institute Research Lab Report C-2923. Sequential Type II. Short-term capability.
PT 533	Steam Generator Circuit Flow	MI	Containment	50 ft	I	286	60	100	2 x 10 ⁸ R	Qualification per Franklin Institute Research Lab Report C-2923. Sequential Type II. Short-term capability.
PT 542	Steam Generator Circuit Flow	MI	Containment	50 ft	I	286	60	100	2 x 10 ⁸ R	Qualification per Franklin Institute Research Lab Report C-2923. Sequential Type II. Short-term capability.
PT 543	Steam Generator Circuit Flow	MI	Containment	50 ft	I	286	60	100	2 x 10 ⁸ R	Qualification per Franklin Institute Research Lab Report C-2923. Sequential Type II. Short-term capability.
PT 544	Steam Generator Circuit Flow	MI	Containment	50 ft	I	286	60	100	2 x 10 ⁸ R	Qualification per Franklin Institute Research Lab Report C-2923. Sequential Type II. Short-term capability.
PT 545	Barometric Pressure (Containment 389)	MI	Containment	48 ft	I	—	—	—	—	Transmitters not tested for Containment accident situations.

POOR ORIGIN

296

553

THIOLIAN NUCLEAR PLANT
ENVIRONMENTAL QUALIFICATION REVIEW OF CLASS II ELECTRICAL EQUIPMENT

Page 5

INSIDE CONTAINMENT

TEST ID	DESCRIPTION	SPEC. NO.	LOCATION	ELEV.	ENVIRONMENTAL SERVICE CONDITION	TEMP. (°F)	PRESSURE (PSIA)	HUMIDITY %	RADIATION	CHEMICAL	METHOD OF QUALIFICATION AND REMARKS	
											VENDOR DOCUMENTATION	POST ACCELERATOR SPRAY
LT517	Steam Generator Narrow Range Level Containment Model 384)	HI	Containment	48 ft	I	286	60	100	2×10^8 R		Same as FT512	
LT518	Steam Generator Narrow Range Level Containment Model 384)	HI	Containment	48 ft	I	286	60	100	2×10^8 R		Same as FT512	
LT519	Steam Generator Narrow Range Level Containment Model 384)	HI	Containment	48 ft	I	286	60	100	2×10^8 R		Same as FT512	
LT520	Steam Generator Narrow Range Level Containment Model 384)	HI	Containment	48 ft	I	286	60	100	2×10^8 R		Same as FT512	
LT521	Steam Generator Narrow Range Level Containment Model 384)	HI	Containment	48 ft	I	286	60	100	2×10^8 R		Same as FT512	
LT522	Steam Generator Narrow Range Level Containment Model 384)	HI	Containment	48 ft	I	286	60	100	2×10^8 R		Same as FT512	
LT523	Steam Generator Narrow Range Level Containment Model 384)	HI	Containment	48 ft	I	286	60	100	2×10^8 R		Same as FT512	
LT524	Steam Generator Narrow Range Level Containment Model 384)	HI	Containment	48 ft	I	286	60	100	2×10^8 R		Same as FT512	
LT525	Steam Generator Narrow Range Level Containment Model 384)	HI	Containment	48 ft	I	286	60	100	2×10^8 R		Same as FT512	
LT526	Steam Generator Narrow Range Level Containment Model 384)	HI	Containment	48 ft	I	286	60	100	2×10^8 R		Same as FT512	
LT527	Steam Generator Narrow Range Level Containment Model 384)	HI	Containment	48 ft	I	286	60	100	2×10^8 R		Same as FT512	
LT528	Steam Generator Narrow Range Level Containment Model 384)	HI	Containment	48 ft	I	286	60	100	2×10^8 R		Same as FT512	
LT529	Steam Generator Narrow Range Level Containment Model 384)	HI	Containment	48 ft	I	286	60	100	2×10^8 R		Same as FT512	
LT530	Steam Generator Narrow Range Level Containment Model 384)	HI	Containment	48 ft	I	286	60	100	2×10^8 R		Same as FT512	
LT531	Steam Generator Narrow Range Level Containment Model 384)	HI	Containment	48 ft	I	286	60	100	2×10^8 R		Same as FT512	
LT532	Steam Generator Narrow Range Level Containment Model 384)	HI	Containment	48 ft	I	286	60	100	2×10^8 R		Same as FT512	
LT533	Steam Generator Narrow Range Level Containment Model 384)	HI	Containment	48 ft	I	286	60	100	2×10^8 R		Same as FT512	
LT534	Steam Generator Narrow Range Level Containment Model 384)	HI	Containment	48 ft	I	286	60	100	2×10^8 R		Same as FT512	
LT535	Steam Generator Narrow Range Level Containment Model 384)	HI	Containment	48 ft	I	286	60	100	2×10^8 R		Same as FT512	
LT536	Steam Generator Narrow Range Level Containment Model 384)	HI	Containment	48 ft	I	286	60	100	2×10^8 R		Same as FT512	
LT537	Steam Generator Narrow Range Level Containment Model 384)	HI	Containment	48 ft	I	286	60	100	2×10^8 R		Same as FT512	
LT538	Steam Generator Narrow Range Level Containment Model 384)	HI	Containment	48 ft	I	286	60	100	2×10^8 R		Same as FT512	
LT539	Steam Generator Narrow Range Level Containment Model 384)	HI	Containment	48 ft	I	286	60	100	2×10^8 R		Same as FT512	
FT413	EG Flow (Ex. Boil Model E13-D1)	HI	Containment	49 ft	I	300	60	100	2×10^8 R		Qualified by Type Test in W Test Acid w/NaOH, Report WCAP-854, Sequential Type II but separate testing for LOCA and radiation. Short-term capability.	
FT414	EG Flow (Ex. Boil Model E13-D1)	HI	Containment	49 ft	I	300	60	100	2×10^8 R		Qualified by Type Test in W Test Report WCAP-854, Sequential Type II but separate testing for LOCA and radiation. Short-term capability.	

POOR ORIGINAL

533

297

THURJAN NUCLEAR PLANT
ENVIRONMENTAL QUALIFICATION REVIEW OF CLASS I¹E ELECTRICAL EQUIPMENT

Page 6

INSIDE CONTAINMENT										
LOCATION	SPEC NO.	BLDG.	ELEV.	ENVIRONMENTAL SERVICE CONDITION	TEMP. (°F)	PRESSURE (PSIA)	HUMIDITY %	RADIATION	CHEMICAL	METHOD OF QUALIFICATION AND REMARKS.
FT416	HC Flow (Eco-Tekno Model E13-DH)	H1	Containment	49 ft	I	300	60	2×10^8	1.5% boric acid w/ NaOH, pH	Qualified by Type Test in W Test Report WCAP-8541. Sequential Type II, but separate testing for LOCA and radiation.
FT417	HC Flow (Eco-Tekno Model E13-DH)	H1	Containment	49 ft	I	300	60	2×10^8	9.25-10.0	Short-term capability.
FT423	HC Flow (Eco-Tekno Model E13-DH)	H1	Containment	49 ft	I	300	60	100	2×10^8	
FT426	HC Flow (Eco-Tekno Model E13-DH)	H1	Containment	49 ft	I	300	60	100	2×10^8	
FT430	HC Flow (Eco-Tekno Model E13-DH)	H1	Containment	49 ft	I	300	60	100	2×10^8	
FT433	HC Flow (Eco-Tekno Model E13-DH)	H1	Containment	49 ft	I	300	60	100	2×10^8	
FT435	HC Flow (Eco-Tekno Model E13-DH)	H1	Containment	49 ft	I	300	60	100	2×10^8	
FT436	HC Flow (Eco-Tekno Model E13-DH)	H1	Containment	49 ft	I	300	60	100	2×10^8	
FT438	HC Flow (Eco-Tekno Model E13-DH)	H1	Containment	49 ft	I	300	60	100	2×10^8	
FT445	HC Flow (Eco-Tekno Model E13-DH)	H1	Containment	49 ft	I	300	60	100	2×10^8	
FT456	HC Flow (Eco-Tekno Model E13-DH)	H1	Containment	49 ft	I	300	60	100	2×10^8	
TE418 & 420	HC Hot/Cold Temp. (Eco-Tekno Model 17685)	H1	Containment	60 ft	I	320	90	100	2×10^8	1.14% boric acid w/ 0.17% NaOH
										Qualified by Type Test in W Test Report WCAP 9137. Sequential Type II, Long-term capability.

PROGRESSIVE

533

298

ENVIRONMENTAL QUALIFICATION REVIEW OF CLASS 1E ELECTRICAL EQUIPMENT

INSIDE CONTAINMENT

POOR ORIGINAL

TROJAN NUCLEAR PLANT
ENVIRONMENTAL QUALIFICATION REVIEW OF CLASS I IP ELECTRICAL EQUIPMENT

Page 9

INSIDE CONTAINMENT

EQUIPMENT NO.	DESCRIPTION	BPG NO.	LOCATION	ENVIRONMENTAL SERVICE CONDITION	TEMP. (°F)	PRESSURE (PSIA)	HUMIDITY %	RADIATION	CHEMICAL	METHOD OF QUALIFICATION AND REMARKS
HQ3301A	Isolation Valve Friction torque Model SHB-00)	H-134D	Containment	78°3"	I	340	60	100	2×10^8 R	Post accident NaOH solution
HQ3301B	Isolation Valve	H-134D	Containment	70°6"	I	340	60	100	2×10^8 R	Qualified by Type test in limit torque report of FRL No. F-C 3441 (Franklin Institute) and F-C3327. Reference Trojan FSAK Section 3-11, Table 3-4, Sheet 6 of 6 and Section 3-11-3-3. Sequential Type I and Synergistic Long-term capability.
HQ3301C	Isolation Valve	H-134D	Containment	78°3"	I	340	60	100	2×10^8 R	
HQ3301D	Isolation Valve	H-134D	Containment	78°3"	I	340	60	100	2×10^8 R	
HQ3301E	Isolation Valve	H-134D	Containment	69°0"	I	340	60	100	2×10^8 R	
HQ3301F	Isolation Valve	H-134D	Containment	78°3"	I	340	60	100	2×10^8 R	
HQ3301G	Isolation Valve	H-134D	Containment	70°6"	I	340	60	100	2×10^8 R	
HQ3301H	Isolation Valve	H-134D	Containment	78°3"	I	340	60	100	2×10^8 R	
HQ3301I	Isolation Valve	H-134D	Containment	69°0"	I	340	60	100	2×10^8 R	
HQ3301J	Isolation Valve	H-134D	Containment	78°3"	I	340	60	100	2×10^8 R	
HQ3301K	Isolation Valve	H-134D	Containment	70°6"	I	340	60	100	2×10^8 R	
HQ3301L	Isolation Valve	H-134D	Containment	69°0"	I	340	60	100	2×10^8 R	
HQ3301M	Isolation Valve	H-134D	Containment	78°3"	I	340	60	100	2×10^8 R	
HQ3301N	Isolation Valve	H-134D	Containment	70°6"	I	340	60	100	2×10^8 R	
HQ3301O	Isolation Valve	H-134D	Containment	69°0"	I	340	60	100	2×10^8 R	
HQ3301P	Isolation Valve	H-134D	Containment	78°3"	I	340	60	100	2×10^8 R	
HQ3301Q	Isolation Valve	H-134D	Containment	70°6"	I	340	60	100	2×10^8 R	
HQ3301R	Isolation Valve	H-134D	Containment	69°0"	I	340	60	100	2×10^8 R	

POOR ORIGINAL

5
5
5

TROJAN NUCLEAR PLANT
ENVIRONMENTAL QUALIFICATION REVIEW OF CLASS I E ELECTRICAL EQUIPMENT

POOR ORIGINAL

TEST NUMBER	DESCRIPTION NO.	SPEC NO.	LOCATION	ENVIRONMENTAL SERVICE CONDITION	TEMP. (°F)	PRESSURE (PSIA)	HUMIDITY (%)	RADIATION	CHEMICAL	METHOD OF QUALIFICATION AND REMARKS	
										INSIDE CONTAINMENT	VENDOR DOCUMENTATION
EQ1114A	Cold Isolation Valves	H-134D	Containment	78° 3"	I	340	60	100	2 x 10 ⁸ R	Post accident Radiolucent solution	Qualified by Type test in Limitorque report of FIKL No. F-C 3641 (Franklin Institute) and F-C 3327. Reference Trojan FSAR Section 3.11, Table 3.11-4, Sheet 6 of 6 and Section 3.11-3-3. Sequential Type 1 and Synergistic. Long-term capability.
EQ1114B	Cold Isolation Valves	H-134D	Containment	69° 0"	I	340	60	100	2 x 10 ⁸ R		
EQ1114C	Cold Isolation Valves	H-134D	Containment	79° 3"	I	340	60	100	2 x 10 ⁸ R		
EQ1114A	Cold Isolation Valves	H-112B	Containment	62° 11"	I	340	60	100	2 x 10 ⁸ R		
EQ1114B	Cold Isolation Valves	H-112B	Containment	62° 11"	I	340	60	100	2 x 10 ⁸ R		
EQ1114C	Cold Isolation Valves	H-112B	Containment	67° 9"	I	340	60	100	2 x 10 ⁸ R		
EQ1114D	Cold Isolation Valves	H-112B	Containment	62° 11"	I	340	60	100	2 x 10 ⁸ R		
EQ1114E	Cold Isolation Valves	H-205B	Containment	45° 6"	I	340	60	100	2 x 10 ⁸ R		
EQ1114F	Cold Isolation Valves	H-205B	Containment	62° 4"	I	340	60	100	2 x 10 ⁸ R		
EQ1114G	Cold Isolation Valves	H-205B	Containment	78° 3"	I	340	60	100	2 x 10 ⁸ R		

533

302

TROJAN NUCLEAR PLANT
ENVIRONMENTAL QUALIFICATION REVIEW OF CLASS I IP ELECTRICAL EQUIPMENT

INSIDE CONTAINMENT

ITEM IDENTIFICATION (Ref. to Spec.)	DESCRIPTION (Ref.)	B/E/C NO.	BLD/G. LOCATION	ELEV	ENVIRONMENTAL SERVICE CONDITION	VENDOR DOCUMENTATION		METHOD OF QUALIFICATION AND REMARKS
						TEMP. (°F)	PRESSURE HUMIDITY (PSIA)	
<u>INSIDE CONTAINMENT</u>								
H-10002	Containment Pressure Valve Limiting Model SHB-03)	H-209	Containment	116'5"	I	340	60	100
								2 x 10 ⁸ R
								Post accident NaOH solution
								report of FIRC No. F-C 3644 (Franklin Institute) and F-C327. Reference Trojan FSAR Section 3.11, Table 3.11-4, Sheet 6 of 6 and Section 3.11-3.
								Sequential Type 1 and Synergistic, Long-term capability.
H-10003	Containment Pressure Valve Limiting Model SHB-03)	H-209	Containment	116'5"	I	340	60	100
								2 x 10 ⁸ R
H-10004	Containment Containment Vent Containment Model SHB-00)	H-209	Containment	78'3"	I	340	60	100
								2 x 10 ⁸ R
H-10005	Containment Containment Vent Containment Model SHB-00)	H-209	Containment	78'3"	I	340	60	100
								2 x 10 ⁸ R
H-10006	Containment Containment Vent Containment Model SHB-00)	H-209	Containment	56'6"	I	340	60	100
								2 x 10 ⁸ R
H-10007	Containment Containment Vent Containment Model SHB-00)	H-209	Containment	51'8"	I	340	60	100
								2 x 10 ⁸ R
H-10008	Containment Containment Vent Containment Model SHB-00)	H-209	Containment	81'0"	I	340	60	100
								2 x 10 ⁸ R
H-10009	Containment Containment Model SHB-00)	H-209	Containment	81'0"	I	340	60	100
								2 x 10 ⁸ R
H-10010	Containment Containment Model SHB-00)	H-209	Containment	44'7"	I	340	60	100
								2 x 10 ⁸ R
H-10011	Containment Containment Model SHB-00)	H-118A	Containment	64'6"	I	340	60	100
								2 x 10 ⁸ R
H-10012	Containment Containment Model SHB-00)	H-118A	Containment	49'6"	I	340	60	100
								2 x 10 ⁸ R
								Sequential Type 1 and Synergistic, Long-term capability.

POOR ORIGINAL

533 303

TROJAN NUCLEAR PLANT
ENVIRONMENTAL QUALIFICATION REVIEW OF CLASS I E ELECTRICAL EQUIPMENT

Page 13

INSIDE CONTAINMENT

EQUIPMENT	SPEC NO.	LOCATION	ELEV.	ENVIRONMENTAL SERVICE CONDITION	TEMP. (°F)	PRESSURE (PSIA)	HUMIDITY	RADIATION	CHEMICAL	METHOD OF QUALIFICATION AND REMARKS
										INSIDE CONTAINMENT
PSD01	HIP Isolation (Limit Torque Model SMB-2)	H-IR	Containment	61'9"	I	340	60	100	2×10^8 R	Post accident NaOH solution
PSD02	HIP Isolation (Limit Torque Model SMB-2)	H-IR	Containment	61'9"	I	340	60	100	2×10^8 R	Qualified by Type test in Limitorque report of TBL No. F-C 3641 (Franklin Institute) and F-C3327. Reference Trojan PSAR Section 3.11, Table 3.11-4. Sheet 6 of 6 and Section 3.11-3-3. Sequential Type I and Synergistic long-term capability.
PSD03	HIP Isolation (Limit Torque Model SMB-4)	H-IR	Containment	52'6"	I	340	60	100	2×10^8 R	
PSD04	HIP Isolation (Limit Torque Model SMB-4)	H-IR	Containment	52'6"	I	340	60	100	2×10^8 R	
PSD05	HIP Isolation (Limit Torque Model SMB-4)	H-IR	Containment	52'6"	I	340	60	100	2×10^8 R	
PSD06	HIP Isolation (Limit Torque Model SMB-4)	H-IR	Containment	52'6"	I	340	60	100	2×10^8 R	
PSD07	HIP Isolation (Limit Torque Model SMB-4)	H-IR	Containment	52'6"	I	340	60	100	2×10^8 R	
PSD08	HIP Isolation (Limit Torque Model SMB-4)	H-IR	Containment	67'0"	I	340	60	100	2×10^8 R	
CYD01	Process System	H-IR	Containment	54'0"	I	350	60	100	1×10^6 R	Qualified by evaluation in letter (NS-CG-692) to NRC dated July 10, 1975. (These air operated valves are controlled by three way solenoids).
CYD02	PSZR System	H-IR	Containment	59'0"	I	350	60	100	1×10^6 R	Same as CYB026.
CYD03	Process System	H-IR	Containment	59'0"	I	350	60	100	1×10^6 R	Same as CYB026.
CYD04	PSZR System	H-IR	Containment	59'0"	I	350	60	100	1×10^6 R	1.2% of boric acid

533 305

TROJAN NUCLEAR PLANT
ENVIRONMENTAL QUALIFICATION REVIEW OF CLASS I IR EQUIPMENT

Page 14

INSIDE CONTAINMENT											
ITEM NUMBER (Ref.)	DESCRIPTION (Ref.)	LOCATION NO.	BLDG.	ENVIRONMENTAL FLY,	ENVIRONMENTAL SERVICE CONDITION	TEMP. (°F)	PRESSURE (PSIA)	HUMIDITY I	RADIATION	CHIMICAL	METHOD OF QUALIFICATION AND REFERENCES
CV8141A	HCP Seal	H-1R	Containment	70°	I	350	60	100	1 x 10 ⁶ R	1.2% of boric acid	Qualified by ev. station in W letter (NS-CF-694; so boric acid July 10, 1975. (These air operated valves are controlled by three way solenoids).
CV8141B	HCP Seal	H-1R	Containment	70°	I	350	60	100	1 x 10 ⁶ R	1.2% of boric acid	Same as above.
CV8141C	HCP Seal	H-1R	Containment	70°	I	350	60	100	1 x 10 ⁶ R	1.2% of boric acid	Same as above.
CV8141D	HCP Seal	H-1R	Containment	70°	I	350	60	100	1 x 10 ⁶ R	1.2% of boric acid	Same as above.
CV8141E	HCP Seal	H-1R	Containment	79°	I	350	60	100	1 x 10 ⁶ R	1.2% of boric acid	Same as above.
CV8141J	Yacht Letdown	H-1R	Containment	68°	I	350	60	100	1 x 10 ⁶ R	1.2% of boric acid	Same as above.
CV8141S	PSZ System	H-1R	Containment	65°7"	I	350	60	100	1 x 10 ⁶ R	1.2% of boric acid	Same as above.
CV8141U	PSZ System	H-1R	Containment	65°7"	I	350	60	100	1 x 10 ⁶ R	1.2% of boric acid	Same as above.
CV8141P	Charging Line Isolation	H-1R	Containment	65°7"	I	350	60	100	1 x 10 ⁶ R	1.2% of boric acid	Same as above.
CV8149A	Letdown Isolation Line	H-1R	Containment	63°	I	350	60	100	1 x 10 ⁶ R	1.2% of boric acid	Same as above.

POOR ORIGINAL

553 306

INSIDE CONTAINMENT

EQUIPMENT NO.	DESCRIPTION	SPEC NO.	LOCATION BLDG.	ELEV	ENVIRONMENTAL SERVICE CONDITION	TEMP. (°F)	PRESSURE (PSIA)	HUMIDITY	RADIATION	CHEMICAL	METHOD OF QUALIFICATION AND REMARKS	
											VENDOR DOCUMENTATION	
CYB117B	Containment Isolation H-LR	Containment	63'	I	350	60	100	1×10^6 R	1.2% of boric acid	1.2% of boric acid	Qualified by evaluation in W letter (HS-CR-692) to NRC dated July 10, 1975. (These air operated valves are controlled by three way solenoids).	
CYB119C	Containment Isolation H-LR	Containment	63'	I	350	60	100	1×10^6 R	1.2% of boric acid	Same as above.		
CYB115Y	Containment Isolation H-LR	Containment	48.5"	I	350	60	100	1×10^6 R	1.2% of boric acid	Same as above.		
CYB115Z	Containment Isolation H-LR	Containment	47.6"	I	350	60	100	1×10^6 R	1.2% of boric acid	Same as above.		
CYB116SA	Pri Hk-Up to RCP	H-LR	Containment	68"	I	350	60	100	1×10^6 R	1.2% of boric acid	Same as above.	
CYB116SB	Pri Hk-Up to RCP	H-LR	Containment	68"	I	350	60	100	1×10^6 R	1.2% of boric acid	Same as above.	
CYB116SC	Pri Hk-Up to RCP	H-LR	Containment	68"	I	350	60	100	1×10^6 R	1.2% of boric acid	Same as above.	
CYB116SD	Pri Hk-Up to SCP	H-LR	Containment	68"	I	350	60	100	1×10^6 R	1.2% of boric acid	Same as above.	
CYB117J	SIS Test	H-LR	Containment	59"	I	350	60	100	1×10^6 R	1.2% of boric acid	Same as above.	
CYB117Y	SIS Test	H-LR	Containment	56"	I	350	60	100	1×10^6 R	1.2% of boric acid	Same as above.	
CYB117S	H-LR Isolation	H-LR	Containment	56"	I	350	60	100	1×10^6 R	1.2% of boric acid	Same as above.	

TWINING WOOD

53
307

TROJAN NUCLEAR PLANT
ENVIRONMENTAL QUALIFICATION REVIEW OF CLASS I E ELECTRICAL EQUIPMENT

INSIDE CONTAINMENT

ITEM NUMBER	DESCRIPTION	SPEC NO.	LOCATION	ELEV.	ENVIRONMENTAL SERVICE CONDITION	TEMP. (°F)	PRESSURE (PSIA)	HUMIDITY %	RADIATION	CHEMICAL	METHOD OF QUALIFICATION AND REMARKS
											INSIDE CONTAINMENT
1-000000	SIS Test	H-1R	Containment	58°	I	350	60	100	1×10^6 R	1.2% of Boric Acid	Qualified by evaluation in letter NS-CR-692 to NRC dated July 10, 1975. (These air operated valves are controlled by three way solenoids).
1-000001	Accumulator Sys	H-1R	Containment	58°	I	350	60	100	1×10^6 R	1.2% of Boric Acid	Same as above.
1-000002	Accumulator Sys	H-1R	Containment	69°	I	350	60	100	1×10^6 R	1.2% of Boric Acid	Same as above.
1-000003	Accumulator Sys	H-1R	Containment	69°	I	350	60	100	1×10^6 R	1.2% of Boric Acid	Same as above.
1-000004	Accumulator Sys	H-1R	Containment	69°	I	350	60	100	1×10^6 R	1.2% of Boric Acid	Same as above.
1-000005	Accumulator Sys	H-1R	Containment	69°	I	350	60	100	1×10^6 R	1.2% of Boric Acid	Same as above.
1-000006	Accumulator Sys	H-1R	Containment	69°	I	350	60	100	1×10^6 R	1.2% of Boric Acid	Same as above.
1-000007	Accumulator Sys	H-1R	Containment	47°	I	350	60	100	1×10^6 R	1.2% of Boric Acid	Same as above.
1-000008	Accumulator Sys	H-1R	Containment	47°	I	350	60	100	1×10^6 R	1.2% of Boric Acid	Same as above.
1-000009	Accumulator Sys	H-1R	Containment	47°	I	350	60	100	1×10^6 R	1.2% of Boric Acid	Same as above.
1-000010	Accumulator Sys	H-1R	Containment	47°	I	350	60	100	1×10^6 R	1.2% of Boric Acid	Same as above.
1-000011	Hi Test Line	H-1R	Containment	49°	I	350	60	100	1×10^6 R	1.2% of Boric Acid	Same as above.

POOR ORIGINAL

533 303

TROJAN NUCLEAR PLANT
ENVIRONMENTAL QUALIFICATION REVIEW OF CLASS 1E ELECTRICAL EQUIPMENT

INSIDE CONTAINMENT

ITEM NO.	DESCRIPTION	SPEC NO.	LOCATION	ENVIRONMENTAL SERVICE CONDITION	TEMP. (°F)	PRESSURE (PSIA)	HUMIDITY	RADIATION	CHEMICAL	STATE OF QUALIFICATION AND REMARKS	
C-1001	Si Test Line	H-1R	Containment	50°	I	350	60	100	1 x 10 ⁶ R	1.2% of Boric Acid	Qualified by evaluation in letter (NSCE-692) to HNC dated July 10, 1975. (These air operated valves are controlled by three way solenoid).
C-10017C	Si Test Line	H-1R	Containment	50°	I	350	60	100	1 x 10 ⁶ R	1.2% of Boric Acid	Same as above.
C-10018	Si Test Line	H-1P	Containment	50°	I	350	60	100	1 x 10 ⁶ R	1.2% of Boric Acid	Same as above.
C-10018A	Accumulator Sys	H-1R	Containment	49°	I	350	60	100	1 x 10 ⁶ R	1.2% of Boric Acid	Same as above.
C-10018B	Accumulator Sys	H-1R	Containment	49°	I	350	60	100	1 x 10 ⁶ R	1.2% of Boric Acid	Same as above.
C-10018C	Accumulator Sys	H-1R	Containment	49°	I	350	60	100	1 x 10 ⁶ R	1.2% of Boric Acid	Same as above.
C-10019	SIS System	H-1R	Containment	49°	I	350	60	100	1 x 10 ⁶ R	1.2% of Boric Acid	Same as above.
C-10021	SIS System	H-1R	Containment	63°	I	350	60	100	1 x 10 ⁶ R	1.2% of Boric Acid	Same as above.
C-10022	SIS System	H-1R	Containment	58°	I	350	60	100	1 x 10 ⁶ R	1.2% of Boric Acid	Same as above.
C-10023	SIS System	H-1R	Containment	56°	I	350	60	100	1 x 10 ⁶ R	1.2% of Boric Acid	Same as above.
C-10028	SIS System	H-1R	Containment	56°	I	350	60	100	1 x 10 ⁶ R	1.2% of Boric Acid	Same as above.

POOR ORIGINAL

533
309

TROJAN NUCLEAR PLANT
ENVIRONMENTAL QUALIFICATION REVIEW FOR CLASS I P. ELECTRICAL EQUIPMENT

Page 18

INSIDE CONTAINMENT		VENDOR DOCUMENTATION		ENVIRONMENTAL TESTS		SERVICE CONDITION		TEMP. (°F)		PRESSURE (PSIA)		HUMIDITY		RADIATION		CHEMICAL		METHOD OF QUALIFICATION AND REMARKS	
Ex. 1-1-1-1-1-1	Containment	Bldg.	No.	LOCATION	LEVEL	ENVIRONMENTAL METAL	TEST	TEMP. (°F)	TEST	PRESSURE (PSIA)	TEST	HUMIDITY	TEST	RADIATION	TEST	CHEMICAL	TEST	METHOD OF QUALIFICATION AND REMARKS	
Lvds/94C	LIS System	H-18	Containment	56°	-	I	-	350	60	100	1 x 10 ⁶ R	-	1.2% of Boric Acid	Qualification by evaluation in Boiler Water test (BS-E-692) to NHC dated July 10, 1975. (These air operated valves are controlled by three way solenoids).	-	-	-		
Lvds/94D	LIS System	H-18	Containment	56°	-	I	-	350	60	100	1 x 10 ⁶ R	-	1.2% of Boric Acid	Same as above.	-	-	-	-	
Lvds/94E	LIS System	H-18	Containment	56°	-	I	-	350	60	100	1 x 10 ⁶ R	-	1.2% of Boric Acid	Same as above.	-	-	-	-	
Lvds/94F	LIS System	H-18	Containment	56°	-	I	-	350	60	100	1 x 10 ⁶ R	-	1.2% of Boric Acid	Same as above.	-	-	-	-	
2-9-1	Even Mounted Limit Switches	HIR(2)	Containment	61°9"	-	I	-	340	70	100	2 x 10 ⁶ R	w/ NaOH, pH 10-11	Boric Acid	Qualified by Type test in AGOE-Cleveland Development Co./Hamco Test report, March 2, 1975. (These are Hamco Model EA-180) Sequential Type I. Long-term capability.	-	-	-	-	
2-9-2	Even Mounted Limit Switches	HIR(2)	Containment	61°9"	-	I	-	340	70	100	2 x 10 ⁶ R	-	Boric Acid	Qualified by Type test in AGOE-Cleveland Development Co./Hamco Test report, March 2, 1975. (These are Hamco Model EA-180) Sequential Type I. Long-term capability.	-	-	-	-	
2-8-1-6	Even Mounted Limit Switches	HIR(2)	Containment	54°0"	-	I	-	340	70	100	2 x 10 ⁶ R	-	-	Not environmentally qualified for post accident conditions, but are not required for any accident and only used for valve position indication. (These limit switches are Hamco Model D2400).	-	-	-	-	
2-8-8-6A	Even Mounted Limit Switches	HIR(2)	Containment	52°6"	-	I	-	200	-	100	1 x 10 ⁴ R	-	-	Not environmentally qualified for post accident conditions, but are not required for any accident and only used for valve position indication. (These limit switches are Hamco Model D2400).	-	-	-	-	
2-8-8-6B	Even Mounted Limit Switches	HIR(2)	Containment	52°6"	-	I	-	200	-	100	1 x 10 ⁴ R	-	-	Not environmentally qualified for post accident conditions, but are not required for any accident and only used for valve position indication. (These limit switches are Hamco Model D2400).	-	-	-	-	

53

INSIDE CONTAINMENT

ITEM NUMBER	DESCRIPTION	SPEC NO.	LOCATION	ENVIRONMENTAL SERVICE CONDITION	TEMP. (OF)	PRESSURE (PSIA)	HUMIDITY %	RADIATION	CHEMICAL	METHOD OF QUALIFICATION AND REFRIGERANT
INSIDE CONTAINMENT										
25545-12	Door Mounted Limit Switches	MIR(2)	Containment	52' 6"	I	200	-	100	1×10^6 R	-
25545-13	Door Mounted Limit Switches	MIR(2)	Containment	52' 6"	I	200	-	100	1×10^6 R	-
25545-14	Door Mounted Limit Switches	MIR(2)	Containment	59°	I	200	-	100	1×10^6 R	Same as above.
25545-15	Door Mounted Limit Switches	MIR(2)	Containment	59°	I	200	-	100	1×10^6 R	Same as above.
25545-16	Door Mounted Limit Switches	MIR(2)	Containment	70°	I	200	-	100	1×10^6 R	Same as above.
25545-17	Door Mounted Limit Switches	MIR(2)	Containment	70°	I	200	-	100	1×10^6 R	Same as above.
25545-18	Door Mounted Limit Switches	MIR(2)	Containment	70°	I	200	-	100	1×10^6 R	Same as above.
25545-19	Door Mounted Limit Switches	MIR(2)	Containment	70°	I	200	-	100	1×10^6 R	Same as above.
25545-20	Door Mounted Limit Switches	MIR(2)	Containment	79°	I	200	-	100	1×10^6 R	Same as above.
25545-21	Door Mounted Limit Switches	MIR(2)	Containment	68°	I	200	-	100	1×10^6 R	Same as above.
25545-22	Door Mounted Limit Switches	MIR(2)	Containment	65° 7"	I	200	-	100	1×10^6 R	Same as above.
25545-23	Door Mounted Limit Switches	MIR(2)	Containment	65° 7"	I	200	-	100	1×10^6 R	Same as above.
25545-24	Door Mounted Limit Switches	MIR(2)	Containment	65° 7"	I	200	-	100	1×10^6 R	Same as above.
25545-25	Door Mounted Limit Switches	MIR(2)	Containment	63°	I	340	70	100	2×10^8 R	Boric acid w/ NaOH pH 10-11
										Qualified by Type test AGC-Cleveland Development Co./Naoco test report, March 3, 1976. (These are Naoco Model EA-180). Sequential Type I. Long-term capability.

TRANSMISSION
ORIGINAL
533

311

TWO-JAN NUCLEAR PLANT
ENVIRONMENTAL QUALIFICATION REVIEW OF CLASS I^E ELECTRICAL EQUIPMENT

Page 20

ITEM NO.	DESCRIPTION	SPEC NO.	LOCATION	ELEV	ENVIRONMENTAL SERVICE CONDITION	TEMP. (°F)	PRESSURE HUMIDITY (PSIA)	IRRADIATION	CHEMICAL	METHOD OF QUALIFICATION AND REASNS	
										VENDOR DOCUMENTATION	
Z581548	Stem Mounted Limit Switches	MIR(?)	Containment	63°	I	340	70	100	2 x 10 ⁸ R	Boric acid w/ NaOH, pH 10-11	Qualified by Type test in AOE-Cleveland Development Co./Nanco test report, March 3, 1978. (These are Nanco Model EA-180.) Sequential Type I. Long-term capability.
Z581549C	Stem Mounted Limit Switches	MIR(2)	Containment	63°	I	340	70	100	2 x 10 ⁸ R		
Z581551	Stem Mounted Limit Switches	MIR(2)	Containment	48°5"	I	200	-	100	1 x 10 ⁴ R		
Z581552	Stem Mounted Limit Switches	MIR(2)	Containment	47°6"	I	200	-	100	1 x 10 ⁴ R		
Z581558	Stem Mounted Limit Switches	MIR(2)	Containment	68°	I	200	-	100	1 x 10 ⁴ R		
Z581559B	Stem Mounted Limit Switches	MIR(2)	Containment	68°	I	200	-	100	1 x 10 ⁴ R		
Z581560C	Stem Mounted Limit Switches	MIR(2)	Containment	68°	I	200	-	100	1 x 10 ⁴ R		
Z581560D	Stem Mounted Limit Switches	MIR(2)	Containment	68°	I	200	-	100	1 x 10 ⁴ R		
Z581563	Stem Mounted Limit Switches	MIR(2)	Containment	59°	I	340	70	100	2 x 10 ⁸ R	Boric acid w/ NaOH, pH 10-11	Qualified by Type test in AOE-Cleveland Development Co./Nanco test report, March 3, 1978. (These are Nanco Model EA-180.) Sequential Type I. Long-term capability.
Z581564	Stem Mounted Limit Switches	MIR(2)	Containment	56°	I	340	70	100	2 x 10 ⁸ R		
Z581575	Stem Mounted Limit Switches	MIR(2)	Containment	56°	I	200	-	100	1 x 10 ⁴ R		
Z581578	Stem Mounted Limit Switches	MIR(2)	Containment	56°	I	200	-	100	1 x 10 ⁴ R		
Z581581	Stem Mounted Limit Switches	MIR(2)	Containment	69°	I	340	100	100	2 x 10 ⁸ R		
Z581588	Stem Mounted Limit Switches	MIR(2)	Containment	69°	I	340	100	100	2 x 10 ⁸ R		

POOR ENGINEERING

553 312

INDIAN NUCLEAR PLANT
ENVIRONMENTAL QUALIFICATION REVIEW OF CLASS I ELEC TRICAL EQUIPMENT

Page 21

EQUIPMENT NO.	DESCRIPTION	SPEC NO.	TESTING	BLDG.	LOCATION	ENVIRONMENTAL	SERVICE CONDITION	TEMP. (°F)	PRESSURE (PSIA)	HUMIDITY	RADIATION	CHEMICAL	METHOD OF QUALIFICATION AND REMARKS		
255875A	Stem Mounted Limit Switches	MIR(2)	Containment	69°	I	200	-	100	1 x 10 ⁶ R	-	Not environmentally qualified for post accident conditions, but are not required for any accident situation and only used for valve indication. {These are Nance Model D400X.}				
255875C	Stem Mounted Limit Switches	MIR(2)	Containment	69°	I	200	-	100	1 x 10 ⁶ R	-	Same as above.				
255875D	Stem Mounted Limit Switches	MIR(2)	Containment	69°	I	200	-	100	1 x 10 ⁶ R	-	Same as above.				
255876A	Stem Mounted Limit Switches	MIR(2)	Containment	47°	I	200	-	100	1 x 10 ⁶ R	-	Same as above.				
255876B	Stem Mounted Limit Switches	MIR(2)	Containment	47°	I	200	-	100	1 x 10 ⁶ R	-	Same as above.				
255876C	Stem Mounted Limit Switches	MIR(2)	Containment	47°	I	200	-	100	1 x 10 ⁶ R	-	Same as above.				
255876D	Stem Mounted Limit Switches	MIR(2)	Containment	47°	I	200	-	100	1 x 10 ⁶ R	-	Same as above.				
255877A	Stem Mounted Limit Switches	MIR(2)	Containment	49°	I	200	-	100	1 x 10 ⁶ R	-	Same as above.				
255877B	Stem Mounted Limit Switches	MIR(2)	Containment	50°	I	200	-	100	1 x 10 ⁶ R	-	Same as above.				
255877C	Stem Mounted Limit Switches	MIR(2)	Containment	50°	I	200	-	100	1 x 10 ⁶ R	-	Same as above.				
255877D	Stem Mounted Limit Switches	MIR(2)	Containment	50°	I	200	-	100	1 x 10 ⁶ R	-	Same as above.				
255879A	Stem Mounted Limit Switches	MIR(2)	Containment	49°	I	200	-	100	1 x 10 ⁶ R	-	Same as above.				
255879B	Stem Mounted Limit Switches	MIR(2)	Containment	49°	I	200	-	100	1 x 10 ⁶ R	-	Same as above.				

POOR ORGANIZATION

1533

TROJAN NUCLEAR PLANT
ENVIRONMENTAL QUALIFICATION REVIEW OF CLASS 1E ELECTRICAL EQUIPMENT

TEST ITEM No.	LOCATION SPEC NO.	SPEC NO.	LOCATION BLDG.	LOCATION ELEV	ENVIRONMENTAL SERVICE CONDITION	VENDOR DOCUMENTATION			METHOD OF QUALIFICATION AND REMARKS
						TEMP. (°F)	PRESSURE HUMIDITY (PSIA)	RADIATION I	
INSIDE CONTAINMENT									
Z-58790	Stem Mounted Limit Switches	HIR(2)	Containment	49°	I	200	-	1 x 10 ⁶ R	-
Z-58791	Stem Mounted Limit Switches	HIR(2)	Containment	49°	I	200	-	1 x 10 ⁶ R	Not environmentally qualified for post accident conditions, but are not required for any accident situation and only used for valve indication. (These are Wanco Model D2400.)
Z-58792	Stem Mounted Limit Switches	HIR(2)	Containment	58°	I	200	-	1 x 10 ⁶ R	Same as above.
Z-58793A	Stem Mounted Limit Switches	HIR(2)	Containment	56°	I	200	-	1 x 10 ⁶ R	Same as above.
Z-58794B	Stem Mounted Limit Switches	HIR(2)	Containment	56°	I	200	-	1 x 10 ⁶ R	Same as above.
Z-58795C	Stem Mounted Limit Switches	HIR(2)	Containment	56°	I	200	-	1 x 10 ⁶ R	Same as above.
Z-58796D	Stem Mounted Limit Switches	HIR(2)	Containment	56°	I	200	-	1 x 10 ⁶ R	Same as above.
Z-58797E	Stem Mounted Limit Switches	HIR(2)	Containment	56°	I	200	-	1 x 10 ⁶ R	Same as above.
Z-58798F	Stem Mounted Limit Switches	HIR(2)	Containment	56°	I	200	-	1 x 10 ⁶ R	Same as above.
Z-58799G	Stem Mounted Limit Switches	HIR(2)	Containment	56°	I	200	-	1 x 10 ⁶ R	Same as above.
Z-58800H	Stem Mounted Limit Switches	HIR(2)	Containment	56°	I	200	-	1 x 10 ⁶ R	Same as above.
Z-58801I	Stem Mounted Limit Switches	HIR(2)	Containment	56°	I	200	-	1 x 10 ⁶ R	Same as above.
Z-58802J	Stem Mounted Limit Switches	HIR(2)	Containment	56°	I	200	-	1 x 10 ⁶ R	Same as above.
Z-58803K	Stem Mounted Limit Switches	HIR(2)	Containment	56°	I	200	-	1 x 10 ⁶ R	Same as above.
Z-58804L	Stem Mounted Limit Switches	HIR(2)	Containment	56°	I	200	-	1 x 10 ⁶ R	Same as above.
Z-58805M	Stem Mounted Limit Switches	HIR(2)	Containment	56°	I	200	-	1 x 10 ⁶ R	Same as above.
Z-58806N	Stem Mounted Limit Switches	HIR(2)	Containment	56°	I	200	-	1 x 10 ⁶ R	Same as above.
Z-58807O	Stem Mounted Limit Switches	HIR(2)	Containment	56°	I	200	-	1 x 10 ⁶ R	Same as Z58701.
Z-58808P	Stem Mounted Limit Switches	HIR(2)	Containment	129°	I	200	-	1 x 10 ⁶ R	Same as Z5879C.
Z-58809Q	Stem Mounted Limit Switches	HIR(2)	Containment	129°	I	200	-	1 x 10 ⁶ R	Same as Z58879C.
Z-58810R	Stem Mounted Limit Switches	HIR(2)	Containment	129°	I	200	-	1 x 10 ⁶ R	Same as Z58879C.

533

POOR ORIGINAL

TWO-JAN NUCLEAR PLANT
ENVIRONMENTAL QUALIFICATION REVIEW OF CLASS IIE ELECTRICAL EQUIPMENT

Page 23

INSIDE CONTAINMENT

ITEM NO.	DESCRIPTION	SPEC NO.	LOC.	ELEV.	ENVIRONMENTAL SERVICE CONDITION	TEMP. (°F)	PRESSURE (PSIA)	HUMIDITY %	RADIATION	CHEMICAL	METHOD OF QUALIFICATION AND REMARKS	
											TEST	TEST
A1B701	Terminal Box	F12	Containment	60°	I	286	40	100	5×10^6	See Note 1	This terminal box is a steel enclosure that is fully gasketed and has General Electric terminal blocks. (Reference Conn. Yankee Atomic Co. test report, March 16, 1978.) Sequential Type I. Long-term capability.	
A1B704	Terminal Box	F12	Containment	60°	I	286	40	100	5×10^6	See Note 1	Same as above.	
A1B705	Terminal Box	F12	Containment	60°	I	286	40	100	5×10^6	See Note 1	Same as above.	
A1B706	Terminal Box	F12	Containment	60°	I	286	40	100	5×10^6	See Note 1	Same as above.	
A1B707	Terminal Box	F12	Containment	60°	I	286	40	100	5×10^6	See Note 1	Same as above.	
A1B708	Terminal Box	F12	Containment	60°	I	286	40	100	5×10^6	See Note 1	Same as above.	
A1B709	Terminal Box	F12	Containment	60°	I	286	40	100	5×10^6	See Note 1	Same as above.	
A1B710	Terminal Box	F12	Containment	60°	I	286	40	100	5×10^6	See Note 1	Same as above.	
A1B711	Terminal Box	F12	Containment	60°	I	286	40	100	5×10^6	See Note 1	Same as above.	
B1B703	Terminal Box	F12	Containment	60°	I	286	40	100	5×10^6	See Note 1	Same as above.	
B1B704	Terminal Box	F12	Containment	60°	I	286	40	100	5×10^6	See Note 1	Same as above.	
B1B705	Terminal Box	F12	Containment	60°	I	286	40	100	5×10^6	See Note 1	Same as above.	
B1B706	Terminal Box	F12	Containment	60°	I	286	40	100	5×10^6	See Note 1	Same as above.	
B1B707	Terminal Box	F12	Containment	60°	I	286	40	100	5×10^6	See Note 1	Same as above.	
B1B708	Terminal Box	F12	Containment	60°	I	286	40	100	5×10^6	See Note 1	Same as above.	
B1B709	Terminal Box	F12	Containment	60°	I	286	40	100	5×10^6	See Note 1	Same as above.	
B1B710	Terminal Box	F12	Containment	60°	I	286	40	100	5×10^6	See Note 1	Same as above.	

Note 1. Chemical spray consisted of 2640 ppm solution of boric acid.

POOR ORIGINAL

TROJAN NUCLEAR PLANT
ENVIRONMENTAL QUALIFICATION REVIEW OF CLASS IE ELECTRICAL EQUIPMENT

EQ/TYPE	DESCRIPTION NO.	SPEC NO.	OUTSIDE CONTAINMENT								METHOD OF QUALIFICATION AND REMARKS
			LOCATION	ELEV.	ENVIRONMENTAL SERVICE CONDITION	TEMP. (°F)	PRESSURE (PSIA)	HUMIDITY %	RADIATION	CHEMICAL	
A200 1100 A210	5 kV Metal Clad Switchgear and Circuit Breakers	E-8	Control	61 ft	III	104	Normal (See Note 2)	-	Normal	NA	Qualified by operating experience based on industry type tests. This equipment meets the requirements of IEEE Std 27-191 (ANSI C37-20). Reference ITE Test Reports.
A211 1101 A212	5 kV Metal Clad Switchgear and Circuit Breakers	E-8	Turbine	69 ft	III	104	Normal	-	Normal	NA	Same as A100.
B213/B203 B214/B204	480 V Load Centers and Circuit Breakers	E-9	Control Turbine	63 ft 69 ft	III IV	104	Normal	-	Normal	NA	Qualified by operating experience based on industry type tests. This equipment was tested per the requirements of ANSI C37-20 (1969) and NEMA Std SG5-1971. Reference ITE Test Reports.
Q108C	4 kV Transfer Switches & Switchboard	E-6	Aux	45 ft	II	104	Normal	-	Normal	NA	Qualified by operating experience based on industry type tests. This equipment was tested per the requirements of ANSI C37-20 (1969), NEMA Std SG5-1971 and IEEE326-1971. Reference ITE Test Reports.
Q210C	4 kV Transfer Switch & Switchboard	E-6	Intake Structure	45 ft	III	104	Normal	-	Normal	NA	Same as Q108C.
B211 B213 B215	480 V Motor Control Centers	E-11	Control	61 ft	III	104	Normal	-	Normal	NA	Qualified by operating experience based on industry type tests. This equipment was tested per the requirements of NEMA Std. ICI-1-1970, NEMA Std ABL-1970. Reference ITE Test Reports.
B212 B214 B216	480 V Motor Control Centers	E-11	Turbine	69 ft	VI	104	Normal	-	Normal	NA	Same as B211.

Note 2: This normal pressure is referring to atmospheric pressure.

T1001591-014

POOR ORIGINAL

533 316

OUTSIDE CONTAINMENT

DESCRIPTION	SPEC NO.	LOCATION ELEV.	ENVIRONMENTAL SERVING CONDITION	VENDOR DOCUMENTATION			METHOD OF QUALIFICATION AND REMARKS
				TEMP. (°F)	PRESSURE (PSIA)	HUMIDITY %	
125V DC Distribution Centers	E-15	Control 63 ft	III	104	Normal	-	Normal N/A Qualified by operating experience based on industry type tests. This equipment was tested per the requirement of IPCEA Std ICS-1-1970.
125V DC batteries	E-16	Control 63 ft	III	104	Normal	-	Normal N/A Qualified by operating experience based on industry type tests. This equipment was tested per the requirement of NEMA Std R12-1971.
125V DC battery chargers	E-17	Control 63 ft	III	104	Normal	-	Normal N/A Qualified by operating experience based on industry type tests. This equipment was tested per the requirement of NEMA Std R12-1971.
Power Cab Power Cable	E-21	Fuel/Aux All	II	350	Normal	100	SaiLo® N/A Okonite Wire and Cable: Laboratory Institute Research Lab. Test Report, FC-3463, August 1972. Refer to Note 3.
Power Cab Power Cable	E-21	Fuel/Aux All	II	350	Normal	100	SaiLo® N/A Okonite Wire and Cable: Laboratory Institute Research Lab. Test Report, FC-3463, August 1972. Refer to Note 3.
Instrument Cable	E-23A	All	II, III, IV, V, VI	340	60	100	Ialox® N/A Qualified by Type Test in Franklin Institute Research Lab. Test Report, FC-3463, August 1972. Refer to Note 2.
CL-2 Relays	E-23B	Control All	IV & III	340	60	100	SaiLo® N/A Qualified by operating experience based on industry type tests. All of CL-2 relays were tested per requirements of ANSI-C37.90 (IEC-311). Reference to generic report by GE of May 20, 1977 in CL2-6678.
CL-2 Relays	E-51	Control All Turbine 63 ft	IV & III	90	Normal	-	SaiLo® N/A Qualified by operating experience based on industry type tests. All of CL-2 relays were tested per requirements of IPCEA Q-79-81.
Cab Switchboard	E-23A	Control All	III	194	Normal	100%	SaiLo® N/A Qualified by type test based on W MAP 2710L test report. This equipment was qualified for LCA environment, but is located outside containment.
Quality/R Procurement Power Supply	H-87	Cable Penetration Area	IV	300	60	100%	N/A

NOTE 3: These cables were qualified for LCA environment even though they are not utilized in Containment.

T1001594-018

POOR ORIGINAL

ECC

TROJAN NUCLEAR PLANT
ENVIRONMENTAL QUALIFICATION REVIEW OF CLASS II ELECTRICAL EQUIPMENT

Page 26

DESCRIPTION ITEM NO.		SPEC NO.	LOCATION BLDG. ELEV.	ENVIRONMENTAL SERVICE CONDITIONS	VENDOR DOCUMENTATION TEMP. (°F) PRESSURE (PSIA)	RADIATION E	CHEMICAL E	METHOD OF QUALIFICATION AND REMARKS
OUTSIDE CONTAINMENT								
P-10A.3	Cool Pump*	H-18	Pool/Aux	45 ft	II	> 104	Normal	Quantified by operating experience based on industrial type tests. These equipment were tested per the requirements of NEBS Std HN-1, USAS G-50.2, and IEEE Pub. #112A.
P-110C	Cool Pump*	H-18	Aux	45 ft	II	32-104	Normal	$\times 10^6 R$
P-10A.3	Service Water Pump	H-32	Intake Structure	45 ft	IV	32-104	Normal	Normal
P-10A.3	Containment Spray Pump	H-22	Aux	5 ft	II	32-104	Normal	$\times 10^6 R$
P-10A.3	SG Emitter Pump	H-32	Aux	45 ft	II	32-104	Normal	$\times 10^6 R$
P-10A.3	Containment Cooling Water Supply Pump*	H-32	Aux	45 ft	II	32-104	Normal	$\times 10^6 R$
P-10A.3	Containment Fugue Chaking Pump*	H-1	Aux	25 ft	II	32-104	Normal	$\times 10^6 R$
P-111	Positive Displacement Chaking Pump	H-1	Aux	25 ft	II	32-104	Normal	$\times 10^6 R$
P-111	Aux Transfer Pump*	H-1	Fuel	66 ft	II	32-104	Normal	$\times 10^6 R$
P-10A.3	R/R Pump*	H-1	Aux	5 ft	II	32-104	Normal	$\times 10^6 R$
P-10A.3	Safety Injection Pump*	H-1	Aux	5 ft	II	32-104	Normal	$\times 10^6 R$
P-10A.3	Containment Recycle Pump*	H-1	Aux	25 ft	II	32-104	Normal	$\times 10^6 R$
P-10A.3	Aux. FW Turbine Driven Pump	H-12	Turbine	45 ft	VI	50-120	Normal	Normal
P-10A.3	Aux. FW Diesel Driven Pump	H-12	Turbine	45 ft	VI	50-120	Normal	Normal

TICKET NUMBER:
100151012

POOR ORIGINAL

C/S

ECS

TIAO JIAN NUCLEAR PLANT
ENVIRONMENTAL QUALIFICATION REVIEW OF CLASS II ELECTRICAL EQUIPMENT

Page 27

<u>OUTSIDE CONTAINMENT</u>									
ITEM NUMBER	DESCRIPTION	SPEC NO.	LOCATION	ENVIRONMENTAL SERVICE CONDITION	VENDOR DOCUMENTATION		RADIATION	CHEMICAL	METHOD OF QUALIFICATION AND REMARKS
					BLDG.	ELEV.			
VC 101.1.5	Battery Room Exhaust Fans	F09	Control	65 ft	III	104	Normal	-	Qualified by operating experience Based on industry type test. These equipment were tested per the requirements of NEA Std. NG-1.
VC 101.2.3	Containment Spray Pump Coolers	F09	Aux	5 ft	II	104	Normal	-	Normal
VC 101.3.6	RGE Pump Fan	F09	Aux	5 ft	II	104	Normal	-	Normal
VC 101.4.6	Safety Injection Pump Unit Coolers	F09	Aux	5 ft	II	104	Normal	-	Normal
VC 101.5.6	'3' SWR Room Heat Coolers	F09	Control	65 ft	III	104	Normal	-	Normal
VC 101.6.6	Cable Spreading Boxes Coolers	F09	Control	77 ft	III	104	Normal	-	Normal
VC 101.7.6	Control Room Emergency Fan	F09	Control	105 ft	V	104	Normal	-	Normal
VC 101.8.6	Control Room Emergency Re-Hexater Coil	F09	Control	105 ft	V	104	Normal	-	Normal
VC 101.9.6	Control Room Emergency Heater	F09	Control	105 ft	V	104	Normal	-	Normal
VC 101.10.6	Battery Re Unit Heaters	F09	Control	65 ft	III	120	Normal	-	Normal
VC 101.11.6.2	IG Supply Fans	F09	Turbine	55 ft	VI	120	Normal	-	Normal
VC 101.12.6.9	IG Exhaust Fans	F09	Turbine	55 ft	VI	120	Normal	-	Normal
VC 101.13.6.9	IG Exhaust Fans	F09	Turbine	55 ft	VI	120	Normal	-	Normal
VC 101.14.6.9	'6' SWR Room Coolers	F09	Turbine	55 ft	VI	120	Normal	-	Normal

TIAO JIAN 014

POOR ORIGINAL

TROJAN NUCLEAR PLANT
ENVIRONMENTAL QUALIFICATION OF CLASS IIE ELECTRICAL EQUIPMENT

OUTSIDE CONTAINMENT

ITEM NUMBER	DESCRIPTION	SPEC NO.	LOCATION	BLDG. ELEV.	ENVIRONMENTAL SERVICE CONDITION		VENDOR DOCUMENTATION	TEMP. (°F)	PRESSURE (PSIA)	HUMIDITY %	RADIATION $\times 10^6$ R	CHEMICAL	METHOD OF QUALIFICATION AND REASONS
					TEMP. (°F)	HUMIDITY %							
VCI101101	Centrifugal Cooling Pump Coolers	P09	Aux	25 ft	II	104	Normal	-	1x10 ⁶ R	NA	NA	NA	This equipment was designed to the requirements of NEMA Std. MG-1. The motors for these fans and coolers utilize Class B insulation which has a maximum temperature rating of 150°C.
VCI101102	Containment Cooling Water Pump Coolers	P09	Aux	45 ft	II	104	Normal	-	1x10 ⁶ R	NA	NA	NA	
VCI101103	SM Booster Pump Coolers	P09	Aux	45 ft	II	104	Normal	-	1x10 ⁶ R	No.	NA	NA	
VCI101104	Containment Hydrogen Vent Fans	P09	Penetration Area	93 ft	II	104	Normal	-	1x10 ⁶ R	NA	NA	NA	
VCI101105	Containment Purge Exhaust Fans	P09	Penetration Area	94 ft	II	104	Normal	-	1x10 ⁶ R	NA	NA	NA	
VCI101106	SM Pump Fans	P09	Intake Structure	108 ft	II	104	Normal	-	1x10 ⁶ R	NA	NA	NA	
VCI101107	AFD Diesel Supply Fan	P09	Turbine	45 ft	VI	104	Normal	-	1x10 ⁶ R	NA	NA	NA	
VCI101108	AFD Diesel Exhaust Fan	P09	Turbine	45 ft	VI	104	Normal	-	1x10 ⁶ R	NA	NA	NA	Qualified by operating experience based on industry tests. This equipment was designed and tested to NEMA Std. MG-1. The motors for these fans utilize Class F insulation which has a maximum temperature rating of 150°C.
VCI101109	AFD Turbine Supply Fan	P09	Turbine	45 ft	VI	104	Normal	-	1x10 ⁶ R	NA	NA	NA	
VCI101110	AFD Turbine Exhaust Fan	P09	Turbine	45 ft	VI	104	Normal	-	1x10 ⁶ R	NA	NA	NA	

T.O.1574-014

FOOR ORIGINAL

220 55

TROJAN NUCLEAR PLANT
ENVIRONMENTAL QUALIFICATION REVIEW OF CLASS II & III ELECTRICAL EQUIPMENT

OUTSIDE CONTAINMENT

DESCRIPTION NO.	SPEC NO.	LOCATION BLDG.	ELEV.	ENVIRONMENTAL SERVICE CONDITION		TEMP. (°F)	PRESSURE (PSIA)	HUMIDITY %	RADIATION 1x10 ⁶ R	CHEMICAL NA	METHOD OF QUALIFICATION AND REPAIRS
				TEMP. (°F)	HUMIDITY %						
V25100-A, B, C Centrifugal Gassing Pump Coolers	P09	Aux	25 ft	I.	104	Normal	-	-	1x10 ⁶ R	NA	This equipment was designed to the requirement of NEMA Std. MG-1. The motors for these fans and coolers utilize Class B insulation which has a maximum temperature rating of 130°C.
V25100-A, B, C Containment Cooling Water Pump Coolers	P09	Aux	45 ft	II	104	Normal	-	-	1x10 ⁶ R	NA	
V25100-A, B SW B. Water Pump Coolers	P09	Aux	45 ft	II	104	Normal	-	-	1x10 ⁶ R	NA	
V25100-A, B Containment Hydrogen Vent Fans	P09	Penetration Area	93 ft	II	104	Normal	-	-	1x10 ⁶ R	NA	
V25100-A, B Containment Forge Exhaust Fans	P09	Penetration Area	94 ft	II	104	Normal	-	-	1x10 ⁶ R	NA	
V25100-A, B 54 Pump Fans	P09	Intake Structure	103 ft	II	104	Normal	-	-	1x10 ⁶ R	NA	
V25100-A, B AFW Diesel Supply Fan	P09	Turbine	45 ft	VI	104	Normal	-	-	1x10 ⁶ R	NA	
V25100-A, B AFW Diesel Exhaust Fan	P09	Turbine	45 ft	VI	104	Normal	-	-	1x10 ⁶ R	NA	Qualified by operating experience based on industry tests. This equipment was designed and tested to NEMA Std. MG-1. The motors for these fans utilize Class F insulation which has a maximum temper- ature rating of 155°C.
V25100-A, B AFW Turbine Supply Fan	P09	Turbine	45 ft	VI	104	Normal	-	-	1x10 ⁶ R	NA	
V25100-A, B AFW Turbine Exhaust Fan	P09	Turbine	45 ft	VI	104	Normal	-	-	1x10 ⁶ R	NA	

TROJAN-91-014

POOR ORIGINAL

323

535

THOLAN NUCLEAR PLANT
ENVIRONMENTAL QUALIFICATION REVIEW OF CLASS II ELECTRICAL EQUIPMENT

Page 10

OUTSIDE CONTAINERMENT

QUALIFICATION TEST	DESCRIPTION NO.	SPEC NO.	LOCATION ELEV.	ENVIRONMENTAL SERVICE CONDITION	VENDOR DOCUMENTATION		HUMIDITY %	RADIATION	CHEMICAL	METHOD OF QUALIFICATION AND REMARKS
					TEMP. (°F)	PRESSURE (PSIA)				
PT100-301	AIR Pump B Ditch Press	H218	Control	93 ft Y	40-125	Normal	10-90	Normal	N/A	Qualification was not required. The equipment is located in control room and will experience normal ambient conditions. (These instruments are Fisher Porter Model 50EK1000).
PT100-302	AIR Pump A Ditch Press	H218	Control	93 ft Y	30-120	Normal	-	Normal	N/A	
PT100-302	AIR Pump B Ditch Press	H218	Control	93 ft Y	30-130	Normal	-	Normal	N/A	
PT100-303A	AIR Pump A/ Site Line Diff	H218	Turbine G100	45 ft YI	30-120	Normal	-	Normal	N/A	
PT100-303B	AIR Pump B/ Site Line Diff	H218	Turbine G100	45 ft YI	30-130	Normal	-	Normal	N/A	
PT100-304A	Diesel Oil Level T6-1118A	H218	Control	93 ft Y	30-130	Normal	-	Normal	N/A	
PT100-305B	Diesel Oil Level T6-119B	H218	Control	93 ft Y	30-130	Normal	-	Normal	N/A	
PT100-306	Containment Pressure	H218	Control	93 ft Y	30-130	Normal	-	Normal	N/A	
PT100-307	Containment Pressure	H218	Control	93 ft Y	30-130	Normal	-	Normal	N/A	
PT100-308	Containment Pressure	H218	Control	93 ft Y	30-130	Normal	-	Normal	N/A	
PT100-309	Containment Pressure	H218	Control	93 ft Y	30-130	Normal	-	Normal	N/A	
PT100-310	Containment Pressure	H218	Control	93 ft Y	30-130	Normal	-	Normal	N/A	
PT100-311	RUST Level	H218	Control	93 ft Y	30-130	Normal	-	Normal	N/A	
PT100-312	RUST Level	H218	Control	93 ft Y	30-130	Normal	-	Normal	N/A	
PT100-313	RUST Level	H218	Control	93 ft Y	30-130	Normal	-	Normal	N/A	

100-01591-014

POOR ORIGINAL

TAJIAN NUCLEAR PLANT
ENVIRONMENTAL QUALIFICATION TESTS OF CLASS II ELECTRICAL EQUIPMENT

OUTSIDE CONTAINMENT

TEST ID	DESCRIPTION	SPEC NO.	LOCATION	BLDG.	SERVICE CONDITION	VENIOR DOCUMENTATION		METHOD OF QUALIFICATION AND REMARKS
						TEMP. (°F)	PRESSURE (PSIA)	
P-1-3-1-A D-4-B	A/W Pump P-102A P-1-3-1-F D-4-B	M216	Control	93 ft	V	40-125	Normal	- Normalization was not required. The equipment is located in control room and will experience normal ambient conditions. This controller is a Fisher Porter Model 53EC.
P-1-3-1-F D-4-B	A/W Pump P102B P-1-3-1-F D-4-B	M218	Control	93 ft	V	40-125	Normal	- Normal
P-1-3-1-A D-4-B	SWS Pump Discharge Rdt Press	M233	Intake Struct	23 ft	III	50-185	Normal	- 4 x 10 ⁵ R Qualified by test in Mercoid Corp. test report 44285-1.
P-1-3-1-A D-4-B	SWS Pump Discharge rdt Press	M233	Intake Struct	23 ft	III	50-185	Normal	- 4 x 10 ⁵ R Qualified by test in Mercoid Corp. test report 44285-1.
P-1-3-1-A D-4-B	Serv Wtr Booster Pmp A Disch	M233	Aux	45 ft	II	50-185	Normal	- 4 x 10 ⁵ R Qualified by test in Mercoid Corp. test report 44285-1.
P-1-3-1-A D-4-B	Serv Wtr Booster Pmp B Disch	M232	Aux	45 ft	II	50-185	Normal	- 4 x 10 ⁵ R Qualified by test in Mercoid Corp. test report 44285-1.
P-1-3-1-A D-4-B	Serv Wtr Booster Pmp C Disch	M233	Aux	45 ft	II	50-185	Normal	- 4 x 10 ⁵ R Qualified by test in Mercoid Corp. test report 44285-1.
P-1-3-1-A D-4-B	Serv Wtr Booster Pmp D Disch	M233	Aux	45 ft	II	50-185	Normal	- 4 x 10 ⁵ R Qualified by test in Mercoid Corp. test report 44285-1.
P-1-3-1-A D-4-B	SW Booster Pmps A & C Suct	M233	Intake Struct	23 ft	III	50-185	Normal	- 4 x 10 ⁵ R Qualified by test in Mercoid Corp. test report 44285-1.
P-1-3-1-A D-4-B	SW Booster Pmps B & D Suct	M233	Intake Struct	23 ft	III	50-185	Normal	- 4 x 10 ⁵ R Qualified by test in Mercoid Corp. test report 44285-1.
P-1-3-1-C	SW Booster A & C Suct	M233	Intake Struct	23 ft	III	50-185	Normal	- 4 x 10 ⁵ R Qualified by test in Mercoid Corp. test report 44285-1.
P-1-3-1-D	SW Booster Pmps B & D Suct	M233	Intake Struct	23 ft	III	50-185	Normal	- 4 x 10 ⁵ R Qualified by test in Mercoid Corp. test report 44285-1.
P-1-3-1-C	SW Booster Pmps B & D Disch	M233	Aux	45 ft	II	50-185	Normal	- 4 x 10 ⁵ R Qualified by test in Mercoid Corp. test report 44285-1.
P-1-3-1-E	SW Booster Pmps A & C Disch	M233	Aux	45 ft	II	50-185	Normal	- 4 x 10 ⁵ R Qualified by test in Mercoid Corp. test report 44285-1.

TJW
10/17/91-UV

ECC
10/17/91-UV

TROJAN NUCLEAR PLANT
ENVIRONMENTAL QUALIFICATION REVIEW OF CLASS 1E ELECTRICAL EQUIPMENT

Page 32

OUTSIDE CONTAINMENT

ITEM NO.	DESCRIPTION	SPEC NO.	LOCATION	ENVIRONMENTAL SERVICE CONDITION	VENDOR DOCUMENTATION		RADIACTION	CHEMICAL	METHOD OF QUALIFICATION AND Remarks
					TEMP. (°F.)	PRESSURE (PSIA)			
↓									
T-1001B	Rust Temp Control	H233	Process Yard	45 ft Outside Environment	37-104	+ .5	-	4x10 ⁵	NA
T-1001C	RUST Temp	H233	Process Yard	45 ft Outside Environment	37-104	+ .5	-	4x10 ⁵	NA
T-1001D	RUST Temp	H233	Process Yard	45 ft Outside Environment	37-104	+ .3	-	4x10 ⁵	NA
T-1001E	RUST Temp	H233	Process Yard	45 ft Outside Environment	37-104	+ .5	-	4x10 ⁵	NA
↓									
E1S-1015	CW Surge Tank A	H228	Aux/Fuel	75 ft IV	-60 to 200	Normal	-	Normal	NA
E1S-1016	CW Surge Tank B	H228	Aux/Fuel	75 ft IV	-60 to 200	Normal	-	Normal	NA
E1S-1017	Aux FW to SG A	H228	HSSS	63 ft VII	-60 to 200	Normal	-	Normal	NA
E1S-1018	Aux FW to SG A	H228	HSSS	63 ft VII	-60 to 200	Normal	-	Normal	NA
E1S-1019	Aux FW to SG B	H228	HSSS	63 ft VII	-60 to 200	Normal	-	Normal	NA
E1S-1020	Aux FW to SG B	H228	HSSS	63 ft VII	-60 to 200	Normal	-	Normal	NA
↓									
E1S-1021	Aux FW to SG C	H228	HSSS	63 ft VII	-60 to 200	Normal	-	Normal	NA
E1S-1022	Aux FW to SG C	H228	HSSS	63 ft VII	-60 to 200	Normal	-	Normal	NA
E1S-1023	Aux FW to SG D	H228	HSSS	63 ft VII	-60 to 200	Normal	-	Normal	NA
E1S-1024	Aux FW to SG D	H228	HSSS	63 ft VII	-	Normal	-	Normal	NA

625
825

POOR ORGANIZATION

ENVIRONMENTAL QUALIFICATION REVIEW OF CLASS I ELECTRICAL EQUIPMENT

Page 33

ITEM	DESCRIPTION NO.	SPEC NO.	LOCATION BLDG. ELEV.	ENVIRONMENTAL SERVICE CONDITION	VENIOR DOCUMENTATION			METHOD OF QUALIFICATION AND REMARKS
					TEMP. (°F)	PRESSURE (PSIA)	HUMIDITY %	
1.1-18-9	Fueling Wtr Storage Tank Level	H-228	Yard Area	40°-70° /	Outside Environment	-40 to 160	Normal	Normal NA
1.1-19-0	Fueling Wtr Storage Tank Level	H-228	Yard Area	40°-70° /	Outside Environment	-40 to 160	Normal	This device has successfully passed LOCA type environmental conditions and is housed in weather proof enclosures. Reference W CAP 714 and ITT Barton Test Report. These transmitters are ITT Barton Model 393.
1.1-19-4	Fueling Wtr Storage Tank Level	H-228	Yard Area	40°-70° /	Outside Environment	-40 to 160	Normal	Normal NA
1.1-19-8	Fueling Wtr Storage Tank Level	H-228	Yard Area	40°-70° /	Outside Environment	-40 to 160	Normal	Normal NA
2.1-1-1	Containment Atmospheric Pressure	H-228	Outside Containment	70°-20° IV	IV	-40 to 160	Normal	Normal NA
2.1-2-1	Containment Pressure Transmitters	H-228	Outside Containment	55°-20° IV	IV	-40 to 160	Normal	Normal NA
2.1-2-2	Containment Pressure Transmitters	H-228	Outside Containment	68°-1° IV	IV	-40 to 160	Normal	Normal NA
2.1-2-3	Containment Pressure Transmitters	H-228	Outside Containment	64°-10° IV	IV	-40 to 160	Normal	Normal NA
2.1-3-1	Aux FW Pump A Ditch	H-228	Turb	49°-3° VI	VI	-40 to 160	Normal	Normal NA
2.1-3-2	Aux FW Pump B Ditch	H-228	Turb	48°-6° VI	VI	-40 to 160	Normal	Normal NA
2.1-3-3	CCW Surge Tank A	H-228	Aux/Fuel	75 ft	IV	-60 to 200	Normal	Statement of Conformance by ITT Barton Meeting Trojan Spec. H-228. These transmitters are ITT Barton Model 283A.
2.1-3-4	CCW Surge Tank B	H-228	Aux/Fuel	75 ft	IV	-60 to 200	Normal	Normal NA

**ENVIRONMENTAL QUALIFICATION REVIEW OF CLASS II ELECTRICAL EQUIPMENT
THILO HUNTER PLANT**

DESCRIPTION NO.		SPEC NO.	LOCATION BLDG.	ELEV.	ENVIRONMENTAL SERVICE CONDITION	TEMP. (°F)	PRESSURE (PSIA)	HUMIDITY %	RADIATION	CHEMICAL	METHOD OF CONFORMANCE AND REMARKS
1.5-479A Day Tank T-152A		H-228	Turb	49°+7°	VI	-60 to 200	Normal	-	Normal	NA	Statement of conformance by ITT Barton meeting Trojan's Spec. M-224 (These transmitters are ITT Barton Model 285A).
1.5-491A Day Tank T-152B		H-228	Turb	49°+7°	VI	-60 to 200	Normal	-	Normal	NA	
1.5-491A Emergency DSL Tank T-111A		H-228	Turb	49°	VI	-60 to 200	Normal	-	Normal	NA	
1.5-491A Emergency DSL Tank T-111B		H-228	Turb	49°	VI	-60 to 200	Normal	-	Normal	NA	
1.5-491A Emergency DSL Tank T-111B		H-228	Turb	49°	VI	-60 to 200	Normal	-	Normal	NA	
1.5-491A Pump Trip A		H-228	Aux	49°	II	-60 to 200	Normal	-	Normal	NA	
1.5-491A Pump Trip B		H-228	Aux	49°	II	-60 to 200	Normal	-	Normal	NA	
1.5-491A Surge Tank A		H-228	HS55	75°	IV	-60 to 200	Normal	-	Normal	NA	
1.5-491A Surge Tank B		H-228	HS55	75°	IV	-60 to 200	Normal	-	Normal	NA	
1.5-491A Surge Tank C		H218	Turbine C160	45°	VI	40-105	Normal	-	Normal	NA	
1.5-491A Air Pump P1028 Drain		H218	Turbine C160	45°	VI	40-105	Normal	-	Normal	NA	
1.5-491A Diesel Oil Storage Tank		H224	Process Yard	41°	Outside Environment	-40 to 160	No. 201	-	Normal	NA	Statement of conformance by Fisher Porter meeting Trojan's Spec. M-224 (These transmitters are Fisher Porter Model 240).
1.5-491A Diesel Oil Storage Tank		H224	Process Yard	41°	Outside Environment	-40 to 160	No. 201	-	Normal	NA	

卷之三

THE POOR ORIGIN

TULAHAN NUCLEAR PLANT
 ENVIRONMENTAL QUALIFICATION REVIEW OF CLASS 1E ELECTRICAL EQUIPMENT

OUTSIDE CONTAINMENT

ITEM NO.	DESCRIPTION	SPEC NO.	LOCATION ELEV.	ENVIRONMENTAL SERVICE CONDITION	VENDOR DOCUMENTATION			CHEMICAL	METHOD OF QUALIFICATION AND REMARKS
					TEMP. (°F)	PRESSURE (PSIA)	HUMIDITY %		
<u>OUTSIDE CONTAINMENT</u>									
PE-1101-A	Containment Spray Valve	H112B	Aux	26°-74°	II	311	60	100	2x10 ⁸ R
PE-1101-B	"	H112B	"	26°-74°	II	311	60	100	2x10 ⁸ R
PE-1101-C	Cond. & Feedwater Valve	H134D	Turbine	44°-48°	VII	311	60	100	2x10 ⁸ R
PE-1101-D	"	H134D	"	44°-48°	VII	311	60	100	2x10 ⁸ R
PE-1101-E	Cont. Spray Sys. Valve	H138A	Piping Penetration Area	41°-64°	IV	311	60	100	2x10 ⁸ R
PE-1101-F	"	H138A	"	41°-64°	IV	311	60	100	2x10 ⁸ R
PE-1101-G	Cont. Spray Sys. Valve	H138A	Piping Penetration Area	58°-104°	IV	311	60	100	2x10 ⁸ R
PE-1101-H	"	H138A	"	78°-24°	IV	311	60	100	2x10 ⁸ R
PE-1101-I	Cont. Spray Sys. Valve	H138A	Aux	11°-64°	II	311	60	100	2x10 ⁸ R
PE-1101-J	"	H138A	"	11°-64°	II	311	60	100	2x10 ⁸ R
PE-1101-K	Cond. & Feedwater Valve	H208B ₄	Turbine	45°-104°	VII	311	60	100	2x10 ⁸ R
PE-1101-L	Component Cooling Valve	H208D	Piping Penetration Area	78°-34°	IV	311	60	100	2x10 ⁸ R
PE-1101-M	"	H208D	"	55°-94°	IV	311	60	100	2x10 ⁸ R
PE-1101-N	"	H208D	"	78°-34°	IV	311	60	100	2x10 ⁸ R
PE-1101-O	Component Cooling	H208B ₂	Fuel	53°-94°	IV	311	60	100	2x10 ⁸ R
PE-1101-P	"	H208B ₂	"	67°-64°	IV	311	60	100	2x10 ⁸ R

TICKET#94-0119

POOR ORIGNAL

TRILOJAH NUCLEAR PLANT
ENVIRONMENTAL QUALIFICATION REVIEW OF CLASS II ELECTRICAL EQUIPMENT

Page 16

OUTSIDE CONTAINMENT									
EQ. LOC. NO.	DESCRIPTION NO.	SPEC NO.	LOC. BLDG. ELEV.	ENVIRONMENTAL SERVICE CONDITION	VENDOR DOCUMENTATION	TEMP. PRESSURE HUMIDITY	RADIATION	CHEMICAL	METHOD OF QUALIFICATION AND REMARKS
E-1-100	Gen. Gen. Shutdown Valve	H-60	Main Steam Support Structure Area	52°-10"	VII	311 60 100	2x10 ⁸ R	NA	All of the following listed valves are Limitoware manufactured and utilize a Class B insulated motor. This type of motor operated valve was type tested in the generic environment. MCAP-7744 qualified the Class B insulated motor to LOCA environment for 8 hours. All of the listed valves are located outside containment. These valves are qualified by type test and operating experience.
E-1-101	"	H-60	"	53°-11"	VII	311 60 100	2x10 ⁸ R	NA	
E-1-102	"	H-60	"	53°-4"	VII	311 60 100	2x10 ⁸ R	NA	
E-1-103	"	H-60	"	53°-6"	VII	311 60 100	2x10 ⁸ R	NA	
E-1-104	"	H112A	"	61°-9"	VII	311 60 100	2x10 ⁸ R	NA	
E-1-105	"	H112A	"	63°-11"	VII	311 60 100	2x10 ⁸ R	NA	
E-1-106	"	H112A	"	63°-11"	VII	311 60 100	2x10 ⁸ R	NA	
E-1-107	"	H112A	"	63°-11"	VII	311 60 100	2x10 ⁸ R	NA	
E-1-108	"	H112A	"	61°-7"	VII	311 60 100	2x10 ⁸ R	NA	
E-1-109	Main Steam Valve	H109B	"	71°-0"	VII	311 60 100	2x10 ⁸ R	NA	
E-1-110	"	H109B	"	71°-0"	VII	311 60 100	2x10 ⁸ R	NA	
E-1-111	"	H109B	"	71°-0"	VII	311 60 100	2x10 ⁸ R	NA	
E-1-112	Aux Steam Valve	H109B	Turbine	54°-0"	VII	311 60 100	2x10 ⁸ R	NA	
E-1-113	Diesel Fuel Oil Valve	H112A	"	58°-4"	VI	311 60 100	2x10 ⁸ R	NA	
E-1-114	"	H112A	"	58°-4"	VI	311 60 100	2x10 ⁸ R	NA	
E-1-115	Diesel Fuel Oil Valve	H112A	"	47°-7"	VI	311 60 100	2x10 ⁸ R	NA	
E-1-116	"	H112A	Turbine	47°-6"	VI	311 60 100	2x10 ⁸ R	NA	
E-1-117	Feedwater	H112A	"	45°-8"	VII	311 60 100	2x10 ⁸ R	NA	

TIG01794.018

POOR ORIGINAL

535
325

TROJAN NUCLEAR PLANT
ENVIRONMENTAL QUALIFICATION REVIEW OF CLASS IIP ELECTRICAL EQUIPMENT

Page 37

CONTAINMENT

EQUIP. NO.	DESCRIPTION NO.	SPEC NO.	LOCATION BLDG. ELV.	ENVIRONMENTAL SERVICE CONDITION	VENDOR DOCUMENTATION			CHEMICAL	METHOD OF QUALIFICATION AND RESULTS
					TEMP. (°F)	PRESSURE (PSIA)	HUMIDITY %		
EQ-11019	CCW Seal	H-208	Aux	66°-0"	11	311	60	100	2x10 ⁸ R
EQ-11018	Component Ctg. Valve	H-208	Aux	34°-3"	11	311	60	100	2x10 ⁸ R
EQ-11018	"	H-208	Aux	34°-3"	11	311	60	100	2x10 ⁸ R
EQ-11018	Hydrogen Vent Syst. Valve	H-209	Between Cont. & Aux Bldg.	81°-3"	14	311	60	100	2x10 ⁸ R
EQ-11016	"	H-209	"	81°-3"	14	311	60	100	2x10 ⁸ R
EQ-11014	"	H-209	"	53°-0"	14	311	60	100	2x10 ⁸ R
EQ-11012	"	H-209	"	53°-0"	14	311	60	100	2x10 ⁸ R
EQ-11013	Containment Sampling Valve	H-113B	"	95°-0"	14	311	60	100	2x10 ⁸ R
EQ-11011	"	H-113B	"	95°-0"	14	311	60	100	2x10 ⁸ R
EQ-11015	"	H-113B	"	78°-0"	14	311	60	100	2x10 ⁸ R
EQ-11016	"	H-113B	"	78°-0"	14	311	60	100	2x10 ⁸ R
EQ-11017	"	H-113B	Aux	101°-0"	11	311	60	100	2x10 ⁸ R
EQ-11018	"	H-113B	Aux	101°-0"	11	311	60	100	2x10 ⁸ R
EQ-11019	Volume Control Tank	H1R	Aux	"	11	311	60	100	2x10 ⁸ R
EQ-11020	"	H1R	Aux	"	11	311	60	100	2x10 ⁸ R
EQ-11021	East Valve	H1R	Aux	"	11	311	60	100	2x10 ⁸ R
EQ-11022	West Valve	H1R	Aux	"	11	311	60	100	2x10 ⁸ R
EQ-11024	Emergency Rotation	H1R	Aux	25 ft.	11	311	60	100	2x10 ⁸ R
EQ-11025	Chg. Line Isolation	H1R	Aux	25 ft.	11	311	60	100	2x10 ⁸ R

TQ14594-01V

POOR ORIGINAL

625
333

THOJAN NUCLEAR PLANT
ENVIRONMENTAL QUALIFICATION REVIEW OF CLASS 1E ELECTRICAL EQUIPMENT

Page 38

OUTSIDE CONTAINMENT									
DESCRIPTION	SPEC NO.	BLDG.	LOCATION	ENVIRONMENTAL SERVICE CONDITION	TEMP. (°F.)	VENDOR DOCUMENTATION PRESSURE (PSIA)	HUMIDITY (%)	RADIATION	CHEMICAL
Chg. Line Isolation	P-8101	MIR	Aux	25 ft. II	311	60	100	2x10 ⁸ R	NA
Chg. Line Isolation	P-8102	MIR	Aux	25 ft. II	311	60	100	2x10 ⁸ R	NA
Chg. Line Isolation	P-8103	MIR	Aux	25 ft. II	311	60	100	2x10 ⁸ R	NA
St. S. P. A.	S-8104A	MIR Suction	MIR	5 ft. II	311	60	100	2x10 ⁸ R	NA
S. S. P. A.	S-8105	KIR Suction	MIR	5 ft. II	311	60	100	2x10 ⁸ R	NA
BOR Isolation	S-8106	BOR Isolation	MIR	5 ft. II	311	60	100	2x10 ⁸ R	NA
SF Suction	S-8107	SF Suction	MIR	25 ft. II	311	60	100	2x10 ⁸ R	NA
SF Suction	S-8108	SF Suction	MIR	25 ft. II	311	60	100	2x10 ⁸ R	NA
Boron Injection	S-8109A	Boron Injection	MIR	Fuel 45 ft. II	311	60	100	2x10 ⁸ R	NA
Boron Injection	S-8110	Boron Injection	MIR	Fuel 45 ft. II	311	60	100	2x10 ⁸ R	NA
SI System	S-8111A	SI System	MIR	Aux 25 ft. II	311	60	100	2x10 ⁸ R	NA
SI System	S-8112B	SI System	MIR	Aux 25 ft. II	311	60	100	2x10 ⁸ R	NA
Boron Inj. Tap.	S-8113A	Boron Inj. Tap.	MIR	Aux 45 ft. II	311	60	100	2x10 ⁸ R	NA
Boron Inj. Tap.	S-8114B	Boron Inj. Tap.	MIR	Aux 45 ft. II	311	60	100	2x10 ⁸ R	NA
RHR Sys.	P-8115A	RHR Sys.	MIR	Aux 5 ft. II	311	60	100	2x10 ⁸ R	NA
RHR Sys.	P-8116A	RHR Sys.	MIR	Aux 5 ft. II	311	60	100	2x10 ⁸ R	NA
SI Suction	P-8117C	SI Suction	MIR	25 ft. II	311	60	100	2x10 ⁸ R	NA
Crossover Valve	P-8118A	Crossover Valve	MIR	Aux 5 ft. II	311	60	100	2x10 ⁸ R	NA
Crossover Valve	P-8119B	Crossover Valve	MIR	5 ft. II	311	60	100	2x10 ⁸ R	NA
LP SI	P-8120A	LP SI	MIR	25 ft. II	311	60	100	2x10 ⁸ R	NA

110-3592-01W

POOR ORIGINAL

335

335

OUTSIDE CONTAINMENT

DESCRIPTION NO.	SPEC NO.	LOCATION BLDG.	ELEV.	ENVIRONMENTAL SERVICE CONDITION	VENDOR DOCUMENTATION TEMP. (°F)	PRESSURE (PSIA)	HUMIDITY %	RADIATION	CHEMICAL	METHOD OF QUALIFICATION AND REMARKS
PIE-11A	Cont'st Sump	HIR	25 ft	II	311	60	100	2x10 ⁻⁸ R	NA	All of the following listed valve operators are Limit torque manufactured and utilized & Class B insulated motor. This type of motor operated valve was type tested in the generic test in KCAP-7744 for a LOCA environment. KCAP-7744 qualified the Class B insulated motor to LOCA environment for 8 hours. All of the listed valves are located outside containment. These valves are qualified by type test and operating experience.
PIE-11B	Cont'st Sump	HIR	25 ft	II	311	60	100	2x10 ⁻⁸ R	NA	
PIE-11C	HIR Isolation	HIR	25 ft	II	311	60	100	2x10 ⁻⁸ R	NA	
PIE-11D	SI Isolation	HIR	25 ft	II	311	60	100	2x10 ⁻⁸ R	NA	
PIE-11E	SI Isolation	HIR	25 ft	II	311	60	100	2x10 ⁻⁸ R	NA	
PIE-11F	SI Disch.	HIR	25 ft	II	311	60	100	2x10 ⁻⁸ R	NA	
PIE-11G	SI Disch.	HIR	25 ft	II	311	60	100	2x10 ⁻⁸ R	NA	
PIE-11H	SI to RCS	HIR	25 ft	II	311	60	100	2x10 ⁻⁸ R	NA	
PIE-11I	SI Suction	HIR	25 ft	II	311	60	100	2x10 ⁻⁸ R	NA	
PIE-11J	SI Suction	HIR	25 ft	II	311	60	100	2x10 ⁻⁸ R	NA	
PIE-11K	Class. Pump to SI	HIR	25 ft	II	311	60	100	2x10 ⁻⁸ R	NA	

CCG

PUNK ORIGINAL

TROJAN NUCLEAR PLANT
 ENVIRONMENTAL QUALIFICATION REVIEW OF CLASS IIE ELECTRICAL EQUIPMENT

DESCRIPTION		SPEC NO.	LOCATION	ENVIRONMENTAL SERVICE CONDITION	VENDOR DOCUMENTATION	HUMIDITY %	RADIATION	CHEMICAL	METHOD OF QUALIFICATION AND REPAIRS
			BLDG. ELEV.		TEMP. °F	PRESSURE (PSIA)			
F75.14	Site Generator	HI	HSSS	59 ft	IV, V11	-5 to 286	60	100	1 x 10 ⁸ R
F75.15	Pressure	HI	HSSS	59 ft	IV, V11	-5 to 286	60	100	1 x 10 ⁸ R
F75.16	Pressure	HI	HSSS	59 ft	IV, V11	-5 to 286	60	100	1 x 10 ⁸ R
F75.17	Pressure	HI	HSSS	59 ft	IV, V11	-5 to 286	60	100	1 x 10 ⁸ R
F75.18	Pressure	HI	HSSS	59 ft	IV, V11	-5 to 286	60	100	1 x 10 ⁸ R
F75.19	Pressure	HI	HSSS	59 ft	IV, V11	-5 to 286	60	100	1 x 10 ⁸ R
F75.20	Pressure	HI	HSSS	59 ft	IV, V11	-5 to 286	60	100	1 x 10 ⁸ R
F75.21	Pressure	HI	HSSS	59 ft	IV, V11	-5 to 286	60	100	1 x 10 ⁸ R
F75.22	Pressure	HI	HSSS	59 ft	IV, V11	-5 to 286	60	100	1 x 10 ⁸ R
F75.23	Pressure	HI	HSSS	59 ft	IV, V11	-5 to 286	60	100	1 x 10 ⁸ R
F75.24	Pressure	HI	HSSS	59 ft	IV, V11	-5 to 286	60	100	1 x 10 ⁸ R
F75.25	Pressure	HI	HSSS	59 ft	IV, V11	-5 to 286	60	100	1 x 10 ⁸ R
F75.26	Pressure	HI	HSSS	59 ft	IV, V11	-5 to 286	60	100	1 x 10 ⁸ R
F75.27	Pressure	HI	HSSS	59 ft	IV, V11	-5 to 286	60	100	1 x 10 ⁸ R
F75.28	Pressure	HI	HSSS	59 ft	IV, V11	-5 to 286	60	100	1 x 10 ⁸ R
F75.29	Pressure	HI	HSSS	59 ft	IV, V11	-5 to 286	60	100	1 x 10 ⁸ R
F75.30	Site Gen. Feedwater Flow	HI	HSSS	59 ft	IV, V11	-5 to 286	60	100	1 x 10 ⁸ R
F75.31	Site Gen. Feedwater Flow	HI	HSSS	59 ft	IV, V11	-5 to 286	60	100	1 x 10 ⁸ R

T-101591-01V

332 333

TROJAN NUCLEAR PLANT
ENVIRONMENTAL QUALIFICATION REVIEW OF CLASS 1C ELECTRICAL EQUIPMENT

OUTSIDE CONTAINMENT

ITEM	DESCRIPTION	SPEC NO.	LOCATION BLDG.	ELEV.	ENVIRONMENTAL SERVICE CONDITION	VENDOR DOCUMENTATION			CHEMICAL	METHOD OF QUALIFICATION AND REFERENCES
						TEMP. (°F)	PRESSURE (PSIA)	HUMIDITY %		
F1.1	Stm Gen. Feedwater Flow	HI	HSSB	59 ft	IV, VII	-5 to 286	60	100	1×10^8 R	N.A.
F1.1	Stm Gen. Feedwater Flow	HI	HSS	59 ft	IV, VII	-5 to 286	60	100	1×10^8 R	N.A.
F1.1	Stm Gen. Feedwater Flow	HI	HSSS	59 ft	IV, VII	-5 to 286	60	100	1×10^8 R	N.A.
F1.1	Stm Gen. Feedwater Flow	HI	HSS	59 ft	IV, VII	-5 to 286	60	100	1×10^8 R	N.A.
F1.1	Stm Gen. Feedwater Flow	HI	HSSS	59 ft	IV, VII	-5 to 286	60	100	1×10^8 R	N.A.
F1.1	Stm Gen. Feedwater Flow	HI	HSS	59 ft	IV, VII	-5 to 286	60	100	1×10^8 R	N.A.

333 555

POOR ORIGINAL

TROJAN NUCLEAR PLANT
ENVIRONMENTAL QUALIFICATION REVIEW OF CLASS II ELECTRICAL EQUIPMENT

Page 42

ITEM NO.	DESCRIPTION	SPEC NO.	LOCATION	BLDG.	SERVICE CONDITION	VENDOR DOCUMENTATION			CHEMICAL	METHOD OF QUALIFICATION AND RESULTS
						TEMP. (°F)	PRESSURE (PSIA)	HUMIDITY %		
CV101-1	Containment Isolation	H209	Aux	93 FT	II	32 to 176	Normal	100	2x10 ⁷ R	NA
CV101-2	Containment Isolation	H209	Aux	93 FT	II	32 to 176	Normal	100	2x10 ⁷ R	NA
CV101-3	Chilled Water Return	H209	Aux	77 FT	II	32 to 176	Normal	100	2x10 ⁷ R	NA
CV101-4	Chilled Water Supply	H209	Aux	77 FT	II	32 to 176	Normal	100	2x10 ⁷ R	NA
CV101-5	KIR Sample	H113	Aux	9 FT	II	32 to 176	Normal	100	2x10 ⁷ R	NA
CV101-6	KIR Sample	H113	Aux	9 FT	II	32 to 176	Normal	100	2x10 ⁷ R	NA
CV101-7	Steam Line Drain	H112	Main Steam Support Structure	77 FT	IV, VII	32 to 176	Normal	100	2x10 ⁷ R	NA
CV101-8	Steam Line Drain	H112	Main Steam Support Structure	77 FT	IV, VII	32 to 176	Normal	100	2x10 ⁷ R	NA
CV101-9	Steam Line Drain	H112	Main Steam Support Structure	77 FT	IV, VII	32 to 176	Normal	100	2x10 ⁷ R	NA
CV101-10	Steam Line Drain	H112	Main Steam Support Structure	77 FT	IV, VII	32 to 176	Normal	100	2x10 ⁷ R	NA
CV101-11	Steam Gen Blvdn	H112	Main Steam Support Structure	93 FT	IV, VII	32 to 176	Normal	100	2x10 ⁷ R	NA
CV101-12	Steam Gen Blvdn	H112	Main Steam Support Structure	93 FT	IV, VII	32 to 176	Normal	100	2x10 ⁷ R	NA

10001594-01V

POOR ORIGINAL

THOLOH NUCLEAR PLANT
ENVIRONMENTAL QUALIFICATION REVIEW OF CLASS IIE ELECTRICAL EQUIPMENT

OUTSIDE CONTAINMENT

ITEM NO.	DESCRIPTION	SPEC NO.	LOCATION	ENVIRONMENTAL SERVICE CONDITION	VENDOR DOCUMENTATION			CHEMICAL	METHOD OF QUALIFICATION AND REPAIRS
					TEMP. (°F)	PRESSURE (PSIA)	HUMIDITY %		
<u>OUTSIDE CONTAINMENT</u>									
CV-101	S. m Gen Bldn	H112	Main Strm Support Structure	93 FT	IV, VII	32 to 176	Normal	100	2x10 ⁷ R
CV-102	S. m Gen Bldn	H112	Main Strm Support Structure	93 FT	IV, VII	32 to 176	Normal	100	2x10 ⁷ R
CV-103	Main Strm Isolation Valve	H123	Main Strm Support Structure	73 FT	IV, VII	-5 to 107	Normal	20-80	3x10 ⁵ R
CV-104	Main Strm Isolation Valve	K123	Main Strm Support Structure	73 FT	IV, VII	-5 to 107	Normal	20-80	3x10 ⁵ R
CV-105	Main Strm Isolation Valve	H123	Main Strm Support Structure	73 FT	IV, VII	-5 to 107	Normal	20-80	3x10 ⁵ R
CV-106	Main Strm Isolation Valve	H123	Main Strm Support Structure	73 FT	IV, VII	-5 to 107	Normal	20-80	3x10 ⁵ R
CV-107	Aux PW Valve	H204	Main Strm Support Structure	59 FT	IV, VII	-5 to 340	Normal	20-80	3x10 ⁵ R
CV-108	Aux PW Valve	H204	Main Strm Support Structure	59 FT	IV, VII	-5 to 340	Normal	10-1	2x10 ⁵ R
CV-109	Aux PW Valve	H204	Main Strm Support Structure	59 FT	IV, VII	-5 to 340	Normal	100	2x10 ⁵ R
CV-110	Aux PW Valve	H204	Main Strm Support Structure	59 FT	IV, VII	-5 to 340	Normal	100	2x10 ⁵ R

CCG

POOR ORIGINAL

11-1791-UV

ENVIRONMENTAL QUALIFICATION REVIEW OF CLASS I¹ ELECTRICAL EQUIPMENT

TROJAN NUCLEAR F. AND

OUTSIDE CONTAINMENT

DESCRIPTION Ref.	SPEC. No.	BLDG. ELEV.	LOCATION ELEV.	ENVIRONMENTAL SERVICE CONDITION	VENDOR DOCUMENTATION			METHOD OF QUALIFICATION AND R. MARKS	
					TEMP. (°F)	PRESSURE (PSIA)	HUMIDITY %		
CV3000A1	Aux FM Valves	H204	Main Strm Support Structure	59 FT	IV, VI	30	Normal	100	2x10 ⁸ R NA See CV3000A1.
CV3000A2	Aux FM Valves	A204	Main Strm Support Structure	59 FT	IV, VI	30	Normal	100	2x10 ⁸ R NA See CV3000A1.
CV3000A3	Aux FM Valves	H204	Main Strm Support Structure	59 FT	IV, VI	30	Normal	100	2x10 ⁸ R NA See CV3000A1.
CV3000A4	C/W Isolation	H208B2	Aux	4.5 FT	II	32-176	Normal	100	= NA Statement of conformance by Allis Chalmers complying with Trojan Spec. Controls coupling with Trojan Spec. H208. These are air operated valves utilizing ASCO solenoids 8321A with explosion proof/watertight enclosures.
CV3000A5	C/W Isolation	H208B2	Aux	4.5 FT	II	32-176	Normal	100	= NA Statement of conformance by Fisher Controls complying with Trojan Spec. H208. These are air operated valves utilizing ASCO solenoids 8321A with explosion proof/watertight enclosures.
CV3000A6	C/W Isolation	H208B2	Fuel	4.5 FT	II	32-176	Normal	100	= NA Statement of conformance by Fisher Controls complying with Trojan Spec. H208. These are air operated valves utilizing ASCO solenoids 8321A with explosion proof/watertight enclosures.
CV3000A7	S4 to EDG	H208BA	D.G. Area	4.5 FT	VI	32-176	Normal	100	= NA Statement of conformance by Fisher Controls complying with Trojan Spec. H208. These are air operated valves utilizing ASCO solenoids 8321A with explosion proof/watertight enclosures.
CV3000A8	S4 to EDG	H208BA	D.G. Area	4.5 FT	VI	32-176	Normal	100	= NA Statement of conformance by Fisher Controls complying with Trojan Spec. H208. These are air operated valves utilizing ASCO solenoids 8321A with explosion proof/watertight enclosures.
CV3000A9	S4 System	H208BA	D.G. Area	4.5 FT	VI	32-176	Normal	100	= NA Statement of conformance by Fisher Controls complying with Trojan Spec. H208. These are air operated valves utilizing ASCO solenoids 8321A with explosion proof/watertight enclosures.
CV3000A10	S4 to HVAC	H208BA	Aux	4.0 FT	IV	32-176	Normal	100	= NA Same as above
CV3000A11	S4 to HVAC	H208BA	Aux	4.0 FT	IV	32-176	Normal	100	= NA Same as above
CV3000A12	S4 System	A36	Yard Area	4.5 FT	Outside	-	Normal	-	No information available.
CV3000A13	S4 System	H36	Yard Area	4.5 FT	Outside	-	Normal	-	No information available.
CV3000A14	S4 System	H208	D. G. Area	4.5 FT	VI	32-176	Normal	100	= NA See CV3712A.
CV3000A15	S4 System	H208	Intake St.	30 FT	II	32-176	Normal	100	= NA See CV3712A.
CV3000A16	S4 Tools+	H208	Intake St.	30 FT	II	32-176	Normal	100	= NA See CV3712A.
CV3000A17	S4 Tools	A12	Aux	4.5 FT	II	32-176	Normal	-	= NA See CV3712A.
CV3000A18	Cont'g Susp	H36	Outside Aux	4.5 FT	II	32-176	Normal	100	2x10 ⁷ R NA Statement of conformance by Anchor Valve complying with Trojan Spec. H11B. These air operated valves utilize ASCO solenoids H18302B26RU with watertight enclosures.

T1201591-014

POOR ORIGINAL

333

555

TROJAN NUCLEAR PLANT
ENVIRONMENTAL QUALIFICATION REVIEW OF CLASS 12 ELECTRICAL EQUIPMENT

OUTSIDE CONTAINMENT

TEST ID	DESCRIPTION	SPEC NO.	LOCATION	ENVIRONMENTAL SERVICE CONDITION	VENDOR DOCUMENTATION TEMP. (°F)	HUMIDITY %	RADIATION	CHEMICAL	METHOD OF QUALIFICATION AND REMARKS
									TEMP. (PSIA)
<u>OUTSIDE CONTAINMENT</u>									
CV5-11	Gas Collect	H138	H558	45 FT	IV, VII	32-176	Normal	100	2x10 ⁷ R
CV5-12	Instr. Air	H112	H558	61 FT	IV, V	32-176	Normal	100	2x10 ⁷ R
CV5-13	Instr. Air	H112	H558	61 FT	IV, VII	32-176	Normal	100	2x10 ⁷ R
CV5-14	HST Sys	H130	Aux	45 FT	II	32-176	Normal	100	2x10 ⁷ R
CV5-15	HST Sys	H130	Aux	45 FT	II	32-176	Normal	100	2x10 ⁷ R
CV5-16	ACUA Sample	H113	Cable Penetration Area	45 FT	IV	32-176	Normal	100	2x10 ⁷ R
CV5-17	HCS Sample	H113	Cable Penetration Area	45 FT	IV	32-176	Normal	100	2x10 ⁷ R
CV5-18	PSZR Sample	H113	Cable Penetration Area	45 FT	IV	32-176	Normal	100	2x10 ⁷ R
CV5-19	PSZR Sample	H113	Cable Penetration Area	45 FT	IV	32-176	Normal	100	2x10 ⁷ R
CV5-20	PCDT Sample	H113	Cable Penetration Area	45 FT	IV	32-176	Normal	100	2x10 ⁷ R
CV5-21	PSZR Sample	H1R	Cable Penetration Area	45 FT	IV	350	60	100	1x10 ⁶ R
CV5-22	PSZR Sys	H1R	Aux	63 FT	II	350	60	100	1x10 ⁶ R
CV5-23	PSZR Sys	H1R	Aux	56 FT	II	350	60	100	1x10 ⁶ R
CV5-24	Letdown Tool	H1R	Aux	63 FT	II	350	60	100	1x10 ⁶ R
CV5-25	Boron Inj.	H1R	Aux	25 FT	II	350	60	100	1x10 ⁶ R
Statement of conformance by Anchor Val complying with Trojans Spec. H138-T air operated valves utilize ASCO solenoid HTB30268U with watertight enclosure See CV2794.									
See CV2294.									
See CV4181.									
See CV4181.									
Qualified by operating experience and test in ASCO test report L12, June 4, 1972. (Air operated valves with ASCO solenoids 8120A801B in explosion proof watertight enclosure).									

71001291-01V

POOR ORIGINAL

337 533

TROJAN NUCLEAR PLANT
ENVIRONMENTAL QUALIFICATION REVIEW OF CLASS I E ELECTRICAL EQUIPMENT

Page 46

OUTSIDE CONTAINMENT

DESCRIPTION [P]	SPEC NO.	BLDG.	LOCATION #LEV.	ENVIRONMENTAL SERVICE CONDITION		VENDOR DOCUMENTATION PRESSURE (PSIA)	HUMIDITY %	RADIACTION	CHEMICAL	METHOD OF QUALIFICATION AND REMARKS
				TSLP. (°F)	TLSP. (°F)					
CV22108 Access. Sys.	M18	Aux	25 Ft	II	III	350	60	100	Ia10 ⁴ R	NA
CV22109 Access. Sys.	M18	Aux	59 Ft	II	III	350	60	100	Ia10 ⁴ R	NA
CV22110 SIS Sys.	M18	Aux	25 Ft	II	III	350	60	100	Ia10 ⁴ R	NA
CV22111 SIS Sys.	M18	Aux	63 Ft	II	III	350	60	100	Ia10 ⁴ R	NA
CV22112 P.C. Unit. Sys.	M18	Aux	45 Ft	II	III	350	60	100	Ia10 ⁴ R	NA
CV22113 Steam Isolation Bypass Solenoid Valve	M232	Outside Aux	101 FT	IV	-5 to 107	Normal	20-80	3x10 ⁴ R	NA	Statement of conformance by R.G. Lawrence Co. complying with Trojan's Spec. M-232. Note that CV2279 has had component failure because of adverse weather conditions. Dated March 31, 1978.
CV22114 Steam Isolation Bypass Solenoid Valve	M232	Outside Aux	101 FT	IV	-5 to 107	Normal	20-80	3x10 ⁴ R	NA	
CV22115 Steam Isolation Bypass Solenoid Valve	M232	Outside Aux	101 FT	IV	-5 to 107	Normal	20-80	3x10 ⁴ R	NA	
CV22116 Steam Isolation Bypass Solenoid Valve	M232	Outside Aux	101 FT	IV	-5 to 107	Normal	20-80	3x10 ⁴ R	NA	
CV22117A Steam Isolation Bypass Solenoid Valve	M232	Outside Aux	101 FT	IV	-5 to 107	Normal	20-80	3x10 ⁴ R	NA	
CV22118 Steam Isolation Bypass Solenoid Valve	M232	Outside Aux	101 FT	IV	-5 to 107	Normal	20-80	3x10 ⁴ R	NA	
CV22119 Steam Isolation Bypass Solenoid Valve	M232	Outside Aux	101 FT	IV	-5 to 107	Normal	20-80	3x10 ⁴ R	NA	
CV22120 Steam Isolation Bypass Solenoid Valve	M232	Outside Aux	101 FT	IV	-5 to 107	Normal	20-80	3x10 ⁴ R	NA	
CV22121 Steam Isolation Bypass Solenoid Valve	M232	Outside Aux	101 FT	IV	-5 to 107	Normal	20-80	3x10 ⁴ R	NA	

TR011594-014

POOR ORIGINAL

333 535

ITEM NO.	DESCRIPTION	SPEC NO.	LOCATION	ENVIRONMENTAL SERVICE CONDITION	VENDOR DOCUMENTATION		CHEMICAL	METHOD OF QUALIFICATION AND REMARKS
					TEMP. (°F.)	PRESSURE (PSIA)		
OUTSIDE CONTAINMENT								
2.5106.1	A/F Manual Reset Pushbutton Station	F12	Main Structure Support Structure	59 ft. IV, VII	32-104	Normal	-	No information available other than the enclosure is Nema 3 with GE light and switch (CR29-0).
2.5106.2	A/F Manual Reset Pushbutton Station	F12	Main Structure Support Structure	59 ft. IV, VII	32-104	Normal	-	
2.5106.3	A/F Manual Reset Pushbutton Station	F12	Main Structure Support Structure	59 ft. IV, VII	32-104	Normal	-	
2.5106.4	A/F Manual Reset Pushbutton Station	F12	Main Structure Support Structure	59 ft. IV, VII	32-104	Normal	-	
2.5106.5	A/F Manual Reset Pushbutton Station	F12	Main Structure Support Structure	59 ft. IV, VII	32-104	Normal	-	
2.5106.6	A/F Manual Reset Pushbutton Station	F12	Main Structure Support Structure	59 ft. IV, VII	32-104	Normal	-	
2.5106.7	Stem Mounted Limit Switch	H209	Aux	93 ft. II	32-104	Normal	-	Statement of conformance by BIF complying with Trojan's Spec. H209. (These limit switches are Cutler-Hammer type LT 10316H).
2.5106.8	Stem Mounted Limit Switch	H209	Aux	93 ft. II	32-104	Normal	-	
2.5106.9	Stem Mounted Limit Switch	H209	Aux	93 ft. II	32-104	Normal	-	

TROJAN NUCLEAR PLANT

POOR ORIGINAL

655

533

TROJAN NUCLEAR PLANT
ENVIRONMENTAL QUALIFICATION REVIEW OF CLASS II ELECTRICAL EQUIPMENT

Page 48

OUTSIDE CONTAINMENT									
DESCRIPTION NO.	SPEC NO.	LOCATION BLDG.	ELEV.	ENVIRONMENTAL SERVICE CONDITION	VENDOR DOCUMENTATION TEMP. (°F)	PRESSURE (PSIA)	HUMIDITY	RADIATION	CHEMICAL
251782	Stem Mounted Limit Switch	H113	Aux	9 Ft	II	32-200	Normal	-	Statement of conformance by Rockwell complying with Trojan Specs. Hill H112 (These limit switches are hanco D2400X).
251784	Stem Mount Limit Swtch	H113	Aux	9 Ft	II	32-200	Normal	-	-
251785	Stem Mounted Limit Switch	H112	Main Sta Support Structure	77 Ft	IV, VII	32-200	Normal	-	-
251786	Stem Mounted Limit Switch	H112	Main Sta Support Structure	77 Ft	IV, VII	32-200	Normal	-	-
251787	Stem Mounted Limit Switch	H112	Main Sta Support Structure	77 Ft	IV, VII	32-200	Normal	-	-
251788	Stem Mounted Limit Switch	H112	Main Sta Support Structure	77 Ft	IV, VII	32-200	Normal	-	-
251789	Stem Mounted Limit Switch	H112	Main Sta Support Structure	93 Ft	IV, VII	32-200	Normal	-	-
251790	Stem Mounted Limit Switch	H112	Main Sta Support Structure	93 Ft	IV, VII	32-200	Normal	-	-
251791	Stem Mounted Limit Switch	H112	Main Sta Support Structure	93 Ft	IV, VII	32-200	Normal	-	-
251792	Stem Mounted Limit Switch	H112	Main Sta Support Structure	93 Ft	IV, VII	32-200	Normal	-	Statement of conformance by Ailis Chalmers complying with Trojan Specs. H208B2 (These limit switches are Mirco Switch QPD-AB).
251793	Stem Mounted Limit Switch	H208B2	Aux	45 Ft	II	32-104	Normal	-	-
251794	Stem Mounted Limit Switch	H208B2	Aux	45 Ft	II	32-104	Normal	-	-

L100174-014

POOR ORIGINAL

345
CCS

TROJAN NUCLEAR PLANT
ENVIRONMENTAL QUALIFICATION REVIEW OF CLASS 1E ELECTRICAL EQUIPMENT

EQUIP. NO.	DESCRIPTION	SPEC NO.	LOCATION	ENVIRONMENTAL SERVICE CONDITION	VENDOR DOCUMENTATION		CHEMICAL	METHOD OF QUALIFICATION AND REMARKS
					BLDG.	ELEV.		
Z-377-A	Stem Mounted Limit Switch	H20884	D.G. Area	45 Ft VI		32-75°	Normal	Statement of conformance by Fisher Controls complying with Trojan Spec. M20884. (These limit switches are Nema D2400X).
Z-377-B	Stem Mounted Limit Switch	H20884	D.G. Area	45 Ft VI		32-109	Normal	
Z-377-C	Stem Mounted Limit Switch	H20884	D.G. Area	45 Ft VI		32-200	Normal	
Z-377-D	Stem Mounted Limit Switch	H20884	Aux	48 Ft II		32-200	Normal	
Z-377-E	Stem Mounted Limit Switch	H20884	Aux	48 Ft II		32-200	Normal	
Z-377-F	Stem Mounted Limit Switch	H36	Yard Area	45 Ft Outside		32-200	Normal	
Z-377-G	Stem Mounted Limit Switch	H36	Yard Area	45 Ft Outside		32-200	Normal	
Z-377-H	Stem Mounted Limit Switch	H20884	D.G. Area	45 Ft VI		32-200	Normal	
Z-377-I	Stem Mounted Limit Switch	H20884	Intake St.	30 Ft II		32-200	Normal	
Z-377-J	Stem Mounted Limit Switch	H20884	Intake St.	30 Ft III		32-200	Normal	
Z-377-K	Stem Mounted Limit Switch	H12A	Aux	45 Ft II		32-200	Normal	
Z-377-L	Stem Mounted Limit Switch	H12B	Outside Aux	45 Ft II		32-104	Normal	
Z-377-M	Stem Mounted Limit Switch	H12B	MSSS	45 Ft IV, VII		32-104	Normal	Statement of conformance by Anchor Val Co. complying with Trojan Spec. M138. (These limit switches are Micro Switch OTY2-BN).
Z-377-N	Stem Mounted Limit Switch	H12A	MSSS	61 Ft IV, VII		32-200	Normal	See 251782.

T1061791 014

POOR ORIGINAL

THORNTON NUCLEAR PLANT
ENVIRONMENTAL QUALIFICATION REVIEW OF CLASS 1E ELECTRICAL EQUIPMENT

Page 50

<u>OUTSIDE CONTAINMENT</u>									
ITEM	DESCRIPTION NO.	SPEC NO.	LOCATION BLDG. ELEV.	ENVIRONMENTAL SERVICE CONDITION	VENDOR DOCUMENTATION		HUMIDITY %	RADIATION	CHEMICAL
					TEMP. (°F)	PRESSURE (PSIA)			
2501013	Stem Mounted Limit Switch	H112	MSS	61 Ft IV, VII	32-200	Normal	-	-	See 2S1782.
2501013	Stem Mounted Limit Switch	H138	Aux	45 Ft II	32-104	Normal	-	-	See 2S4181.
2501016	Stem Mounted Limit Switch	H138	Aux	45 Ft II	32-104	Normal	-	-	See 2S4181.
2501014	Stem Mounted Limit Switch	H113	Cable Penetration Area	45 Ft IV	32-200	Normal	-	-	See 2S1782.
2501014	Stem Mounted Limit Switch	H113	Cable Penetration Area	45 Ft IV	32-200	Normal	-	-	See 2S1782.
2501015	Stem Mounted Limit Switch	H113	Cable Penetration Area	45 Ft IV	32-200	Normal	-	-	See 2S1782.
2501019	Stem Mounted Limit Switch	H113	Cable Penetration Area	45 Ft IV	32-200	Normal	-	-	See 2S1782.
2501018	Stem Mounted Limit Switch	H113	Cable Penetration Area	45 Ft IV	32-200	Normal	-	-	See 2S1782.
2501025	Stem Mounted Limit Switch	M18	Cable Penetration Area	45 Ft IV	32-200	Normal	100	2x10 ⁶ R	Qualified by Type Test in Hanco test report dated March 17, 1978 (Hanco EA110).
2501023	Stem Mounted Limit Switch	M18	Aux	63 Ft II	32-200	Normal	100	2x10 ⁶ R	Qualified by Type Test in Hanco test report dated March 17, 1978 (Hanco EA110).
2501023	Stem Mounted Limit Switch	M18	Aux	56 Ft II	32-200	Normal	100	2x10 ⁶ R	Same as above
2501015	Stem Mounted Limit Switch	M18	Aux	63 Ft II	32-200	Normal	100	2x10 ⁶ R	See 2S8025.

71001191-01V

POOR ORIGINAL

245
533

INDIAN NUCLEAR PLANT
ENVIRONMENTAL QUALIFICATION REVIEW OF CLASS I E ELECTRICAL EQUIPMENT

Page 51

OUTSIDE CONTAINMENT

ITEM	DESCRIPTION	BLDG. NO.	LOCATION	ENVIRONMENTAL LEVEL	SERVICE CONDITION	VENDOR DOCUMENTATION			METHOD OF QUALIFICATION	REMARKS
						TEMP. (°F)	HUMIDITY (PSIA)	RADIATION		
21-3708-A	Stem Mounted Limit Switch	M13	Aux	25 Ft	II	32-200	Normal	-	-	Statement of Conformance by Naaco complying with W Spec.
21-3708-B	Stem Mounted Limit Switch	M18	Aux	25 Ft	II	32-200	Normal	-	-	Same as above.
21-3708-C	Stem Mounted Limit Switch	M18	Aux	59 Ft	II	32-200	Normal	-	-	Same as above.
21-3708-D	Stem Mounted Limit Switch	M18	Aux	25 Ft	II	32-200	Normal	-	-	Same as above.
21-3708-E	Stem Mounted Limit Switch	M18	Aux	45 Ft	II	32-200	Normal	-	-	Same as above.
21-3708-F	Stem Mounted Limit Switch	M208B2	Aux	63 Ft	II	32-200	Normal	-	-	See CV303.
21-3708-G	Stem Mounted Limit Switch	M208E	Aux	63 Ft	II	32-200	Normal	-	-	See CV303.
21-3708-H	Stem Mounted Limit Switch	M18	Aux	11	32-200	Normal	100	2×10^6 R	-	Qualified by type test in Naaco test report dated March 17, 1978 (Naaco EAI10).
21-3708-I	Stem Mounted Limit Switch	M18	Aux	11	32-200	Normal	100	2×10^6 R	-	Qualified by type test in Naaco test report dated March 17, 1978 (Naaco EAI10).

343 533

POOR ORIGINAL

T1-1741-014

THOMAS HANFORD PLANT REVIEW OF CLASS IIE ELECTRICAL EQUIPMENT

Page 52

ENVIRONMENTAL QUALIFICATION TESTS	DESCRIPTION	SPEC NO.	LOCATION	BLDG. ELEV.	ENVIRONMENTAL SERVICE CONDITION		VENDOR DOCUMENTATION	TEMP. (°F)	PRESSURE (PSIA)	HUMIDITY %	RADIATION	CHEMICAL	METHOD OF QUALIFICATION AND REMARKS
					TEST	TEST							
OUTSIDE CONTAINMENT	Inverter #1	H1	Control	65 ft	III	III	32-104	Normal	-	Normal	NA	NA	Qualified by operating experience based upon industry test. This equipment meets the requirement of ANSI C37.11. Test results for this equipment are kept by the manufacturer, W.
	Inverter #2	H1	Control	65 ft	III	III	32-104	Normal	-	Normal	NA	NA	Qualified by operating experience based upon industry test. This equipment meets the requirement of NEMA Std. PB-1 and UL-67. Test results for this standard equipment are kept by the manufacturer, W.
	Inverter #3	H1	Control	65 ft	III	III	32-104	Normal	-	Normal	NA	NA	Qualified by operating experience based upon industry test. This equipment meets the requirement of NEMA Std. PB-1 and UL-67. Test results for this standard equipment are kept by the manufacturer, W.
	Inverter #4	H1	Control	65 ft	III	III	32-104	Normal	-	Normal	NA	NA	Qualified by operating experience based upon industry test. This equipment meets the requirement of NEMA Std. PB-1 and UL-67. Test results for this standard equipment are kept by the manufacturer, W.
	Preferred AC Bus	H1	Control	65 ft	III	III	32-104	Normal	-	Normal	NA	NA	Qualified by operating experience based upon industry test. This equipment meets the requirement of NEMA Std. PB-1 and UL-67. Test results for this standard equipment are kept by the manufacturer, W.
	Preferred AC Bus	H1	Control	65 ft	III	III	32-104	Normal	-	Normal	NA	NA	Qualified by operating experience based upon industry test. This equipment meets the requirement of NEMA Std. PB-1 and UL-67. Test results for this standard equipment are kept by the manufacturer, W.
	Preferred AC Bus	H1	Control	65 ft	III	III	32-104	Normal	-	Normal	NA	NA	Qualified by operating experience based upon industry test. This equipment meets the requirement of NEMA Std. PB-1 and UL-67. Test results for this standard equipment are kept by the manufacturer, W.
	NIS Regulator	H1	Control	65 ft	III	III	32-104	Normal	-	Normal	NA	NA	Qualified by operating experience based upon industry test. This equipment was designed and tested to NEMA Std. T&I-1968.
	NIS Regulator	H1	Control	65 ft	III	III	32-104	Normal	-	Normal	NA	NA	Qualified by operating experience based upon industry test. This equipment was designed and tested to NEMA Std. T&I-1968.
	NIS Regulator	H1	Control	65 ft	III	III	32-104	Normal	-	Normal	NA	NA	Qualified by operating experience based upon industry test. This equipment was designed and tested to NEMA Std. T&I-1968.
	Rotor Trip Switchgear	H1	Control	65 ft	III	III	32-104	Normal	-	Normal	NA	NA	Qualified by operating experience based upon industry test. This equipment was designed and tested to ANSI C37 and ANSI 39.1.
	Post LOCA Containment Hydrogen Analysis	H87	Aux	55 ft	II	II	32-104	Normal	-	Normal	NA	NA	Qualified by operating experience based upon industry test. This equipment was designed and tested to NEMA ICS and ANSI 39.1.

POOR ORIGINAL

TUOIS94-0

355

**TROJAN NUCLEAR PLANT
ENVIRONMENTAL QUALIFICATION REVIEW OF CLASS I¹E ELECTRICAL EQUIPMENT**

OUTSIDE CONTAINMENT									
TEST NUMBER	DESCRIPTION	EC NO.	LOCATION	ENVIRONMENTAL	ENVIRONMENTAL	VENDOR DOCUMENTATION	PRESSURE	HUMIDITY	METHOD OF QUALIFICATION AND REMARKS
			BLDG. ELEV.	SERVICE CONDITION	(PSIA)	TEMP. (°F)	T	RADIATION	CHEMICAL
C-1A,B,C & D	Nuclear Inst. System Panel	HI	Control	93 ft	Y	60-120	Normal	15-95	NA
C-1A,A',B', A',B',C', & D'	Process I&C Protection Panels	HI	Control	93 ft	Y	60-120	Normal	15-95	NA
C-1B,C',D', A',B',C', & D'	Process I&C Control Panels	HI	Control	93 ft	Y	60-120	Normal	15-95	NA
C-1B,C',D', A',B',C', & D'	Process I&C Control Panels	HI	Control	93 ft	Y	60-120	Normal	15-95	NA
C-1B,C',D', A',B',C', & D'	Process I&C Control Panels	HI	Control	93 ft	Y	60-120	Normal	15-95	NA
C-1B,C',D', A',B',C', & D'	Process I&C Control Panels	HI	Control	93 ft	Y	60-120	Normal	15-95	NA
C-1B,C',D', A',B',C', & D'	Process I&C Control Panels	HI	Control	93 ft	Y	60-120	Normal	15-95	NA
C-1B,C',D', A',B',C', & D'	Process I&C Control Panels	HI	Control	93 ft	Y	60-120	Normal	15-95	NA
C-1B,C',D', A',B',C', & D'	Process I&C Control Panels	HI	Control	93 ft	Y	60-120	Normal	15-95	NA
C-1B,C',D', A',B',C', & D'	Process I&C Control Panels	HI	Control	93 ft	Y	60-120	Normal	15-95	NA
C-1B,C',D', A',B',C', & D'	Protection System Test Panels	HI	Control	93 ft	Y	20-120	Normal	15-95	NA
C-1B,C',D', A',B',C', & D'	Auxiliary Safe- guard Panels	HI	Control	93 ft	Y	20-120	Normal	15-95	NA
C-1B,C',D', A',B',C', & D'	Solid State Protection System Cabinet	HI	Control	93 ft	Y	20-120	Normal	15-95	NA
C-1B,C',D', A',B',C', & D'	Solid State Protection System Cabinet	HI	Control	93 ft	Y	20-120	Normal	15-95	NA

191

POOR ORIGINAL

ENVIRONMENTAL QUALIFICATION REVIEW OF TROJAN ELECTRICAL EQUIPMENT

OUTSIDE CONTAINMENT							METHOD OF QUALIFICATION AND RANKS		
ITEM NO.	DESCRIPTION	SPEC NO.	LOCATION BLDG.	ENVIRONMENTAL ELEV.	SERVICE CONDITION	VENDOR DOCUMENTATION PRESSURE (PSIA)	HUMIDITY	RADIATION	CHEMICAL
							%	NA	NA
1.0/1.4.3	Point LOCA Hydrogen Recombiner Fancie	No.7	Control	93 ft	V	40-120	Normal	15-95	Normal
1.0/1.4.4	Radiation Monitoring Panel	P-240	Control	93 ft	V	40-104	Normal	15-95	Normal
1.0/1.4.5	Diesel Generator Control Panel	Hi6	Turbine	45 ft	VI	40-104	Normal	-	Water Spray
1.0/1.4.6	Diesel Generators	Hi6	Turbine	45 ft	VI	40-120	Normal	-	Water Spray
1.0/1.7.1	Diesel Generator Cables	Hi6	Turbine	45 ft	VI	40-104	Normal	-	Water Spray
1.0/1.7.2	Diesel Generator Field Terminals	Hi6	Turbine	45 ft	VI	40-104	Normal	-	Water Spray

TODAY

POOR ORIGINAL

533

THILO MUNICIPAL PLANT
ENVIRONMENTAL QUALIFICATION REVIEW OF CLASS II ELECTRICAL EQUIPMENT

Page 55

OUTSIDE CONTAINMENT									
DESCRIPTION	SPEC NO.	LOCATION	ENVIRONMENTAL SERVICE CONDITION	VENTILATION	TEMP. (°F)	PRESSURE (PSIA)	HUMIDITY	RADIATION	CHEMICAL
Q1010301 Neutral Grounding Resistor	H16	Turbine	45 ft	VI	40-104	Normal	Normal	Normal	Water Spray
Q1010302 Diesel Generator Air Compressor	H16	Turbine	45 ft	VI	40-120	Normal	Normal	Normal	Water Spray
Wiring ^a	H16	Turbine	45 ft	VI	150	Normal	Normal	Normal	Water Spray
A/C Diesel Battery Charger	H12	Turbine	45 ft	VI	0-120	Normal	Normal	Normal	NA
A/C Diesel Batteries	H12	Turbine	45 ft	VI	50-104	Normal	Normal	Normal	NA
Q1010301 A/C Diesel Control Box & Governor (Woodward Governor)	H12	Turbine	45 ft	VI	50-150	Normal	Normal	Normal	NA
A/C Turbine Trip Contactor	H12	Turbine	45 ft	VI	40-104	Normal	Normal	Normal	NA
A/C Turbine Trip Box (Woodward Governor)	H12	Turbine	45 ft	VI	50-150	Normal	Normal	Normal	NA
Wiring on A/C Diesel Driven Pump	H12	Turbine	45 ft	VI	194	Normal	Normal	Normal	NA

TURBO 17000 V

POOR ORIGINAL

347

225

METHOD OF QUALIFICATION AND PHASES

Same as above. This device is housed on NEMA 4 enclosure for water protection.

Qualified by operating experience based on industry tests. This equipment was tested per requirement of NEMA MG-1. This motor has Class S insulation which has 130°C maximum temperature and is total enclosed enclosures.

This equipment was tested and designed to IEC 6-1981. This wiring has insulation temperature rating of 150°C (302°F).

Qualified by operating experience based on industry tests. This equipment was tested per requirements of NEMA Std. R12-1976. (La Marche Model A51).

This enclosure is a REHA 4 enclosure that protects the equipment from water and snow external condensation. The equipment is Woodward Governor Model 2301 that is designed and tested to IEC 606 and NEMA Std. ICS.

Same as above.

Same as BTR/01

This wiring type TA with insulation temperature rating of 90°C (194°F) in accordance with National Electric Code and was tested to IEC 6-1981.

LIST OF SAFETY-RELATED EQUIPMENT BELOW THE
MAXIMUM WATER LEVEL (52'-11-1/2")
IN CONTAINMENT FOLLOWING A LOCA

Reference: Trojan FSAR Section 15.4.1.6

<u>Item No.</u>	<u>Equipment No.</u>	<u>Elevation</u>	<u>Description</u>
1	FT512, FT513, FT522, FT523, FT532, FT533, FT542, FT543	50'	Steam Generator Flow Transmitters
2	PT403, PT405	48'	RCS Wide Range Pressure Transmitter
3	LT517, LT518, LT519, LT527, LT528, LT529, LT537, LT538, LT539, LT547, LT548, LT549	48'	Steam Generator Level Transmitter
4	FT414, FT415, FT416, FT424, FT425, FT426, FT434, FT435, FT436, FT444, FT445, FT446	49'	Reactor Coolant Loop Flow Transmitter
5	M01605	45'-6"	Condensate Drain Tank Valve
6	M0400J	44'-7"	Reactor Coolant Drain Tank Valve
7	M04180	49'-6"	Containment Sump Discharge Valve
8	M08808A, M08808B, M08808C, M08808D	52'-6"	Accumulator Tank Isolation Valve
9	CV8153	48'-5"	Letdown Isolation Valve
10	CV8154	47-6"	Letdown Isolation Valve
11	CV8876A, CV8876B, CV8876C, CV8876D	47'	Accumulator Tank to RCDT Valve
12	CV8877A	49'	Safety Injection Test Line Valve
13	CV8877B, CV8877C, CV8877D	50'	Safety Injection Test Line Valve
14	CV8879A, CV8879B, CV8879C, CV8879D	49'	Accumulator System Valve

Poor Original

<u>Item No.</u>	<u>Equipment No.</u>	<u>Elevation</u>	<u>Description</u>
15(1)	DIC901	52'-5"	Instrumentation Cable Tray
16(?)	CIC901	52'-5"	Instrumentation Cable Tray

-
- (1) Cable tray DIC901 contains cables associated with RCS pressure (PT403), RCS Loop 4 hot and cold leg temperature (TE441A, B and TE440A, B), pressurizer pressure (PT458), steam generator loop level (LT517, LT527, LT537, LT547), and pressurizer relief valve discharge temperature (TE465).
- (2) Cable tray CIC901 contains cable associated with RCS loop flow (FT416, FT426, FT436, FT446), RCS Loop 3 hot and cold leg temperature (TE430A, B and TE431A, B), pressurizer vapor pressure (PT457), pressurizer level (LT461), steam generator loop levels (LT518, LT528, LT538, LT548), and pressurizer relief valve discharge temperature (TE464).

533 349

POOR ORIGINAL