

JUL 16 1979

DISTRIBUTION:

Dockets  
NRR Rdg  
EPT Rdg  
ESB Rdg  
DMuller  
WRegan  
DEisenhut  
WGammill  
RBevan  
RSamworth  
TCain  
GLear

Docket Nos. 50-254  
and 50-265

REGULATORY DOCKET

MEMORANDUM FOR: Thomas A. Ippolito, Chief  
Operating Reactors Branch 3, DOR

FROM: George Lear, Chief  
Environmental Specialists Branch, DSE

SUBJECT: PROPOSED CHANGES TO ENVIRONMENTAL TECHNICAL SPECIFICATIONS  
(ETS) FOR QUAD-CITIES (TAC 7799)

PLANT NAME: Quad-Cities Station, Units 1 and 2  
RESPONSIBLE BRANCHES: ORB #3, ESB  
PROJECT MANAGER: R. Bevan  
REVIEW STATUS: Complete

By letter dated February 2, 1978, Commonwealth Edison requested changes to Appendix B, Environmental Technical Specifications, to the Quad-Cities Station licenses. The proposed change would eliminate the 20F per hour temperature change limit during changes in the mode of condenser cooling.

We have reviewed the licensee's submittal, the Quad-Cities Station FES, the semi-annual operating reports and the NPDES permit requirements. We find that the licensee's proposed change is justified and no significant environmental impact will occur from this change. An Environmental Impact Appraisal (EIA) is enclosed to support a Negative Declaration for this action.

We also note that the licensee submits semi-annual operating reports. We now require only an annual report for new plants. Most existing ETS reporting requirements have been changed from semi-annual to annual. We recommend that this be done for the Quad-Cities Station as an administrative action.

Original Signed by Jerry D. Kline

George Lear, Chief  
Environmental Specialists Branch  
Division of Site Safety and  
Environmental Analysis

606158

Enclosure:

OFFICE	EIA	DSE:EPT:ESB	DSE:EPT:ESB	DSE:EPT:ESB	
BY NAME	Contact: T. Cain	TCain:ws	RSamworth	GLear	
DATE	X27903	7/16/79	7/16/79	7/16/79	

7908100124