

TSC

NORTHEAST UTILITIES



THE CONNECTICUT LIGHT AND POWER COMPANY
THE HARTFORD ELECTRIC LIGHT COMPANY
WESTERN MASSACHUSETTS ELECTRIC COMPANY
HOLYOKE WATER POWER COMPANY
NORTHEAST UTILITIES SERVICE COMPANY
NORTHEAST NUCLEAR ENERGY COMPANY

P.O. BOX 270
HARTFORD, CONNECTICUT 06101
(203) 666-6911

Docket No. 50-245

Mr. Boyce H. Grier
Director, Region I
Office of Inspection and Enforcement
U. S. Nuclear Regulatory Commission
King of Prussia, Pennsylvania 19406

Reference: (1) Boyce Grier letter to W. G. Council dated May 22,
1979, forwarding I & E Bulletin 79-11.

Gentlemen:

Millstone Nuclear Power Station, Unit No. 1
Faulty Overcurrent Trip Device In Circuit Breakers
For Engineered Safety Systems

In reference (1), Northeast Nuclear Energy Company (NNECo) was
requested to determine whether Westinghouse type DB-50 and DB-75 circuit
breakers with overcurrent trip devices are in safety related class IE
service or in spares at this facility.

In response to Item 1 of the bulletin, Westinghouse type DB-50 and DB-75
circuit breakers are not used in safety related class IE service at this
facility. Additionally, there are no Westinghouse type DB-50 and DB-75
circuit breakers in spares or intended for use in safety related class
IE service at Millstone Unit 1.

Very truly yours,

NORTHEAST NUCLEAR ENERGY COMPANY

W. G. Council
Vice President

626 339

7908130046