

LICENSEE EVENT REPORT

CONTROL BLOCK: [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] [] (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0	1	G	A	E	I	H	2	0	0	0	0	0	0	0	0	0	0	0	0	4	1	1	1	1	4	1	5				
LICENSEE CODE								LICENSE NUMBER																	LICENSE TYPE					CAT	

0	1	1	0	5	0	0	0	3	6	6	7	0	1	7	2	5	7	1	9	8	0	8	0	3	7	9	9
REPORT SOURCE			DOCKET NUMBER								EVENT DATE								REPORT DATE								

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 | While attempting to place the reactor building chillers in parallel for a special

03 | test at a steady state power level of 72%, the volumetric average drywell temperature

04 | exceeded its limit of 1350F as specified in Tech Specs Sect. 3.6.1.7. This is a

05 | repetitive problem as noted in LERs 78-06, 78-09, 79-48, and 79-80.

06 |

07 |

08 |

0	9	A	A	A	X	Z	Z	Z	Z	Z	Z	Z	Z	Z	Z	Z	Z	Z	Z	Z	Z	Z	Z	Z	Z	Z	Z
SYSTEM CODE			CAUSE CODE		CAUSE SUBCODE		COMPONENT CODE										COMP. SUBCODE		VALVE SUBCODE								

17	7	9	0	8	1	0	8	L	0
LER/RO REPORT NUMBER	EVENT YEAR		SHUTDOWN METHOD	SEQUENTIAL REPORT NO.		OCCURRENCE CODE		REPORT TYPE	REVISION NO.

X	X	Z	Z	0	0	0	0	Y	N	Z	Z	Z	Z
ACTION TAKEN		EFFECT ON PLANT		SHUTDOWN METHOD		HOURS		ATTACHMENT SUBMITTED	NPRD-4 FORM SUB.	PRIME COMP. SUPPLIER		COMPONENT MANUFACTURER	

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 | The drywell temperature was reduced below 1350F within 8 hours by returning the

11 | chilled water system to its normal operation upon completion of the special test.

12 | Within 2 hours of the deviation, the drywell temperature was reduced below 1350F

13 | while both chillers were operating during the special test. A safety evaluation was

14 | performed and the Tech Spec limit has been changed (continued)

1	5	E	0	7	2	N/A	A	Operator Observation			
FACILITY STATUS			% POWER			OTHER STATUS	METHOD OF DISCOVERY		DISCOVERY DESCRIPTION		

1	6	Z	Z	N/A	N/A
ACTIVITY CONTENT RELEASED		AMOUNT OF ACTIVITY		LOCATION OF RELEASE	

1	7	0	0	Z	N/A
PERSONNEL EXPOSURES		DESCRIPTION			

1	1	0	0	N/A
PERSONNEL INJURIES		DESCRIPTION		

1	2	Z	N/A
LOSS OF OR DAMAGE TO FACILITY		DESCRIPTION	

1	3	N	N/A	7	9	0	8	1	3	0	3	4	5
ISSUE DESCRIPTION		PRIORITY		NRC USE ONLY									

NAME OF PREPARED: C. L. Coggin, Supt. Pft. Eng. Serv. PHONE: 912-367-7781

555138

7 908 130 345

Georgia Power Company
Plant E. I. Hatch
Baxley, Georgia 31513

Cause Description and Corrective Actions (continued)

from 135°F to 145°F until permanent modifications can be made. The unit is now at full power and the temperatures have stabilized well below the new T.S. limit.

555139