

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50-312

UNIT Rancho Seco Unit 1

DATE 79-06-30

COMPLETED BY R. W. Colombo

TELEPHONE (916) 452-3211

MONTH July

DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)
1	0
2	0
3	0
4	0
5	88
6	532
7	819
8	866
9	867
10	867
11	867
12	620
13	613
14	715
15	857
16	860

DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)
17	861
18	862
19	859
20	727
21	0
22	0
23	467
24	852
25	860
26	866
27	868
28	865
29	869
30	856
31	856

INSTRUCTIONS

On this format, list the average daily unit power level in MWe-Net for each day in the reporting month. Compute to the nearest whole megawatt.

7908140482

(9/77)

626 128

OPERATING DATA REPORT

DOCKET NO. 50-312
 DATE 79-07-31
 COMPLETED BY R. W. Colombo
 TELEPHONE 916-452-3211

OPERATING STATUS

1. Unit Name: Rancho Seco Unit
2. Reporting Period: July 1979
3. Licensed Thermal Power (MWt): 2772
4. Nameplate Rating (Gross MWe): 963
5. Design Electrical Rating (Net MWe): 918
6. Maximum Dependable Capacity (Gross MWe): 917
7. Maximum Dependable Capacity (Net MWe): 873
8. If Changes Occur in Capacity Ratings (Items Number 3 Through 7) Since Last Report, Give Reasons:
N/A

Notes

Shut down July 20 for approximately 54 hours to modify several pipe supports to the criteria in I&E Bulletin 79-02.

9. Power Level To Which Restricted, If Any (Net MWe): N/A
10. Reasons For Restrictions, If Any: N/A

	This Month	Yr.-to-Date	Cumulative
11. Hours In Reporting Period	<u>744</u>	<u>5087</u>	<u>37584</u>
12. Number Of Hours Reactor Was Critical	<u>601.9</u>	<u>3399.4</u>	<u>22470.2</u>
13. Reactor Reserve Shutdown Hours	<u>0</u>	<u>1519.2</u>	<u>3915.6</u>
14. Hours Generator On-Line	<u>573.8</u>	<u>3277.5</u>	<u>21440.7</u>
15. Unit Reserve Shutdown Hours	<u>13.8</u>	<u>1199.3</u>	<u>1210.2</u>
16. Gross Thermal Energy Generated (MWH)	<u>1,546,232</u>	<u>8,961,925</u>	<u>54,035,081</u>
17. Gross Electrical Energy Generated (MWH)	<u>480,799</u>	<u>2,932,120</u>	<u>18,194,920</u>
18. Net Electrical Energy Generated (MWH)	<u>450,527</u>	<u>2,780,155</u>	<u>17,179,045</u>
19. Unit Service Factor	<u>77.1</u>	<u>64.4</u>	<u>57.0</u>
20. Unit Availability Factor	<u>79.0</u>	<u>88.0</u>	<u>60.3</u>
21. Unit Capacity Factor (Using MDC Net)	<u>69.4</u>	<u>62.6</u>	<u>52.4</u>
22. Unit Capacity Factor (Using DER Net)	<u>66.0</u>	<u>59.5</u>	<u>49.8</u>
23. Unit Forced Outage Rate	<u>21.4</u>	<u>7.1</u>	<u>35.1</u>
24. Shutdowns Scheduled Over Next 6 Months (Type, Date, and Duration of Each): <u>None</u>			

25. If Shut Down At End Of Report Period, Estimated Date of Startup: N/A

	Forecast	Achieved
INITIAL CRITICALITY	<u>N/A</u>	<u>N/A</u>
INITIAL ELECTRICITY	<u>N/A</u>	<u>N/A</u>
COMMERCIAL OPERATION	<u>N/A</u>	<u>N/A</u>

626 129

UNIT SHUTDOWNS AND POWER REDUCTIONS

DOCKET NO. 50-312
 UNIT NAME Ryncho Seco Unit 1
 DATE 79-07-31
 COMPLETED BY R. W. Colombo
 TELEPHONE (916) 452-3211

REPORT MONTH: July

No.	Date	Type ¹	Duration (Hours)	Reason ²	Method of Shutting Down Reactor ³	Licensee Event Report #	System Code ⁴	Component Code ⁵	Cause & Corrective Action to Prevent Recurrence
7	79-07-01	S	13.8	F	1	N/A	N/A	N/A	Continuation of last month's "Prerequisite testing of AFW and plant heatup in preparation for startup."
8	79-07-01	F	97.6	B	3	N/A	N/A	N/A	Rx trip due to high pressure resulting from STP-070 (Aux. Feedwater Flow Test). Repaired weld on Aux. System Line and performed other maintenance.
9	79-07-12	F	5.0	A	3	N/A	N/A	N/A	Rx trip due to pressure transmitter malfunction which was equated to turbine overspeed.
10	79-07-20	F	53.8	F	1	79-007/01-T-0	CF	SUPPORT	Pipe supports having safety factor of <2 according to I.E. Bulletin 79-02 analysis.

¹
 F: Forced
 S: Scheduled

²
 Reason:
 A-Equipment Failure (Explain)
 B-Maintenance of Test
 C-Refueling
 D-Regulatory Restriction
 E-Operator Training & License Examination
 F-Administrative
 G-Operational Error (Explain)
 H-Other (Explain)

³
 Method:
 1-Manual
 2-Manual Scram.
 3-Automatic Scram.
 4-Other (Explain)

⁴
 Exhibit G - Instructions for Preparation of Data Entry Sheets for Licensee Event Report (LER) File (NUREG-0161)

⁵
 Exhibit I - Same Source

(9/77)

626 130

NARRATIVE SUMMARY OF PLANT OPERATIONS

DATE

7/1/79

- (0000) Reactor at 15% Full Power
- (0855) Lowered reactor to 13% power
- (1348) Reactor tripped (high pressure)

7/4/79

- (1030) Reactor in heatup mode

7/5/79

- (0730) Reactor critical
- (0750) Reactor at 2.5% power
- (1239) Completed STP-070, "Aux. Feedwater Flow Test"
- (1500) Reactor at 15% FP
- (1525) Generator on line (closed OCB's)
- (2340) Reactor at 50% power increasing to 70% (420 MWe)

7/6/79

- (1126) Reactor at 70% power, commenced 5-hour hold
- (1600) Increasing to 92% power

7/7/79

- (1738) Started increasing to 100% power
- (1946) Unit at 100%

7/8/79

- (0530) Completed Auxiliary Feedwater Pump P-319 portion of STP-071, Auxiliary Feedwater Endurance Test

7/10/79

- (1235) Completed Auxiliary Feedwater Pump P-318 portion of STP-071, Auxiliary Feedwater Endurance Test

7/12/79

- (1717) Reactor trip on turbine-generator trip
- (1909) Reactor critical
- (2216) Generator on line (Closed OCB's)

626-131

7/13/79

- (2400) Reactor at 32% power
- (0115) Started increasing reactor to 50% power
- (0255) Reactor at 50%
- (0712) Increasing reactor to 92% power
- (1230) Reactor at 90%, commenced 2-hour hold
- (1510) Started increasing to 100% power
- (2115) Reactor at 100% power

7/14/79

- (1740) Overspeed Protection Control failed. All intercept valves closed. Lowered reactor power to 30%. Took manual control of turbine
- (2205) Increasing to 92% power

7/15/79

- (0000) Reactor at 87% commenced 2-hour hold
- (0159) Reactor at 100% power

7/20/79

- (1615) Started reactor power decrease at 1 MW/minute
- (2210) Transferred aux. trans. loads to SU transformers
- (2245) Opened OCB's 220/230
- (2247) Pushed Turbine trip button
- (2320) Reactor in HSD

7/23/79

- (0117) Reactor critical
- (0431) Generator on line (closed OCB's)
- (0542) Reactor at 50% power
- (0650) Started increasing to 72% power
- (1510) Started increasing to 92% power

626 132

7/23/79 (Continued)

- (1805) Reactor at 87% power commenced 2-hour hold
(2107) Reactor at 100% power

PERSONNEL CHANGES REQUIRING REPORTING

No personnel changes that require reporting in accordance with Technical Specifications Figure 6.9-2 were made in July, 1979.

MAJOR ITEMS OF SAFETY-RELATED MAINTENANCE

- 1) Conducted inspection test of all pipe support anchors in Class 1 systems. Made modifications to those anchors that did not meet the new criteria covered in Bulletin 79-02. Reference: LER 79-07.
- 2) Replaced "B" Decay Heat Pump (P-261B) outboard seal. Reference: LER 79-08.

SUMMARY OF CHANGES MADE IN ACCORDANCE WITH 10 CFR 50.59(b)

No changes, tests, or experiments were completed in July, 1979, which constituted a change in a safety analysis report description.

626 133

REFUELING INFORMATION REQUEST

1. Name of Facility: Rancho Seco Unit 1
2. Scheduled date for next refueling shutdown: February 1980
3. Scheduled date for restart following refueling: April 1980
4. Technical Specification change or other license amendment required:
 - a) Change to Rod Index vs. Power Level Curve (TS 3.5.2)
 - b) Change to Core Imbalance vs. Power Level Curve (TS 3.5.2)
 - c) Tilt Limits (TS 3.5.2)
 - d) Safety Equipment Testing (TS 3.3.3)
5. Scheduled date(s) for submitting proposed licensing action: December 1979
6. Important licensing considerations associated with refueling: None
7. Number of fuel assemblies:
 - a) In the core: 177
 - b) In the Spent Fuel Pool: 112*
8. Present licensed spent fuel capacity: 579
9. Projected date of the last refueling that can be discharged to the Spent Fuel Pool: 1987

*Previous reports of 122 were in error.