



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

PDR

JUL 13 1979

Docket Nos.: 50-424
50-425

Mr. W. E. Ehrensperger
Senior Vice President
Power Supply
Georgia Power Company
P. O. Box 4545
Atlanta, Georgia 30302

Dear Mr. Ehrensperger:

SUBJECT: SPECIFICATIONS FOR CONCRETE IN THE VOGTLE FACILITY

In response to your letter of May 11, 1979 to Mr. Roger Boyd, we have determined that your clarification for the use of pozzolan concrete mixes for Category I structures is acceptable. These specifications meet the requirements for ANSI N45.2.5 as modified for 91-day strength and also meet the applicable requirements of ACI 349 and ACI 359 codes. We request that you amend the PSAR to show this clarification as augmented by the Regulatory Guides 1.136 and 1.142 respectively.

Please call if you have any questions.

Sincerely,

A handwritten signature in dark ink, reading "L. S. Rubenstein".

L. S. Rubenstein, Acting Chief
Light Water Reactors Branch No. 4
Division of Project Management

cc: See next page

626 291

7908140

495

B

Georgia Power Company

ccs:

Mr. I. S. Mitchell, III
Vice President and Secretary
Georgia Power Company
P. O. Box 4545
Atlanta, Georgia 30302

Mr. Ruble A. Thomas
Vice President
Southern Services, Inc.
P. O. Box 2625
Birmingham, Alabama 35202

Mr. J. A. Bailly
Project Licensing Manager
Southern Company Services, Inc.
P. O. Box 2625
Birmingham, Alabama 35202

George F. Trowbridge, Esq.
Shaw, Pittman, Potts and Trowbridge
1800 M Street, N. W.
Washington, D. C. 20036

626 292