



KERR-MCGEE

KERR-MCGEE CENTER • OKLAHOMA CITY, OKLAHOMA 73125

July 5, 1979

CERTIFIED MAIL -
RETURN RECEIPT REQUESTED

Ms. Adelene Harrison
Regional Administrator
U.S. Environmental Protection Agency
Region VI
First International Bank Building
1201 Elm Street
Dallas, Texas 75270

Subject: Noncompliance under NPDES Permit
No. OK0000191, 002 Outfall

Dear Ms. Harrison:

Please refer to the subject permit and its attached requirements. Part 2, subparagraph A requires notification within five days of a noncompliant condition on any daily maximum effluent limitation specified.

Accordingly, we notify you that a pH value of 9.2 was recorded for a grab sample taken at 1530 hours on 6/29/79. As an earlier grab sample taken at 0630 hours showed a pH value of 7.1, this unexplained pH increase is currently being investigated.

Should you require additional information, please let us know.

Sincerely,


W.J. Shelley, Director

WJS:maw

cc: Jim Barnett, OWRB
C. Grosclaude
D. Swaney
J.W. Craig
Burnell Brown
JMC
ALD
ml

626 305

13458

7908140 507 C