

# LICENSEE EVENT REPORT

CONTROL BLOCK: | | | | | | | | | | | (1)

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 | I L Z I S 1 | 2 0 0 - 0 0 0 0 0 0 - 0 0 | 3 4 1 1 1 1 | 4 | 5  
7 8 9 14 15 25 26 30 37 CAT 38  
LICENSEE CODE LICENSE NUMBER LICENSE TYPE CAT  
 CONT  
 0 1 | L | 6 0 5 0 0 0 2 9 5 | 7 0 7 0 2 7 9 | 8 0 7 2 4 7 9 | 9  
7 8 60 61 64 65 69 74 75 80 81  
REPORT SOURCE DOCKET NUMBER EVENT DATE REPORT DATE

### EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | During a check source test the check source and indicator needle of Aux.  
 0 3 | Bldg. Rad Monitor ORT-AR08 stuck in the high alarm position. The  
 0 4 | monitor was taken O.O.S. and shiftly area readings were taken as required  
 0 5 | by T.S. 3.14.1.2.  
 0 6 |  
 0 7 |  
 0 8 |

0 9 | SYSTEM CODE: B A | CAUSE CODE: X | CAUSE SUBCODE: X | COMPONENT CODE: I N S T R U | COMP. SUBCODE: I | VALVE SUBCODE: Z  
7 8 9 10 11 12 13 18 19 20  
SEQUENTIA LER/RO REPORT NUMBER: 7 9 | OCCURRENCE CODE: 0 3 | REPORT TYPE: L | REVISION NO.: 0  
 21 22 23 24 26 27 28 29 30 31 32  
ACTION TAKEN: B | FUTURE ACTION: Z | EFFECT ON PLANT: Z | SHUTDOWN METHOD: Z | HOURS: 0 0 0 0 | ATTACHMENT SUBMITTED: N | NPRD-4 FORM SUB.: N | PRIME COMP. SUPPLIER: A | COMPONENT MANUFACTURER: N 3 0 5  
 33 34 35 36 37 40 41 42 43 44 47

### CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 | On inspection, the needle was found to be bent and stuck to the face of  
 1 1 | the meter. The check source had retracted earlier, thus clearing the  
 1 2 | high alarm condition. The needle was straightened and manually moved  
 1 3 | away from the face. The meter glass was replaced. The monitor was func-  
 1 4 | tionally tested & returned to service. No further action is necessary.

1 5 | FACILITY STATUS: E | % POWER: 0 5 5 | OTHER STATUS: NA | METHOD OF DISCOVERY: B | DISCOVERY DESCRIPTION: Daily Inspection  
7 8 9 10 12 13 44 45 46  
ACTIVITY CONTENT RELEASED OF RELEASE: Z | AMOUNT OF ACTIVITY: NA | LOCATION OF RELEASE: NA  
 8 9 10 11 44 45 46  
 1 6 | PERSONNEL EXPOSURES: 0 0 0 | TYPE: Z | DESCRIPTION: NA  
7 8 9 11 12 13 39  
PERSONNEL INJURIES: 0 0 0 | DESCRIPTION: NA  
 7 8 9 11 12 41  
 1 7 | LOSS OF OR DAMAGE TO FACILITY: Z | DESCRIPTION: NA  
7 8 9 10 43  
 1 8 | PUBLICITY ISSUED: N | DESCRIPTION: NA  
7 8 9 10 45

7908140542 S

627230

NRC USE ONLY

NAME OF PREPARED

Fred Ost

PHONE: 312-746-2084 #238