

LICENSEE EVENT REPORT

CONTROL BLOCK: _____ (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 | P | A | B | V | S | 1 | 2 | 0 | 0 | - | 0 | 0 | 0 | 0 | 0 | - | 0 | 0 | 3 | 4 | 1 | 1 | 1 | 1 | 4 | 5
7 8 9 LICENSEE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE 30 57 CAT 58

0 1 | L | 6 | 0 | 5 | 0 | 0 | 0 | 3 | 3 | 4 | 7 | 0 | 7 | 2 | 6 | 7 | 9 | 8 | 0 | 8 | 0 | 9 | 7 | 9 | 9
7 8 9 REPORT SOURCE 60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | During testing of the Emergency Bus 4160V/480V General Electric Transformers, megger
0 3 | readings indicated a significant degradation of the insulation resistance as compared
0 4 | to the original acceptance testing.
0 5 |
0 6 |
0 7 |
0 8 |

0 9 | SYSTEM CODE [E B] (11) CAUSE CODE [E] (12) CAUSE SUBCODE [A] (13) COMPONENT CODE [T R A N S F] (14) COMP. SUBCODE [Z] (15) VALVE SUBCODE [Z] (16)
17 LER/RO REPORT NUMBER [7 9] (21) EVENT YEAR [7 9] (22) SEQUENTIAL REPORT NO. [0 2 1] (24) OCCURRENCE CODE [0 1] (28) REPORT TYPE [T] (30) REVISION NO. [0] (32)
ACTION TAKEN [C] (18) FUTURE ACTION [Z] (19) EFFECT ON PLANT [Z] (20) SHUTDOWN METHOD [Z] (21) HOURS [0 0 0 0] (22) ATTACHMENT SUBMITTED [N] (23) NRPD-4 FORM SUB. [Y] (24) PRIME COMP. SUPPLIER [A] (25) COMPONENT MANUFACTURER [G 0 8 0] (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 | All four transformers on the emergency buss have been replaced with properly
1 1 | qualified ITE transformers which were available on-site to improve reliability.
1 2 |
1 3 |
1 4 |

1 5 | FACILITY STATUS [G] (28) % POWER [0 0 0] (29) OTHER STATUS [N/A] (30) METHOD OF DISCOVERY [C] (31) DISCOVERY DESCRIPTION [Special test] (32)

1 6 | ACTIVITY CONTENT [Z] (33) RELEASER OF RELEASE [Z] (34) AMOUNT OF ACTIVITY [N/A] (35) LOCATION OF RELEASE [N/A] (36)

1 7 | PERSONNEL EXPOSURES NUMBER [0 0 0] (37) TYPE [Z] (38) DESCRIPTION [N/A] (39)

1 8 | PERSONNEL INJURIES NUMBER [0 0 0] (40) DESCRIPTION [N/A] (41)

1 9 | LOSS OF OR DAMAGE TO FACILITY TYPE [Z] (42) DESCRIPTION [N/A] (43)

2 0 | PUBLICITY ISSUED [N] (44) DESCRIPTION [N/A] (45) 7908140 828 S- 650 139 NRC USE ONLY

NAME OF PREPARER J. A. Werling

PHONE: 412-643-1258