

AUG 30 2019

Docket No.: 52-026

ND-19-1027  
10 CFR 52.99(c)(1)U.S. Nuclear Regulatory Commission  
Document Control Desk  
Washington, DC 20555-0001Southern Nuclear Operating Company  
Vogtle Electric Generating Plant Unit 4  
ITAAC Closure Notification on Completion of ITAAC C.2.6.12.05 [Index Number 675]

Ladies and Gentlemen:

In accordance with 10 CFR 52.99(c)(1), the purpose of this letter is to notify the Nuclear Regulatory Commission (NRC) of the completion of Vogtle Electric Generating Plant (VEGP) Unit 4 Inspections, Tests, Analyses, and Acceptance Criteria (ITAAC) Item C.2.6.12.05 [Index Number 675] for verifying the short circuit contribution of each as-built offsite circuit at the interface with the onsite ac power system is compatible with the interrupting capability of the onsite fault current interrupting devices. The closure process for this ITAAC is based on the guidance described in Nuclear Energy Institute (NEI) 08-01, "Industry Guideline for the ITAAC Closure Process under 10 CFR Part 52," which was endorsed by the NRC in Regulatory Guide 1.215.

This letter contains no new NRC regulatory commitments. Southern Nuclear Operating Company (SNC) requests NRC staff confirmation of this determination and publication of the required notice in the Federal Register per 10 CFR 52.99.

If there are any questions, please contact Tom Petrak at 706-848-1575.

Respectfully submitted,

Michael J. Yox  
Regulatory Affairs Director Vogtle 3 & 4Enclosure: Vogtle Electric Generating Plant (VEGP) Unit 4  
Completion of ITAAC C.2.6.12.05 [Index Number 675]

MJY/DJG/sfr

U.S. Nuclear Regulatory Commission

ND-19-1027

Page 2 of 3

**To:**

**Southern Nuclear Operating Company/ Georgia Power Company**

Mr. Peter P. Sena III (w/o enclosures)

Mr. D. L. McKinney (w/o enclosures)

Mr. M. D. Meier (w/o enclosures)

Mr. D. H. Jones (w/o enclosures)

Mr. G. Chick

Mr. M. J. Yox

Mr. A. S. Parton

Ms. K. A. Roberts

Mr. T. G. Petrak

Mr. C. T. Defnall

Mr. C. E. Morrow

Mr. J. L. Hughes

Ms. K. M. Stacy

Ms. A. C. Chamberlain

Mr. J. C. Haswell

Document Services RTYPE: VND.LI.L06

File AR.01.02.06

cc:

**Nuclear Regulatory Commission**

Mr. W. Jones (w/o enclosures)

Mr. F. D. Brown

Mr. C. P. Patel

Mr. G. J. Khouri

Ms. S. E. Temple

Mr. N. D. Karlovich

Mr. A. Lerch

Mr. C. J. Even

Mr. B. J. Kemker

Ms. N. C. Coovert

Mr. C. Welch

Mr. J. Gaslevic

Mr. V. Hall

Mr. G. Armstrong

Ms. T. Lamb

Mr. M. Webb

Mr. T. Fredette

Mr. C. Weber

**Oglethorpe Power Corporation**

Mr. R. B. Brinkman

Mr. E. Rasmussen

**Municipal Electric Authority of Georgia**

Mr. J. E. Fuller  
Mr. S. M. Jackson

**Dalton Utilities**

Mr. T. Bundros

**Westinghouse Electric Company, LLC**

Dr. L. Oriani (w/o enclosures)  
Mr. D. C. Durham (w/o enclosures)  
Mr. M. M. Corletti  
Ms. L. G. Iller  
Mr. Z. S. Harper  
Mr. J. L. Coward

**Other**

Mr. J. E. Hesler, *Bechtel Power Corporation*  
Ms. L. Matis, *Tetra Tech NUS, Inc.*  
Dr. W. R. Jacobs, Jr., Ph.D., *GDS Associates, Inc.*  
Mr. S. Roetger, *Georgia Public Service Commission*  
Ms. S. W. Kernizan, *Georgia Public Service Commission*  
Mr. K. C. Greene, *Troutman Sanders*  
Mr. S. Blanton, *Balch Bingham*

**Southern Nuclear Operating Company  
ND-19-1027  
Enclosure**

**Vogtle Electric Generating Plant (VEGP) Unit 4  
Completion of ITAAC C.2.6.12.05 [Index Number 675]**

## **ITAAC Statement**

### **Design Commitment:**

5. The fault current contribution of each offsite circuit is compatible with the interrupting capability of the onsite short circuit interrupting devices.

### **Inspections, Tests, Analyses:**

Analyses of the as-built offsite circuit will be performed to evaluate the fault current contribution of each offsite circuit at the interface with the onsite ac power system.

### **Acceptance Criteria:**

A report exists and concludes the short circuit contribution of each as-built offsite circuit at the interface with the onsite ac power system is compatible with the interrupting capability of the onsite fault current interrupting devices.

## **ITAAC Determination Basis**

Analyses of the as-built offsite power system were performed to verify the fault current contribution of each as-built offsite circuit is compatible with the interrupting capability of the onsite short circuit interrupting devices.

The design of the as-built offsite circuits was reviewed and the fault current contribution of each offsite circuit was analyzed for short-circuits of the offsite power system based on Vogtle Units 1, 2, 3, and 4 in normal operation. The results of the analyses are provided in the report, C.2.6.12.05-U4-PCD-Rev 0, "Vogtle 3&4 Offsite Power - Maximum Available Fault Currents" (Reference 1).

The design of the onsite alternating current (AC) power system was reviewed to determine that the capabilities of the interrupting devices are compatible with the short circuit contribution of each as-built offsite circuit. The results of the design review are summarized in the report, PCD Summary Report C.2.6.12.05-U4-SumRep-Rev 0, "Review of As-Designed Short-Circuit Capabilities of Onsite AC Power System" (Reference 2). The report concludes the analyses that determined the equipment ratings were performed with a conservative equivalent short-circuit impedance. The equipment rating requirements identified in those analyses were incorporated in the design specifications issued for procurement of the equipment.

The fault capabilities of the onsite AC power system are conservatively designed for fault currents greater than the maximum expected fault currents of the offsite power system. The short-circuit contribution of each as-built offsite circuit at the interface with the onsite AC power system is compatible with the interrupting capability of the onsite fault current interrupting devices.

### **ITAAC Finding Review**

In accordance with plant procedures for ITAAC completion, Southern Nuclear Operating Company (SNC) performed a review of all ITAAC findings pertaining to the subject ITAAC and associated corrective actions. This review found that there are no relevant ITAAC findings associated with this ITAAC. The ITAAC completion review document number is included in the Vogtle Unit 4 ITAAC Completion Package for ITAAC C.2.6.12.05 (Reference 3) and available for NRC inspection.

### **ITAAC Completion Statement**

Based on the above information, SNC hereby notifies the NRC that ITAAC C.2.6.12.05 was performed for Vogtle Unit 4 and that the prescribed acceptance criteria are met. Systems, structures, and components verified as part of this ITAAC are being maintained in their as-designed, ITAAC compliant condition in accordance with approved plant programs and procedures.

### **References (available for NRC inspection)**

1. C.2.6.12.05-U4-PCD-Rev 0, "Vogtle 3&4 Offsite Power - Maximum Available Fault Currents"
2. C.2.6.12.05-U4-SumRep-Rev 0, "Review of As-Designed Short-Circuit Capabilities of Onsite AC Power System"
3. Vogtle Unit 4 ITAAC Completion Package for ITAAC C.2.6.12.05