



Commonwealth Edison
One First National Plaza, Chicago, Illinois
Address Reply to: Post Office Box 767
Chicago, Illinois 60690

SC

July 12, 1979

Mr. James G. Keppler, Director
Directorate of Inspection and
Enforcement - Region III
Nuclear Regulatory Commission
199 Roosevelt Road
Glen Ellyn, Illinois 60137

Subject: Dresden Station Units 1, 2 and 3
Quad-Cities Station Units 1 and 2
Zion Station Units 1 and 2
Revised Response to IE Bulletin No. 79-11
NRC Docket Nos. 50-10/237/249, 50-254/265
and 50-295/304

References (a): May 22, 1979 letter from James G. Keppler
to Byron Lee, Jr. transmitting IE Bulletin
No. 79-11

(b): July 2, 1979 letter from C. Reed to J. G.
Keppler transmitting response to IE Bulletin
No. 79-11

Dear Mr. Keppler:

Reference (a) transmitted IE Bulletin No. 79-11
regarding "Faulty Overcurrent Trip Device In Circuit Breakers
for Engineered Safety Systems." Reference (b) contained
Commonwealth Edison's response to that Bulletin for Dresden,
Quad-Cities and Zion Stations. That response should be
revised to read:

1. Westinghouse DB-50 and DB-75 circuit breakers
are not used in safety-related systems nor
stored as spares at Dresden and Quad-Cities
Station.

JUL 16 1979

690301

7908150 349

Q

Mr. James G. Keppler:

- 2 -

July 12, 1979

2. Westinghouse DB-50 and DB-75 circuit breakers with overcurrent trip devices are not used in safety-related systems nor stored as spares at Zion Station.

Please address any additional questions regarding this matter to this office.

Very truly yours,



Cordell Reed
Assistant Vice-President

690302