

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION

1 In the Matter of:
2 IE TMI INVESTIGATION INTERVIEW
3 of Kenneth Bryan, Shift Supervisor
4
5
6
7
8

9 Trailer #203
10 NRC Investigation Site
11 TMI Nuclear Power Plant
12 Middletown, Pennsylvania

13 May 16, 1979
14 (Date of Interview)

15 July 9, 1979
16 (Date Transcript Typed)

17 198
18 (Tape Number(s))
19
20

21 NRC PERSONNEL:
22 Dorwin R. Hunter
23 Tracy Binion
24 Chip Foster
25 John R. Sinclair

7908280772

683 176

1 SINCLAIR: The following interview is being conducted of Mr. Kenneth
2 Bryan. Mr. Bryan is the Shift Supervisor at the Three Mile Island
3 Nuclear Power Facility. Present time is 3:18 p.m. Eastern Daylight
4 Time. Today's date is May 16, 1979. The place of the interview is
5 trailer 203 which is located immediately outside the south gate at the
6 Three Mile Island site. The individuals present for the interview will
7 be, interviewer Mr. Dorwin R. Hunter. Mr. Hunter is an Inspection
8 Specialist, Performance Appraisal Branch, I&E Reactor Construction
9 Inspection. Also attending the interview will be Miss Tracy Binion,
10 Inspector Auditor from the Office of Inspector and Auditor, U.S. Nuclear
11 Regulatory Commission. Also attending is Mr. Chip Foster. Mr. Foster
12 is also an Inspector Auditor, Office of Inspector and Auditor. My name
13 is John R. Sinclair. I'm an Investigator, Office of Inspector and
14 Auditor, U.S. Nuclear Regulatory Commission. Prior to the interview
15 being conducted, Mr. Bryan was provided a copy of a document explaining
16 his rights concerning information to be obtained regarding the incident
17 at Three Mile Island. In addition, Mr. Bryan was apprised of the purpose
18 of the investigation, its scope and the authority by which Congress
19 authorizes the Nuclear Regulatory Commission to conduct the investigation.
20 On the second page of the advisement document, Mr. Bryan has answered
21 three questions. The questions and Mr. Bryan's replies will now be
22 recorded as part of the interview.

1 SINCLAIR: Mr. Bryan, do you understand the document?
2

3 BRYAN: Yes I do.
4

5 SINCLAIR: Second question. Do we have your permission to tape the
6 interview?
7

8 BRYAN: Yes.
9

10 SINCLAIR: Third question. Do you want a copy of the tape and transcript?
11

12 BRYAN: Yes.
13

14 SINCLAIR: Okay, thank you. Okay, at this point I would like you to
15 provide us maybe a brief work history, work in the nuclear industry and
16 any training which may be pertinent.
17

18 BRYAN: Well, I started work with Metropolitan Edison Company at Crawford
19 Station in Middletown, coal power plant, and I came down here in 1969 in
20 the training program Met Ed had set up for control room operators and it
21 was in a 42 week course and that's basically how I got into the industry.
22 We went through the 42 week training course that Met Ed has supplied and
23 from there I went on to get my RO license.
24
25

1 SINCLAIR: RO is?

2
3 BRYAN: Reactor Operator.

4
5 SINCLAIR: Reactor Operator. And all your time you spent here at Three
6 Mile Island?

7
8 BRYAN: Yes, all my time has been at Three Mile Island.

9
10 SINCLAIR: Okay, thank you. At this point I'll turn it over to Mr.
11 Hunter.

12
13 HUNTER: Okay, Ken after the 42 week training course you then received
14 your reactor operator's license and you are a control room operator in
15 which unit?

16
17 BRYAN: Unit 1.

18
19 HUNTER: And then you were promoted to Shift Supervisor from a Control
20 Room Operator?

21
22 BRYAN: No, my second position was a Shift Foreman in Unit 1.

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

HUNTER: And then?

BRYAN: And then Shift Supervisor.

HUNTER: When did you obtain the position of Shift Supervisor in Unit 1?

BRYAN: Station Shift Supervisor. Approximately a year ago.

HUNTER: And in that position you are...you have a senior license on both Units 1 and 2?

BRYAN: Yes sir.

HUNTER: Okay. Okay, Ken, realizing that it's been a while since March 28, the March 28, you were working the 11:00 to 7:00 shift on Unit 1, if I understand your position at that time.

BRYAN: That's correct.

HUNTER: And that would put you onsite somewhere right...right prior to 11:00 on the 27th. What was the...what were your duties on Unit 1 at that time on the 11:00 to 7 what were you...what were you involved in in Unit 1?

1 BRYAN: We were in the process of heating Unit 1 up. This is...we just
2 finished refueling outage, we were heating Unit 1 up to put it back on
3 the line.

4
5 HUNTER: Were you doing any special testing, Ken?

6
7 BRYAN: Not that I recall.

8
9 HUNTER: Just a...it was a normal heat up, normal procedures?

10
11 BRYAN: Yes.

12
13 HUNTER: What was the...what was your plan for the morning of the 28th
14 on Unit 1, just continue heat up?

15
16 BRYAN: I...I don't remember if we had done the second vent on the
17 control rod drives or not, you know, I really don't remember.

18
19 HUNTER: Okay, then...

20
21 BRYAN: I think we were the whole way up.

1 HUNTER: Alright.

2
3 BRYAN: It seems to me like we were getting ready to...there...there was
4 something holding us up in deborating and I...I don't remember what it
5 was.

6
7 HUNTER: Okay, it's alright. And early in the morning apparently you
8 received a called from Bill Zewe on Unit 2, the Shift Supervisor on Unit
9 2. Can you characterize that particular call that you had from Bill?

10
11 BRYAN: No, I didn't get a call from Bill, I called Bill.

12
13 HUNTER: Okay.

14
15 BRYAN: They announced over the page system that the turbine had tripped
16 in Unit 2 and at the time we needed st..., we were using Unit 2 steam
17 for feedwater heating and turbine seals in Unit 1, and I called him to
18 find out if the reactor had tripped and whether we needed our aux boilers
19 or not and he said that it did and he said why don't you come on down
20 and give me a hand and that's when I went down.

21
22 HUNTER: Did he indicate to you anything other than a reactor trip,
23 turbine trip? Can you give me any kind of point status at that time?

1 BRYAN: He mentioned that he had ES injection already.
2

3 HUNTER: Does that mean anything to you as far as...was that unusual on
4 Unit 2?
5

6 BRYAN: It has happened before in Unit 2 on a turbine trip.
7

8 HUNTER: Okay. About what time then did you get to Unit 2?
9

10 BRYAN: 4:08.
11

12 HUNTER: Your fairly specific as far as your time how did you know
13 exactly when you got there?
14

15 BRYAN: Cause it was right after I got there, but when I got there I
16 noticed that the feedwater valve...we weren't getting any feedwater to
17 the steam generators and Craig was standing in front of me. He looked
18 down and said the 12's are shut and he opened the feedwater valves...
19

20 HUNTER: Okay.
21

22 BRYAN: ...that's right when I got there.
23
24
25

1 HUNTER: Ken, and when you walked into the control room, what keyed you
2 to say your not getting any feedwater, what did you look at?
3

4 BRYAN: The first thing I noticed when I walked in was the Tavg indicator
5 and was 592 degrees, 596, and it was a little hot and I looked over the
6 steam generators and the levels were low and I said you don't have any
7 feedwater.
8

9 HUNTER: Did you notice anything other then the Tavg in the fact that
10 the levels were...but were they actually at 10 inches or were they that
11 low, do you recall?
12

13 BRYAN: They were that...they were low.
14

15 HUNTER: They were low, they were very low.
16

17 BRYAN: Yes.
18

19 HUNTER: Okay. Was there anything else that you noticed, did you notice
20 anything about the auxiliary feedwater, the emergency feedwater pumps at
21 that time or was that just your comment?
22

23 BRYAN: That was my comment at the time. That all happened right away.
24 I looked at Tavg, I looked at the steam generator levels and I said you
25

1 don't have any feedwater and Craig was standing between me and the 12
2 valves, well he was right in front of them, and he looked down and said
3 the 12 valves are closed, and he opened them up.
4

5 HUNTER: Okay. Did the...did...were you then...were you two fellas then
6 or everybody in the control room, were you aware of the feeding of the
7 steam generators at that time and if you were how did you know when he
8 opened the 12 valves?
9

10 BRYAN: Well the levels started to come back.
11

12 HUNTER: Okay. Does that take time or does it occur right away?
13

14 BRYAN: It takes some time, yeah, we're talking a minute or two I guess.
15

16 HUNTER: Alright, Craig mentioned something about the...the noise monitor
17 being on the A generator and that there was....
18

19 BRYAN: You could hear the feedwater.
20

21 HUNTER: water hammer, splash in...in...
22
23
24
25

1 BRYAN: Yes.

2
3 HUNTER: ...and the water entered the steam generator, do you recall
4 hearing that?

5
6 BRYAN: Yes, that's the first I've heard of that since that night, but I
7 do remember it, we could hear something on the steam generator and we
8 assumed it was the feedwater.

9
10 HUNTER: Okay, did...did...what...did you walk over and look at the
11 feedwater station at that time? In other words to backup Craig or see
12 what he was doing, look at the feedpump pressures or are there actual,
13 number of feedpumps running, anything...anything specific that you did
14 when they took...opened the 12 valves backup?

15
16 BRYAN: No, I...I think...the next thing I went over to look at was the
17 pressurizer level.

18
19 HUNTER: Okay, lets...

20
21 BRYAN: I was still...it was either that or the condensate pumps because
22 he didn't have...it seems to me there was only one condensate pump
23 running at the time or something. So I'd just walked in and I was just
24 trying to take a look and see what else is going on so I didn't pay too
25 much more attention to the feedwater at that time.

1 HUNTER: Okay, Tavg was high? No feedwater flow, they got the feedwater
2 flow back, the 12 valves were closed and now they are open, the next
3 thing you indicate you throttled it up to pressurizer level do you
4 remember what...what it was at the time you looked at it?
5

6 BRYAN: It was either still pegged high or just barely starting to
7 come ... come off the top of the scale.
8

9 HUNTER: Did that strike you as being unusual?
10

11 BRYAN: Oh yes! Well...
12

13 HUNTER: Looking back at your training, but go ahead...
14

15 BRYAN: With that high Tavg, I guess it...you know...you could expect a
16 higher than normal level.
17

18 HUNTER: Okay, Tavg should have come down to about 545 or so and it was
19 50 degrees higher, 40 something degrees higher rather, being at 592,
20 okay. When you saw the high pressurizer level what was your...what was
21 your reaction then and what did you look at?
22

23 BRYAN: I looked at letdown flow and we were...there was a guy on...he
24 was trying to control letdown flow, increase letdown flow and reduce the
25 pressurizer level.

1 HUNTER: Okay, and the... if my notes again are right, 8 minutes into
2 the event, apparently Ed Frederick was at the...at the pressurizer level
3 panel and also it could've been Fred Scheimann also was there.
4

5 BRYAN: I think Fred was there when I...
6

7 HUNTER: Okay.
8

9 BRYAN: ...I remember Fred being there.
10

11 HUNTER: Alright, and he was trying to increase letdown flow? What
12 about the actual makeup flow, the pressurizer level is high, the 17
13 valve which is the makeup valve would be closed....
14

15 BRYAN: Right.
16

17 HUNTER: ... if it's fixed on automatic and I assume that it was, that's
18 the indication we're getting. What about any makeup flow through the
19 high pressure injection path or the reactor coolant pump seals?
20

21 BRYAN: Well you still have seal injection flow...
22

23 HUNTER: Would the operators ever secure the seal water injection flow
24 that you're aware of? Would that be normal?
25

1 BRYAN: Would they secure it?

2
3 HUNTER: Or have they...or would they routinely secure it or do they
4 ever secure it or...
5

6 BRYAN: No, that's not a normal...
7

8 HUNTER: ...and the procedures they normally keep the seal injection
9 operating?
10

11 BRYAN: Yes, yes.
12

13 HUNTER: Okay. Well then you assume that...or did you notice whether
14 there was one or two makeup pumps on to make any seal water injection?
15

16 BRYAN: I thought at the time that there wasn't any on.
17

18 HUNTER: I've been reading some of the things. I want to make sure
19 because I'm getting some different information and I want to make sure
20 that...can you tell me why you maybe thought that, or maybe..maybe they
21 weren't off. That's what I need to know?
22
23
24
25

1 BRYAN: Maybe they weren't, it's true.

2
3 HUNTER: Yes, that's what I want to make sure.

4
5 BRYAN: I don't know how I came across this opinion but that morning I
6 assumed that they were off with the high pressurizer level and increase
7 in letdown and I thought we had secured them because of the fact that we
8 had a solid system and you didn't want to keep the head of the makeup
9 pump on the reactor coolant system.

10
11 HUNTER: I understand.

12
13 BRYAN: But I just....just yesterday I was talking about it and I...
14 they say there was one running yet, I don't know.

15
16 HUNTER: Okay, fine. The...as they shift...as the...looking at your
17 shift Unit 1, or Unit 2, and again looking at the seal water injection,
18 would the operators normally keep it on to protect the pumps? Will the
19 pumps run without seal water injection?

20
21 BRYAN: Oh, yeah.

1 HUNTER: Is...is it detrimental to the pumps at all?
2

3 BRYAN: No, you can run without seal injection.
4

5 HUNTER: Okay, so the reactor coolant pumps could run...
6

7 BRYAN: Yeah.
8

9 HUNTER: ...your leakage then would just be out not being supplied by
10 the seal water injection?
11

12 BRYAN: True.
13

14 HUNTER: Okay. An item that I wanted to look at is that...early on you
15 indicated in a previous interview that, there's some previous information
16 that we have is that the...in previous interviews that we've done that
17 the core flood tank valves were closed or were closed while you were
18 there.
19

20 BRYAN: Yes.
21

22 HUNTER: Can you elaborate on closing those valves and what the...your
23 philosophy or your...the reason for those valves being closed if you
24 were involved?
25

1 BRYAN: Yes, we had, pressurizer level was still high and core flood
2 system is designed for a loss of coolant accident to reflood the...the
3 core and with the full pressurizer we didn't need any more water at the
4 time we thought, so we closed the...isolation valves in the core flood
5 tanks.

6
7 HUNTER: Procedure for closing those valves or how..how...how did you go
8 about closing them? Do you have to go unlock them and energize the
9 breakers and then close the valves? Is that the way they were set up?

10
11 BRYAN: Yep.

12
13 HUNTER: Who...who unlocked the valves? Do you recall who...who...did
14 you send somebody down or did Bill Zewe send somebody down?

15
16 BRYAN: I don't know.

17
18 HUNTER: Okay.

19
20 BRYAN: Somehow or another by the time we got to that, the valves were
21 energized I don't know...

22
23 HUNTER: Okay. When you close them...close them, do you leave them
24 closed, I mean do you leave the electrical breakers closed, and were
25 they sitting there in the energized position?

1 BRYAN: Yes, so that it can be reopened.

2
3 HUNTER: Okay. Reopened how? Manually, with a switch?

4
5 BRYAN: With a switch from the control room.

6
7 HUNTER: What about any automatic opening of those valves?

8
9 BRYAN: There is none.

10
11 HUNTER: The ES does not open those valves?

12
13 BRYAN: No.

14
15 HUNTER: Okay. Later on in the day those were reopened?

16
17 BRYAN: Yes.

18
19 HUNTER: Well, did you happen to be there when they were reopened?

20
21 BRYAN: No.

22
23 HUNTER: Okay. Did you happen to look at the steam generator, the
24 condensate pumps were secured, the atmospheric dumps are automatically
25

1 labeled but when the condensate system is...no...the circ water pumps
2 were still on so the atmospheric dumps were not in operation, the turbine
3 bypass was in operation. Did you happen to look at the turbine bypass
4 valves and...at that time and if they were functioning or were on automatic?
5

6 BRYAN: I didn't look at those, I looked at header pressure and header
7 pressure was holding.
8

9 HUNTER: Holding steady?
10

11 BRYAN: Yes and indicating that the valves were working properly.
12

13 HUNTER: It looked normal to you...
14

15 BRYAN: Right.
16

17 HUNTER: ...then at that time? Okay. There seemed to be a problem with
18 hotwell level and it was fairly soon after you got to Unit 2, Bill Zewe
19 ended up going to the Turbine Building and looking at hotwell level, can
20 you elaborate about the hotwell level and what the problem is with
21 hotwell level at that time?
22

23 BRYAN: We had a high indication in the control room and Bill went down
24 to check the site glass and he came back and said, "The site...it was
25

683 194

1 out at the top of the site glass" indicating that actually had a high
2 level in the hotwell and I think that's about the time we secured the
3 circ water pumps to automatically go over to the atmospheric relief
4 valves so that the steam we were dumping back to the hotwell would go
5 out the atmospherics and start reducing our inventory of water in the
6 hotwell.

7
8 HUNTER: The intent at that time was to get the condensate pump back or
9 booster pump and get the reject system back in and reject the hotwell
10 back to the steam generators.

11
12 BRYAN: Capacity, yeah, well at that time we opened the... we wanted the
13 atmospherics opened, it was just so we'd be blowing steam out instead of
14 saving it, thus reducing the water inventory that we had in the hotwell.

15
16 HUNTER: Okay. Do you know what the problem was with the hotwell?

17
18 BRYAN: The more I think back on it we didn't...we weren't feeding
19 anything, everything just ended up in the hotwell.

20
21 HUNTER: That...that would be your evaluation of it now by just by again
22 looking back at it?

1 BRYAN: Yeah.

2
3 HUNTER: You weren't involved in getting it squared away and finding out
4 what was wrong with it, if it would have a failed level control system
5 or ... or whatever?
6

7 BRYAN: Oh no.

8
9 HUNTER: Okay. The ... through some inter ... of the interviews I've
10 come across in the fact that the reject line off of the condensate
11 system, the downstream valve on the reject line on Unit 2 is normally
12 throttled. Are you aware of that, or are you aware of the problem? Is
13 that for a specific reason?
14

15 BRYAN: Yes, the automatic control valve sometimes fails open.

16
17 HUNTER: What's the result if it fails open then?
18

19 BRYAN: Get a low...a low suction pressure to the feed pumps and the
20 feed pumps trip.
21

22 HUNTER: And low feed pumps tripped and then would cause a run back or a
23 Unit trip?
24
25

683 196

1 BRYAN: Yep.

2
3 HUNTER: Okay. Is that thing going on for a substantial amount of time,
4 that you're aware of?

5
6 BRYAN: All I can say is that I know it's happened twice.

7
8 HUNTER: And the valves have been throttled....

9
10 BRYAN: Since then to...

11
12 HUNTER: Okay.

13
14 BRYAN: ...to prevent that.

15
16 HUNTER: Alright. Were you involved at all in the demineralizer problem
17 in Unit 2, other than just discussions with the other fellows?

18
19 BRYAN: No.

20
21 HUNTER: ...because that ended up being the problem that they had, okay.
22 Were you ever involved in any of the trips in Unit 2? A turbine trip
23 before from any source? Personally, you know you'd have...you'd have
24 the...
25

1 BRYAN: Yes.

2
3 HUNTER: ...you'd happen to have the...

4
5 BRYAN: I've been there for a couple other ... I was ... I'm just trying
6 to think...

7
8 HUNTER: Let me go a little further, Ken. During the trip that you had
9 that you have seen...if you have seen a trip, have you seen the ES
10 initiated before on a routine or a normal plant trip in Unit 2?

11
12 BRYAN: No, not while I was there.

13
14 HUNTER: Not while you were there, okay. But again you said it didn't
15 surprise you that it had initiated because you...had you reviewed trip
16 reports from the other trips that showed that ES had in fact initiated?

17
18 BRYAN: I can't say that I actually reviewed a trip report it just...we
19 all talk...

20
21 HUNTER: Okay.

1 BRYAN: ... if a trip or something happens.
2

3 HUNTER: Supervisors or other people, the operators had talked and you
4 were aware that that was the problem, okay? How did you feel about
5 pressurizer being solid, personally, and you look ... look back at your
6 training, does that...did that...did your training key on trying to
7 maintain a pressurizer other than solid?
8

9 BRYAN: Oh yes, yes, we tried not...we tried to maintain it with a
10 bubble.
11

12 HUNTER: Can you give...give me a feeling of...of what the problems
13 you...you would have visualized with allowing the pressurizer to go
14 solid?
15

16 BRYAN: Well for one thing, once you get solid whatever your discharge
17 pressure of the makeup pumps is it goes right onto the system.
18

19 HUNTER: Let's say the discharge pressure of the pumps is approximately,
20 it could go as high as I think 2900 pounds...?
21

22 BRYAN: Yes.
23
24
25

1 HUNTER: ...if you take the primary system solid and you have the pumps,
2 I would be under the assumption you'd lift the safety valves at 2485
3 pounds...

4
5 BRYAN: Right.

6
7 HUNTER: ...and you'd be sitting it on safety valves.

8
9 BRYAN: That's true.

10
11 HUNTER: Have you fellows discussed that?

12
13 BRYAN: That night.

14
15 HUNTER: In your training or...?

16
17 BRYAN: Oh, no.

18
19 HUNTER: Did you fellows discuss it that night?

20
21 BRYAN: No.

1 HUNTER: You know, Fred Scheimann or anybody with you that morning?
2

3 BRYAN: Not that I'm aware of.
4

5 HUNTER: Okay. You indicated that with a solid pressurizer you might
6 have been inclined to shut down the makeup pumps. Is the reason because
7 the fellows are that sensitive to that solid pressurizer level that they
8 would tend to...to go back to almost no makeup pumps or minimum makeup
9 just to maintain that...try to maintain pressurizer level?
10

11 BRYAN: Well, really once you get a solid pressurizer you don't need any
12 makeup, at least we didn't at the time, and like you say you're just not
13 set there and operate on the relief valves.
14

15 HUNTER: Okay.
16

17 BRYAN: And, the relief valves aren't designed to set there and operate,
18 you know, with a steady flow of water through them like that and once
19 you get back to a... to get back to a situation that you...you can get
20 another bubble again and you may not be able to get the relief valves to
21 reseal.
22

23 HUNTER: Have you seen in Unit 1 or 2 of the case where the relief
24 valves have in fact failed to reseal? Have you ever had that type
25 problem in either of these Units?

1 BRYAN: No, but we've never sat there and operated solid.

2
3 HUNTER: Okay.

4
5 BRYAN: ... with coolant water through them.

6
7 HUNTER: You say the main steam safety valves failed to reseal due to
8 failures, other than that one time have you seen any fail to reseal?
9

10 BRYAN: No.

11
12 HUNTER: Okay. In one of the interviews that we've had they indicated
13 that they had trouble with the A makeup pump failing to start, in one
14 case the makeup pump...the fellow may've held...failed to hold the
15 switch over for more than a time delay to allow the oil pressure to
16 build up. In another case the makeup pump tripped in like 26 seconds
17 after the heater had been sitting there running for that amount time.
18

19 BRYAN: Is this that...that night we are talking about?
20

21 HUNTER: Yes, and that morning. Are you...I...I...I can understand why
22 if the man doesn't hold the switch for the 3-1/2, it depends on the
23 pump, or 4 seconds for the lube oil pressure to build up. I can under-
24 stand why the pump would trip back out. I'm having difficulty and so
25

1 far I haven't been able to determine why the pump would trip after 26
2 seconds and it was just sitting there running. Have you seen this
3 problem with those makeup pumps or with the makeup pumps where maybe the
4 lube oil system fails, or we get a pressure spike, or something, that
5 would...the computer didn't printout a low lube oil pressure which it
6 would normally do I think if that was the problem so I couldn't key onto
7 that low lube oil pressure.

8
9 BRYAN: No, I haven't seen that problem.

10
11 HUNTER: Alright. The reactor coolant drain tank was a problem the
12 morning when you came over to Unit 2, and you indicated that you had
13 walked around and looked at the reactor coolant drain tank and I believe
14 that some words about...it may be pumped down or whatever and when you
15 got around it was empty. Would that indicate the rupture disc had gone
16 at that time ... to you? Or do...you know...?

17
18 BRYAN: Not...not right away.

19
20 HUNTER: Do you know what time it was you walked around and looked at
21 the reactor coolant drain tank?

1 BRYAN: No I don't.

2
3 HUNTER: Do you have any feel for the time frame?

4
5 BRYAN: It was early...within the first hour.

6
7 HUNTER: Okay. Had...have you seen the rupture disc blown on the cool-
8 ant...reactor coolant drain tank in Unit 1 or Unit 2 before? Or been
9 involved in that type of event?

10
11 BRYAN: No. no.

12
13 HUNTER: Is it...is it unusual for the reactor coolant drain tank to be
14 hot and high temperature on a reactor trip or a turbine trip when the...after
15 the power operated relief valve opens?

16
17 BRYAN: That's not unusual, but it was unusual that it was empty.

18
19 HUNTER: Okay. Did...when you went back around did you tell anybody or
20 did you talk with anybody about that particular item?

21
22 BRYAN: I think that happened, if I remember the sequence of events
23 right, when I came back around after I had seen that the drain tank was
24 empty, it was in a couple of minutes that we got a Reactor Building fire
25 alarm.

1 HUNTER: Okay.

2
3 BRYAN: And that's when we went, I started looking at the temperatures
4 in the Reactor Building and they were increasing.

5
6 HUNTER: The temperatures of the containment, Reactor Building tempera-
7 tures, were increasing?

8
9 BRYAN: Um Um.

10
11 HUNTER: What about the containment humidity, do you have that available
12 to you to look at?

13
14 BRYAN: No.

15
16 HUNTER: Okay. The temperature recorders I believe you indicate...

17
18 BRYAN: Yes.

19
20 HUNTER: ...there are temperature recorders that look at containment
21 temperatures? Do you recall what the temperatures were?

22
23 BRYAN: Specifically, no. There...I was looking at a trend, you know,
24 they were all trending up.

25

683 205

1 HUNTER: Okay. What would that indicate to you?
2

3 BRYAN: That we had a leak in the reactor building.
4

5 HUNTER: Okay. Did you key that to anything? Did we primary coolant
6 leak or secondary leak or steam leak in the steam generator or was there
7 some... discussion at that time?
8

9 BRYAN: Yeah, with the drain tank being empty and the temperatures going
10 up I think that's when we decided we had blown the rupture disc.
11

12 HUNTER: Okay. Did you look at reactor building pressure at that time?
13

14 BRYAN: Yes.
15

16 HUNTER: Do you recall, was it a trend or do you recall any specific
17 pressure numbers?
18

19 BRYAN: Around 2 pounds.
20

21 HUNTER: Do you recall any discussion about the B steam generator?
22
23
24
25

1 BRYAN: Yes.

2
3 HUNTER: Give me a feel for that if you would.

4
5 BRYAN: We had the levels increasing in the B much higher than the A and
6 we thought...we thought we had a primary-secondary leak in there and we
7 isolated the B steam generator.

8
9 HUNTER: Okay. That...with the B steam generator isolated and you need
10 to steam to atmosphere or you are steaming to atmosphere, prior maybe to
11 getting your circ pumps back on, is there a physical valve line up
12 that's required to prevent steaming the B generator or will it just not
13 steam? Do you recall?

14
15 BRYAN: Yes, you have to close the...you have to close the feedwater
16 valve...we closed the feedwater valves and the block valves for the dump
17 valves. I don't recall if we had circ water back on...I don't think we
18 did.

19
20 HUNTER: If you didn't have circ water, do you close the block valve on
21 one of the atmospheric dump valves upstairs in the main steam area?
22
23
24
25

1 BRYAN: Yes.

2
3 HUNTER: If you had circ water on then would you have closed the block
4 valve on that B side of the condenser?

5
6 BRYAN: If we had circ water on it would have closed itself and we
7 could've reverted back to controlling on the hotwell till the pressure
8 got up so high and then we'd have to close the manual valve at the block
9 valve for the atmospheric relief valve anyway, you'd end up closing up.

10
11 HUNTER: What about on the turbine bypass? Is it split also, the turbine
12 bypass valves?

13
14 BRYAN: Yes.

15
16 HUNTER: Would there be a manual valve you would have to close on that
17 also?

18
19 BRYAN: There, there, yes.

20
21 HUNTER: Okay.

22
23 SINCLAIR: Let me break here. The time is 3:45 p.m., we are going to
24 take a break here to change this tape.

1 SINCLAIR: Alright. The time is 3:50 p.m., and we are gonna continue
2 the interview with Mr. Bryan.

3
4 HUNTER: Okay Ken, this is Hunter speaking again. We just discussed
5 isolating the B steam generator and discussed the atmospheric and the
6 turbine bypass valve manual isolation. I'd like to move to the power
7 operated relief valve, the RB2 and the isolation valve on that. In your
8 early stay in the control room did you review the condition of the power
9 operated relief valve, the discharge temperatures and what did you see?

10
11 BRYAN: I looked at the indication in the control room. That indicated
12 it was closed. I printed out the thermocouples on the power operated
13 relief valve plus the two electric ... code safety valves and they all
14 three, the temperatures were all fairly close which indicated ... I
15 didn't ... never thought that the code safety valves opened. So with
16 the temperatures of the three valves being close, I didn't think that
17 the electromatic was open at this time.

18
19 HUNTER: Okay. One thing you indicated you didn't feel like the code
20 safetys... Did you review the pressure chart to see what the pressures
21 went to during the trip?

22
23 BRYAN: 2355, I think we tripped at, and that's when they started going
24 down.

25

683 209

1 HUNTER: Okay. So you didn't feel like you got to a point where a
2 safety should have lifted?
3

4 BRYAN: Right.
5

6 HUNTER: Ah, and the temperatures were reading the same within a few
7 degrees?
8

9 BRYAN: 10, 15, maybe 20.
10

11 HUNTER: You would suspect if the RB2 valve was open that the temperature
12 would be much higher than that?
13

14 BRYAN: Higher than the other two.
15

16 HUNTER: The difference between would be higher, okay? So you didn't
17 suspect a problem at that time?
18

19 BRYAN: No, I didn't.
20

21 HUNTER: Okay. An area that ah...you learned later that the power
22 operated relief valve had in fact been open and they had in fact isolated
23 it to the MOV, my understanding is at that time you were in Unit 1 and
24 somebody called you and let you know that it was open, right?
25

683 210

1 BRYAN: Yes, it was Mike Ross.

2
3 HUNTER: Okay. So I...that's fine I got to the point. Now, when you
4 called up the power operated relief valve temperatures on the computer
5 did you call up on the demand log? You said you called this out?
6

7 BRYAN: Yes.
8

9 HUNTER: Okay. So the numbers that you called up are available and we
10 have been through the particulars.
11

12 BRYAN: I turned them out twice probably within twenty minutes, maybe
13 even three times while I was there in the morning. Twice within twenty
14 minutes or so I believe.
15

16 HUNTER: It's...would you know the time frame that you printed them out?
17 You guys don't initial the log, so I can't tell who prints out what.
18 Was it within the first half hour or maybe an hour ah, of the when you
19 came over?
20

21 BRYAN: Within an hour.
22

23 HUNTER: Can you key it to an event. Were you doing something when
24 the...?
25

683 211

1 BRYAN: It was after I noticed the drain tank was empty.

2
3 HUNTER: Okay. So it would be fairly quickly but not within the first
4 ten minutes or so?

5
6 BRYAN: Oh, no.

7
8 HUNTER: Okay. Reactor coolant flow was decreasing fairly quickly into
9 the event apparently it started decreasing. Did you review the reactor
10 coolant flow and watch it as...you know, discuss it with the... Bill
11 Zewe or any of the other people in the control room?

12
13 BRYAN: Yes, Mike Ross was there by this time I think also.

14
15 HUNTER: What was your impression of the flow decreasing?

16
17 BRYAN: We didn't really know right off...you know.

18
19 HUNTER: Okay. Now I'm gonna ask you again, I want you to be very
20 honest because I want the information. I want to go back and key that
21 you had a high pressurizer level, okay? And I want to also go back and
22 say did you review the reactor pressurizer pressure, the reactor coolant
23 system pressure, did you look at it during the time that you were there,
24 like between well, I think you left somewhere around whatever, 9 or
25 9:30?

1 BRYAN: 6:30.

2
3 HUNTER: That's right, 6:30. Did you look at the reactor coolant pressure
4 during that time?

5
6 BRYAN: Yes, we did and all I could say, at first we didn't know, and we
7 thought maybe we were getting to a point where the temperature was too
8 high for the pressure and we were starting to cavitate the pumps. They
9 were forming steam in the pump cavity or something, or net positive
10 suction head wasn't enough at this temperature for the pumps to operate
11 properly.

12
13 HUNTER: Okay. Do you have curves available to you to use...to look
14 at... to give you an idea about where the pressure should be versus
15 temperature?

16
17 BRYAN: We have our heat up and cool down curves.

18
19 HUNTER: Did you look at any of those, or was anybody looking at them
20 that you were aware of?

21
22 BRYAN: If I remember right we were already outside the curves so we
23 weren't looking at any.

24
25
683 213

1 HUNTER: But you were aware, you were aware that you were outside the
2 curve? How did you find out, how did you determine that? Was it automatic
3 because you know the curve or the temperatures?
4

5 BRYAN: With the temperature we were at and the pressure we were at we
6 knew we were outside the curve.
7

8 HUNTER: Okay. What does that mean to you being outside that curve?
9

10 BRYAN: In relationship to what, you know, the reactor coolant pumps?
11

12 HUNTER: Uh, that's part of it.
13

14 BRYAN: See the heatup and cooldown curve is based on alot of different
15 things and it's just...it's one...it's compiled into one curve but each
16 line has different meanings.
17

18 HUNTER: I understand. Do you have in fact like a...I'll look at you
19 and I can talk and I'll draw a picture with my hands but the left hand
20 line of course is the nil-ductility transition limit, okay? And if you
21 go all the way over to the right hand side of the curve, there's a
22 saturation limit curve that's over here.
23
24
25

683 214

1 BRYAN: Right.

2
3 HUNTER: Now there's pin compression limits and pump limits, whatever
4 inside of that but what does that...you're actually outside of your
5 saturation limit. What does that mean to you?
6

7 BRYAN: Oh, we could be forming steam bubbles. We could be forming
8 steam at that pressure.
9

10 HUNTER: And the reactor coolant pressure at that time was...ah...it
11 varied around by 1200 pounds, 1000, whatever it was.
12

13 BRYAN: Yes.
14

15 HUNTER: Okay. And the pumps were still on, okay?
16

17 BRYAN: That's true.
18

19 HUNTER: Flow was down but, and the auxiliary ... the emergency feedwater
20 system was functioning if you will and you were releasing steam to the
21 atmosphere. So you were fairly stable from that standpoint, but the key
22 issue that keeps coming back to me, okay, is that the pressure was low
23 and if you take ah...if you take the Tavg and walk over to 545 when at
24 that time you were about at 1000 pounds and go up and take your xy plot
25

107-015

1 and ... it would put you outside of that ... or, you were moving right
2 around the saturation.

3
4 BRYAN: Right.

5
6 HUNTER: Did you discuss that with anybody or did anybody come up and
7 discuss that with you? Do you recall any detailed discussion of it or
8 comments by anybody?

9
10 BRYAN: No, I don't recall any detailed discussion of that. It was
11 mentioned and that's all I remember.

12
13 HUNTER: Okay. The reactor coolant flow decreased and the shift ended
14 up taking off two pumps and they took off the B pumps leaving the A on
15 and this was my understanding is due to spray. Is there any other
16 reason that you know of that you would pick the B rather than the A?

17
18 BRYAN: No. You need the spray. No, I don't know any other reason.

19
20 HUNTER: Okay. I don't either, I just want to make sure that I'm finding
21 the key to ... going to get all the information I can. Ah, were you
22 there when they secured the last two pumps?

23
24
25
683 210

1 BRYAN: What time was that?

2
3 HUNTER: Ah, well the first two went off 74 minutes into the event which
4 would be slightly, you know, would be past 5 and then the next one went
5 off at 100 minutes which was right before 6.
6

7 BRYAN: Yes, I was there.
8

9 HUNTER: Okay. One of the discussions that apparently went on or it
10 appears to have gone on was going on natural circulation when you take
11 these reactor coolant pumps off. Give me a feel about natural circula-
12 tion and what you...what, your understanding of natural circulation, and
13 what's required to go on natural circulation. Besides the fact that you
14 turned the pumps off when you were there, but look ... go through a
15 little bit of your understanding. I'm not the ... I'm a B&W expert now,
16 I guess, but give me your feel for the natural circulation requirements
17 and talk procedure if you want to, I don't mind you talking about a
18 procedure at all, and talk ... whether or not you had a procedure in
19 your hand or whether or not you saw somebody with a procedure.
20

21 BRYAN: I don't recall seeing anybody with the procedure at this time.
22 I'm not saying they weren't.
23
24
25

685-21

1 HUNTER: No, I understand.

2
3 BRYAN: But ah, because by this time...

4
5 HUNTER: You didn't have one.

6
7 BRYAN: No, I didn't have one. There were quite a few other people in
8 the control room by this time and I know the problem was to turn the
9 reactor coolant pumps off and to go on natural circulation but I know if
10 the steam bubble was in the top of the steam generator, which we didn't
11 know at the time, you can't get natural circulation very well if you
12 can't get flow around the whole loop and I guess that's what we had at
13 this time and natural circulation doesn't work as well without it.

14
15 HUNTER: Is there any requirement to raise steam generator levels prior
16 to going on natural circulation?

17
18 BRYAN: Oh yes, you have to be at 50 percent. Well, I don't know if it
19 is required before you secure the pumps. The emergency procedure is if
20 the ... all flow reactor coolant pumps trip the steam generators go on
21 level control at 50 percent, through the emergency feedwater valves.

1 HUNTER: And that's 50 percent on the...which range?
2

3 BRYAN: 50% on the operating range.
4

5 HUNTER: 50% on the operating range. What would that give you on the
6 startup?
7

8 BRYAN: 95%.
9

10 HUNTER: 95%? Good enough.
11

12 BRYAN: The emergency procedure is probably written for operating at
13 some percent power when the steam generators are already higher in that
14 level or around that level.
15

16 HUNTER: Okay.
17

18 BRYAN: So if you would lose all four reactor coolant pumps you already
19 have your...the level established in the steam generators.
20

21 HUNTER: Let me go back when...were you there when they secured the
22 first two pumps?
23
24
25

683 219

1 BRYAN: Yes.

2
3 HUNTER: My understanding now is that they were trying to protect the
4 pumps and if I'm wrong tell me.
5

6 BRYAN: That's true.
7

8 HUNTER: The pumps were vibrating and they were making noise. They were
9 vibrating, the rpms were varying, they were getting ... the computer was
10 printing out alarms on another backstop all pressure, etc., etc., so you
11 guys had indication that the pumps were in fact under stress.
12

13 BRYAN: Right.
14

15 HUNTER: And so the first two pumps you secured, the B pumps, was anybody
16 or do you recall watching the B loops the steam generator what the
17 actual loops did at that time? Was anybody watching that particular
18 parameter?
19

20 BRYAN: No. Not that I know of.
21

22 HUNTER: I can indicate to you by the charts and the graphs and review
23 the event that when those two pumps were secured no backflow occurred.
24 Not one smidgen occurred. Now if you secured two pumps and you still
25

683 220

1 have two running and there is no backflow, what would that indicate to
2 you?

3
4 BRYAN: You say I have no backflow through the tube operating under its
5 coolant pumps?

6
7 HUNTER: Through the two secured reactor coolant pumps, the two that are
8 down. No backflow at all through the B generator when they took that
9 off...when they took the B pumps off...they just died. That loop just
10 died.

11
12 BRYAN: That would indicate that it's got a steam bubble on top the loop
13 and you know the water can't flow the whole way through.

14
15 HUNTER: Okay. I want to make sure. I'm not used to the J-leg type
16 generators but looking at the...you take off two pumps in a solid system
17 you would expect backflow and that generator would in fact steam some
18 and it would come to equilibrium and you would be sitting. You indicated
19 that you picked up procedures when you came to Unit 2. Do you recall
20 which procedures, emergency procedures that you reviewed?

21
22 BRYAN: Turbine trip and reactor trip.
23
24
25

683 221

1 HUNTER: Were there any others that you reviewed?
2

3 BRYAN: No.
4

5 HUNTER: Okay. Part of the turbine ... reactor trip procedures, I think
6 in both of them requires a sample to be taken on the reactor coolant
7 system after the trip. Did you, were you involved in that particular
8 request?
9

10 BRYAN: Yes, more or less. It might have been done by someone else also
11 but I happened to see Dick Dubiel, he's the Chemistry Supervisor, he's
12 the HP and Chemistry Supervisor, and I said you know you got a requirement
13 here for a greater than 15 percent power change, you have to take a
14 sample, and he says yes. Whether someone else had told him that before
15 or I was the first one I don't know.
16

17 HUNTER: Did you get the results back on the samples while you were
18 there?
19

20 BRYAN: No. I was sitting in Unit 1 when they took the samples. That's
21 when we found out that we had some problems.
22
23
24
25

683 222

1 HUNTER: Okay.

2
3 BRYAN: Cause the sample lines run into Un't 1, they come by the hot
4 machine shop and into the sample room and when they put the thing on
5 recirc we got the high radiation alarms in the hot machine shop and the
6 sample room.

7
8 HUNTER: Okay. What about the boron concentrations? Were you there
9 when an earlier sample was taken? I'll go a little further. The situ-
10 ation that you are talking about occurred after the pumps were off,
11 okay, but apparently somebody requested that the chemistry lab place
12 the... obtain a boron sample for the shutdown margin check and the
13 calculation for restart, whatever the requirements are, and they put it
14 on recirc early. There was no radiation problem at that time.

15
16 BRYAN: Early, what do you mean?

17
18 HUNTER: That was at 4:45 or so and you got the sample about 5:00 and
19 then they called it into the control room and it was 700 parts per
20 million. Do you...were you aware of that particular number?

21
22 BRYAN: No. That's the first I heard that.

1 HUNTER: Okay. Well then the second sample was in fact later on, and
2 another sample, and Dick Dubiel had two people split the sample. Were
3 you aware of the results of that sample? That was after you left.
4

5 BRYAN: No.
6

7 HUNTER: Okay. When you were in the control room did you look at the
8 source range instrumentation, the intermediate range instrumentation?
9

10 BRYAN: No, I didn't.
11

12 HUNTER: Were you aware of any emergency borating that was going on?
13

14 BRYAN: No.
15

16 HUNTER: Okay. You were not involved in any discussion by the...taking
17 off the second set of pumps. Were you involved in a discussion as far
18 as natural circulation and the requirements? Do you recall discussing
19 that? Kunder was there, okay, Mike Ross, Bill Zewe...
20

21 BRYAN: Brian Miller.
22
23
24
25

1 HUNTER: Brian Miller was there?

2
3 BRYAN: Yeah. Right after Brian came in was when I went back to Unit 1.

4
5 HUNTER: Okay, I understand that.

6
7 BRYAN: And, no I wasn't involved in that conversation.

8
9 HUNTER: Okay. There was some discussion about ah, well let me go back
10 again I'm just trying to fill in some blanks, the auxiliary feedwater...I
11 mean the auxiliary steam system is used for Unit 1 for feedwater heating
12 I gather during the normal heatup. Unit 2 needed the auxiliary feedwater
13 for ah...to maintain a vacuum after they had tripped. Ah, and ah so
14 when Unit 2 came down you needed to from Unit 1 to supply them steam for
15 the vacuum. Did you guys get in a discussion at that time about supplying
16 auxiliary steam?

17
18 BRYAN: Yes.

19
20 HUNTER: Was it a, did you end up supplying steam to Unit 2?

21
22 BRYAN: Uh, huh.

1 HUNTER: How did you, how did you end up, I have got the impression from
2 some interviews and all that Unit 1...that there was some hesitancy at
3 first to supply steam and I guess that's the best way to rightly put it.
4 Did somebody, were you over in Unit...

5
6 BRYAN: You can't run both Units with one aux boiler and Unit 1 was
7 sitting at the point where we were about ready to go back on the line.
8

9 HUNTER: Okay.
10

11 BRYAN: And we were already heated up. The Unit 2 was down and we knew
12 it was going to be down for awhile. I'm speaking of a day or two at
13 least you know at this time, and the decision I guess was made, earlier
14 we will get Unit 1 on and we'll worry about Unit 2 later, but, as it
15 turned out during the course of the day and that we had to get turbine
16 seals on the Unit 2 for the cooldown, we...you know...we just took Unit
17 1 back to nothing and gave Unit 2 the steam.
18

19 HUNTER: Okay. Then do you recall...was the decision to supply Unit 2
20 steam while you were in Unit 2 or had you gone back to Unit 1?
21

22 BRYAN: I left Unit 2 early. The decision was Unit 1 gets the steam.
23
24
25

1 HUNTER: Okay.
2

3 BRYAN: And there was a couple of control room operators called and said
4 they want steam and I kind of ignored that and I forget somebody else
5 called up a couple of times and Mike or Bill or somebody called later on
6 and said we decided we are going to put the seals back on the turbine in
7 Unit 2 and this and that. So we started cutting back on the feedwater
8 heating in Unit 1 and we ended up cutting it back almost to nothing.
9

10 HUNTER: And then...Unit 2...then you were able to maintain better seals
11 and get the vacuum? In order to not dump steam to the outside that's
12 my understanding that they have to have one of these ...
13

14 BRYAN: You have to have a vacuum.
15

16 HUNTER: Gland seal steam system on a vacuum, okay. I have in fact
17 covered all the areas that I need to cover, do you have any questions or
18 is there anything that you would that you need...oh I have one more
19 question. This is sort of off the cuff. Jim Floyd was in Lynchburg.
20

21 BRYAN: Uh, huh.
22
23
24
25

683 227

1 HUNTER: And did he talk with you on the phone that morning?
2

3 BRYAN: Yes, he did.
4

5 HUNTER: What was the discussion? Did he ask you questions about Unit
6 2?
7

8 BRYAN: Uh, huh.
9

10 HUNTER: You were back in Unit 1 at that time if my time frame is right.
11

12 BRYAN: I don't remember the specific questions, but they had heard
13 about it down there and he had called and he wanted to know some temper-
14 atures, radiation monitor readings, and I gave him those numbers over
15 the telephone. He was down there with Bernie Smith and I guess some of
16 the head people from B&W were all sitting around talking about it.
17

18 HUNTER: Okay. I just wanted to make sure that that was the type conver-
19 sation you had. He wanted some numbers and you gave him the numbers.
20 Did you have to take any messages to Unit 2 or did you have to go to
21 Unit 2 to get any messages or it was it just a general conversation?
22

23 BRYAN: It was a general conversation at first and I gave him the numbers
24 off the top of my head that I had seen when I left there.
25

1 HUNTER: Did you have ... go and give him any more numbers?
2

3 BRYAN: Yes, I believe he did call back later on. Him or Bernie.
4

5 HUNTER: ...called and did they talk to you again?
6

7 BRYAN: Yes.
8

9 HUNTER: Okay. Did you end up in Unit 1 the rest of the day?
10

11 BRYAN: Yes.
12

13 HUNTER: You didn't end up back in Unit 2 at all?
14

15 BRYAN: No.
16

17 HUNTER: In Unit 1 then were you with Greg Hitz I think, or some of the
18 fellows who were over there in a support function as far as supporting
19 Unit 2?
20

21 BRYAN: Well, yes.
22

23 HUNTER: Right, okay. And what did they do with Unit 1 during the day?
24 Did it stay in hot shutdown or did you fellows go in and cool it down?
25

1 BRYAN: I don't remember if we cooled it down that day or not. We
2 cooled it down that day or the next day.

3
4 HUNTER: Okay.

5
6 BRYAN: I don't remember what day it was.

7
8 HUNTER: Did you make any tours into Unit 2 at all? I know Greg Hitz
9 ended up going in with an auxiliary operator and doing some tours. Did
10 you do anything like that?

11
12 BRYAN: No, I didn't.

13
14 HUNTER: Okay. Any other areas of interest that you can think of that
15 we need to that...you need us to look into?

16
17 BRYAN: No. The rest of the day I spent, was all in the Unit 1 control
18 room, other than that, that's about it.

19
20 HUNTER: Okay. Alright. I don't have any further questions. Any of
21 you have any comments at all? If not then we'll...

22
23 SINCLAIR: Thank you very much Mr. Bryan for coming down. The time is
24 presently 4:11 p.m. At this time we will conclude the interview.

25 Today's date is May 16, 1979.