

ORIGINATING OFFICE NRR

AUTHOR _____

DATE:(or time period covered) 2/28 - 4/6/79

DESCRIPTION OF DOCUMENT CONTENTS: HANDWRITTEN AND TYPED NOTES RE GENERAL INFORMATION IN HANDLING TMI ACCIDENT

OTHER IDENTIFYING PARTICULARS: _____

7906070030

227 307

P

230 KW
A-690
T4 KW

@ 6 PM

499-8070

3/31

4 x 2.5 MW at Navy Shipyard

2 days or less



4/15/59
6.9

Miles	Naval Reactor	TM
3-1500 KW	4 KW	with switchgear

at West Milton

not in use among
few bed trucks

8 x 2000 KW, 4 KW Gas turbine

3 - California steel mounted
can be air lifted
operates with them

3 - Norfolk Naval Shipyard
good availability

2 - On tracks Rockwell
N. Carolina 1 day to
delivered

227 308

C

Gabor Tick

8

4/2 4:30 a.m. Ross

Have taken worst gas sample - no analysis yet
local anal for H_2 \rightarrow Better
25 cc sample reads 2 R/hr
Noise analysis - B&W tracking bubble
with it - gump in charge of analysis
say you can't conclude from noise
analysis that bubble is gone

Denny & Ashok bubble calculation (same
simple one as before)

Hanauer worried over pressure trace
Bob Kryter at ORNL was contacted by Ross
Gil Ziegler is SAI expert on site - still simple OK
The two are to consult ^{Robinson} (Kent Ackerman & Fry)
Kryter will in turn consult experts & one of
more will come up to review data
concern is with low pressure rising
on reactor pressure - plant computer
sees same thing - QA of noise
monitor confirms inst. OK

Space recombiner location is known to
the utility - ready to ship

Flow transmitter in idle hot leg
has gone bad - only one in that leg
Flow trans in operating loop is OK
B&W has advised that other instruments
can be predicted to ~~be~~ begin to fail
about now, including purifier
pressure & level.

Can't work in present mode w/o
level $\circ\circ$ procedure developed to
go water solid and vent in

227 309

POOR ORIGINAL

HPSTIS - don't know if RCP would
be run - Asbeck checking on status of
procedure - ^(in midst of writing now) NRC hasn't reviewed
app'd - level indicator is in a
more shielded position.

Warren Owen coming to trailer sat
am to discuss strategy.

primary pump OK, TCs OK

Personnel Side

Ross & Grimes favor rotation

Helps NRC safety expertise

People would go straight back to
Op Center in Bethesda

Grimes & Ross could switch
Tedesco & Volmer

People here want to know how
long they'll be here

Require at least as many as we
have here now

12-12 cycle is good (really 19 on - 10 off)

Israel & Novak could trade

Hannauer, Davis

Loose

Should NRC have a focal point for
the 60 man advisory group
(e.g. Ross)

NRC
counterpart
from
SD 7 talk
to Grimes

licensee asked last night for help in
decontamination - beyond their
expertise - Joe Deal of DOE with
HP consultants on the way to
appraise the problem and see if
DOE or DOD can help.

727 310

POOR ORIGINAL

4/2 Comack 6:10 a.m.

wants to call Comack ^{to} know
wants to know what ^{the} line is
for his press ^{and} when he
shows up here ^{check} for
story ^{consider}

*

LVG wants some stories in DC ^{if} it is gone
to know others say it is not
what NCC story is

4/2 Denton 11:00 a.m. press ^{and}

we are ^{supp} encouraging
sales to ^{get}
no #s put out ^{get}
bullet size ^{is} the interest
needs

RTM at press ^{and}

5:40 a.m. Mosely both
ruffled feathers ^{sample}
all requests for ^{should}
be funneled ^{to} command
center at ^{center}

56.1 H
43.9 N₂
no oxygen

227 311

POOR ORIGINAL

File
general
info

Summary of 4/6 day shift @ - 4/6/79 - 9:00 pm

- ✓ Waste Gas Decay Tank transfers started about 11:00 am
- ✓ Agreed on NRC reps in control room
- ✓ Agreed on NRC organizational structure in Bethesda & Site
- ✓ RCP 1A tripped, 2A started.
- ✓ Prepared NRC manning profile for command, operations, and technical review. Prepared Deaton Memo
- ✓ Ybarondo on board & working for Ross
- ✓ Leak in Heise Gage fixed
- ✓ original Pz level transducer resuscitated - others have noise, however.
- ✓ Ross Ordered 3 - Whole Body Counters
- ✓ Ross has Ybarondo pulling all nat'l lab work together in a schematic form as of 4/7 am.
- ✓ IRS - coming Monday

POOR ORIGINAL

227 312

POOR ORIGINAL

file
general
info

4/6 7:20am

people into CR - need list - Novak
Guy Holman at IAG needs to communicate
industrial waste purged 1:30-3:30
2nd & 3rd level ~~is~~ instruments OK
Heise Gay is leaking (elbow?)

*

{ B tank valve wouldn't open
A tank leaked - will they now go to MUT and
hydrogen or my derm in contain

* confirm

plans to spray Aux w/ ~~the~~ Sodium Hydroxide
transferred water to unit 1 - will tell us ^{need} it
Noonan report on SG

rechecked dedicated OS lower in storm/lost air
up to 2100 man rem integrated dose
work during note is dull shift sched

*

need
decision
today

{ Case wants to review systems changes in X
Deufen will talk w/him
we need to get geared up today to review
in one place or another
press conference at 4:00 - Vic will do directly

*

need plan for people changes

Status

10:00 AM

Activation time for H₂ Recombiner Midnight

O ₂	18.1	N ₂ 79.5	13:30	H ₂	2.1%
			15:00		2.0%
	19	78.8	18:00		2.0%

850

H ₂	2.4
O ₂	18.1
N ₂	78.5

Now

2.2
19
78.8

1330	2.1%
1500	2.0%
1800	2.0%

3:30 AM 4/2

Recombiner ready and
can be available in hours

POOR ORIGINAL

227-314

1000 ft³ @ 875 psi 1×10^{-4}
 300 °F 2'

if all
 gas in
 vessel is
 H₂!

$$\frac{P_1 V_1}{R T_1} = \frac{P_2 V_2}{R T_2}$$

15 psia
 100 °F

$$\frac{890 (1000)}{760} = \frac{15 (V_2)}{560}$$

$$V_2 = 4.37 \times 10^4$$


$$210 \times 10$$

$$2.4 \% H_2 + 2.1 \times 10^6$$

$$+ \frac{5.04 \times 10^4}{4.37 \times 10^4} H_2$$

$$+ \frac{9.41 \times 10^4}{2.1 \times 10^6}$$

$$= 4.5 \% H_2$$



U

POOR ORIGINAL

227 315

STATUS 4/1

Info 5:45 Pm
10 Pm
10:45 Pm

Activation Time for H₂ Recombiner Midday
Containment Conditions

NOON	H ₂	2.2%
	O ₂	19%
	N ₂	78.8%
1330	H ₂	2.1%
1500	H ₂	2.0%
1800	H ₂	2.0%

11:05 Pm ^{RES} Bettis Analysis was in error
Brown line is 1750 PPM and not 875

11:15 22:55 Bubble Size 298 ft³

12:20 Reviewing Recombiner Activation Plans
Comments prepared - Expect to be ready to agree on revised procedures in about 1 hour.
Met. Ed is ready to go except for leak test.

Single Recombiner to be tested
quick isolation from Control Room
Start Recombiner - 1st MSmt. Approval
Don't expect to begin operation until ^{next shift}
Recombiner Next up time - 3 hrs.

POOR ORIGINAL

227 316

Unit 2 CR intake Monitor (Kv)

330 AM - 400 cpm

10 AM - 2000 cpm

1300 - 500 cpm

IE was over on evidence of a

release. No evidence of chattering

relief valves, etc.

Time Sensors

~~4. 10/11/2~~

Lost Parts Monitor

1. Control all
Fuel to bed
dumps a point
around DOD
FDE,

McCabe uses us a Red Saver

2. Any slugs
will be
you -

1.711
16.5% O₂

Quality of Waste Gas
line A contains water

Rod samples

Belt's

6.970 of 7₍₁₃₎ in can

6.070 of 13₍₁₃₎

.0033% SV 89.9°

71 U

Ca 134 20%

Ca 136 2%

137 1.7%

Bay 140 06%

not a
lot of fuel
melted

POOR ORIGINAL

APR 1 1979

This table includes a number of assumptions about activity and weather. These assumptions have been chosen conservatively. In an actual release, the release rate and weather should be evaluated as they are at the time, and the decision based on those values.

227 319

U

Event - Spontaneous failure or decision to perform a potentially risky maneuver

Find out what actually happened and what is functioning.

Predict what could result - different likelihoods

Predict release rate

In tables

Determine present weather and forecast

Assumed constant
in table

Dose Prediction

In table

Action Guidelines

Per Appendix 7

227 320

EVENT	EXPECTED PLANT RESPONSE (RANGE?)	RELEASE AND TIME	WARNING TIME	EVACUATION SCENARIO	WHO DECIDES
1. Loss of vital function or decision to perform a potentially risky maneuver. Examples	Restore Function Within 1 hour	No significant change		None*	
	Switch to Alternate Function involving Pri Coolant in Aux Building	Small leak less than 1 gal/hour		None*	
		Large leak in Aux Building 50 gal/min	2 hour	Evac 2 miles Stay Inside to 5 miles	
1. Reactor Coolant Pump Trip. 2. Leak in Aux Building. 3. Loss of off-site power 4. Loss of feed-water 5. Depressurization to go on RHR.	Failure to restore vital function	Core melt; see item 2 below & Appendix 1		*For sufficiently risky maneuver, do precautionary evac 2 mi and stay inside 5 mi; whether to do this or not depends on details of maneuver and plant situation.	

227 321

EVENT	EXPECTED PLANT RESPONSE (RANGE?)	RELEASE AND TIME	WARNING TIME	EVACUATION SCENARIO	WHO DECIDES
2. Core Melt	Maintain Containment Integrity (likely) with Containment Cooling	Tech Spec Containment Leak Rate	4 hour	Precautionary Evac 2 mi all around and 5 mi sector; stay inside 10 mi	
	Containment Breached	Reactor Safety Study Categories PWR 4 - See Appendix 1	24 hour	Evac 5 mi all around and 10 mi sector, stay inside 15 mi	
3. Hydrogen Explosion Inside Reactor Vessel	No significant change in reactor or primary system	No significant change		None	
	Core Crushed (unlikely)	Core melt See Item 2 & Appendix 1			

227 322.

Major sequences evaluated here are tied to the loss of forced circulation in the RCS. The loss of flow from the reactor coolant pump (RCP) is the generalized initiating event from which other initiating events such as loss of offsite power can develop.

loss of PORV

APPENDIX 1.a SEQUENCES OF POSSIBLE SYSTEMS FAILURES

Figure 1.b-1 shows the loss of RCP event tree. This tree shows the various options available given the loss of the RCP, and indicates which combinations of events or failures would lead to core meltdown (CM). The sequences denoted with an asterisk are those which would be expected to follow the core meltdown progression discussed below, leading to the variety of atmospheric radioactive releases and consequences discussed later. Some core meltdowns could be expected to be delayed for roughly a week because of the availability of ECC injection over that period. This method of core cooling, however, is not expected to be adequate to prevent core melt; as such a core meltdown is assessed to occur at roughly a week. A rough measure of relative probabilities of the various outcomes is indicated by the notation of L, M, H (low, medium, high). The column on the right-hand side of the page indicates the relative probabilities of the sequences, with "LM" as the highest probability and L³M as the lowest.

Sumps because unavailable
 DSS/DCK agree in a week we could get around this but release would be vast
 because of debris in a n.bldg.


3 sequences loose sump
 1 sequence loose RCP

assumed that would not be effective - if it were it adds conservatism

Fig 1.03-1 Loss of Reactor Coolant Pump

Start
other
RCP.

LPSI HPSI
ERV opens
SV opens
Pump
bleed
Pump
available



Loss of RCP

227 324

MAJOR EVENTS AND TIMING IN EVENT OF CORE MELTDOWN

Event 1 - Sprays and Coolers Operative

Time=0 Flow stops, core and water start heat-up

Time=100 min Core starts to uncover

Time=150 min Core begins to melt

Time=200 min Molten core is in lower head of reactor vessel, pressure is 2500 psia

Time=210 min Reactor vessel fails, containment pressure goes to 25 psia

Time=210 min Hydrogen burns, containment pressure goes to 67 psia
Steam explosion possibility - minor consequence

CONTAINMENT SURVIVES (Failure assumed 130 psia)

Time=10 hours Molten core has melted about 1 meter into basemat

Time=days Major problem - handle hydrogen, oxygen - maintain containment integrity

CAUTION: - Keep sprays running
- Keep water many feet over molten debris
- WITHOUT RECOMBINERS Hydrogen continues to build up

BASEMAT SURVIVES

Event 1 Conclusion: This event should not produce major releases

Event 2 - Sprays and Coolers Failed Before Flow Stops

Time=0 to Time=210 min Same as Event 1 - containment pressure is 25 psia

Time=810 min Containment pressure is 70 psia

Time=1 day Containment fails due to steam (mostly) overpressure - about 135 psia

CONTAINMENT FAILS

Event 2 Conclusion: This event leads to major releases.

227 325

The event tree for core melt leading to various releases is shown in Figure 1.b.

The following are essential in the event of core melt.

1. Sprays and coolers are required to prevent major releases.
2. Hydrogen must be recombined or otherwise removed from containment.




FIGURE 1.b

1c. Large Leak in Auxiliary Building (AB)

The activity level in the reactor coolant is so high that substantial releases can come from small amounts spilled in the AB which requires once through ventilation. A leak of 5 gpm to the AB atmosphere is assumed for the expected level of leakage. A leak of 50 gpm is taken as a large leak to consider a major leak in pump shaft sealing or some similar mishap. Based on the leakage experienced already only the noble gases and no iodine are assumed to evolve. The AB ventilation exhaust is assumed to flow through the charcoal filters.

1d. Hydrogen Explosion in Reactor Pressure Vessel

A detonation of the hydrogen oxygen bubble in the reactor vessel could rupture the vessel and/or crush the core. Rough analysis indicates that the pressure vessel would not rupture. Postulation of the core response is difficult. If the core is crushed, it could effectively prevent core cooling leading directly to the core melt sequence described earlier. It is unlikely that compression would lead to criticality.

Action Alternatives	Evacuation	Stay Inside
1.		2 miles
2.	2 miles	5 miles
3.	2 miles all around 5 miles 90° sector	10 miles
4.	5 miles all around 10 miles 90° sector	15 miles

- a. All sector choices governed by wind direction. If shifting, more than one quadrant may be affected.
- b. These are initial values; as the release continues measurements may indicate the need for reconsideration of action up to 20 miles.

227 329

6. Weather

The table is based on F stability and 1 m/sec wind speed, in view of the April 1-3 forecast. At the approach to decision time for evacuation, the appropriate met. condition will be factored into the dose equations to determine the evacuation time, sectors, and distances for the evacuation.

NRC is predicting X/Q for current meteorology as the incident progresses.

227 330

7. Action Guidelines

- a. Notify evacuation authorities two hours in advance to standby for a possible evacuation.
- b. Predicted doses of 1R whole body or 5R thyroid in 8 hours - mandatory evacuation of children and pregnant women.
- c. Predicted doses of 5R whole body or 25R thyroid in 8 hours - mandatory evacuation of all persons.

Assumes general warning already that some form of evacuation may become necessary.

227 331.



Telford

492-8160
 Jim Moore GPU - Control Room

B&W - formula for computing bubble

Billy Bingham

804-384-5111

Ext 2196

1- 5 min of Syst. Status data to assume steady state

2- press $P_{press} + 75 \text{ psi}$ use tank

NOTE if level $< 1.50 \text{ m}$, stop test.

3- 5 min of data at $P_0 + 75 \text{ psi}$ & 1 min intervals

P_{press} , Level, T_C

T_{press} , let flow } or 1/2
 make flow } Tank
 seal surface } level

227.332 Mandan SG level constant, 0

Deery NT

Frank Miraltea phoned in
data from Annie Pickings.

4/1 4 PM

Deery H. 0.21 % Power (2772 MW)

4/4 4 AM 0.15%

4/11 4 AM 0.09%

227 333

(1)

4/11/79

RB atmosphere sampling procedure

800 ft³ @ 1000 psi & 270 °F

$$\frac{960}{750} R = 400K$$

$$M = \frac{PV}{RT} = \frac{(1000)}{15} \left(\frac{800 \text{ ft}^3 \times \frac{2838}{100}}{750} \right) \frac{7.60}{0.092 \text{ liter} \cdot \text{atm} / \text{mole} \cdot \text{OK}} = 4.6 \times 10^4 \text{ moles}$$

H₂/O₂/Ar

9:45

3:00 1.9/21.2/76

7:00

$$4.6 \times 10^4 \text{ moles} \times \frac{46}{50}$$

Vol + conc of water dry pumped to imp from

$$= 4.4 \times 10^6 \text{ g}$$

Red field for recombiners

$$V_d = 6 \text{ and } 9 \text{ ft}^3$$

$$= 4.4 \text{ MT of } \text{H}_2\text{O}$$

9 ft³

	nCi/ml	DCF	= R/sec	
Xe - 133	675	0.00406	6	166 Ci
133	15.8			
- 135	8.1	0.0567	0.46	
I - 131	0.063	6.0272	0.006	
I - 135	0.05	0.154	0.005	
			6.5	

3 bleed tanks filled - low conc tanks in 2

pump unit 1 1100 ft³
10⁻² nCi/cc

condensate storage tank 16⁴

4 mR/hr through dome

2000 R/hr inside

3 1/2 ft of concrete

3 mR/hr

10.4 R/hr

$$R = \frac{22.4 \text{ liter} \cdot \text{atm}}{273^\circ} = 0.082 \frac{\text{atm} \cdot \text{liter}}{\text{mole} \cdot \text{K}}$$

200 R/hr at surface
10-30 R/hr at 1 cm

can recombiner be best tank
drain from recombiner

227-334

Control Center 492-8111 Tom Telford
Copy of Plans / Marsh 492-8060
Zollman in office

① Bibble Process

② NaOH Tank level change ^{not added}
How long snapp on? 6 min

③ Matt Taylor call Tedesco ~~2778~~ 27783

Letdown path concerns

goes to Reactor Block holdup
varies with pressure in this cracked
where are they getting to low rate
where are they getting the flow rate

FACS NO. 492-7928 Bethesda
944-2483

Activation Time for Recombiner - 1200

cracked vent valve - constant since Friday AM @ 3:00
IRCP

1st or 2nd
3rd or 4th
5th or 6th
7th or 8th
9th or 10th
11th or 12th

RT
5000 gal
114-200 gal
114-1 gal

227 ~~336~~
335

$$0.045 \frac{\mu\text{Ci}}{\text{ml}} \times \frac{50 \text{ ft}^3}{\text{min}} \times \frac{28500 \text{ ml}}{\text{ft}^3} = 8.9 \times 10^4 \mu\text{Ci}/\text{min}$$

$$\frac{8.9 \times 10^4 \mu\text{Ci}}{18 \text{ s}} = 4900 \frac{\mu\text{Ci}}{\text{s}} = 10.9 \frac{\mu\text{Ci}}{\text{s}}$$

1500 hrs 224 ft³ in bubble normalized to 875 psig

1700 hrs 340 ft³

Bobby Joe Davis - DOE

in NRC trailer other side of
I.E. trailer

ORNL wants to know if they can get
hydrogen analyzer back

$$\frac{13 \times 10^3 \mu\text{Ci}/\text{ml} \text{ to } 10^5}{0.63 \mu\text{Ci}/\text{ml} \text{ in air}} = 2 \times 10^5$$

equip hatch + personnel access hatch need p

50 mvr/hr

area monitor 10 mvr/hr

227 ~~330~~

336

C

3-31-79

HLD briefing JEC

need expert technical help
J. West, F. Stern CE

H₂ assistance

what if H₂ explodes in vessel head?

should we evacuate?

RJM says: not enough O₂ for explosion

pressurizes bubble - is it
changed? METED says yes
We say nay

Important changes
in process cleared
with us

Need sample from tank

Not yet recombering
- still shudding

Need diesel 5th power
from NR

Off Site power dedicated to here
227 ~~531~~ 331

10 H. DENTON

IMPORTANT!

From: JOHN R. JOHNSON
MANCHESTER Ohio
DATON Light & POWER PLANT
TELE NO. 1-513-549-2309

227 ~~338~~
338

THE FOLLOWING INFORMATION WAS QUOTED OVER THE TELEPHONE BY JOHN R JOHNSON TO THE OBSERVATION CENTER FOR MR. H. DENTON.

QUOTE: WE HAVE CAMERAS TAKING PICTURES OF UNIT giving PROBLEMS WITH 2 LARGE ILLUMINATING LIGHTS. WE HAVE A DOUBLE WINDOW IN THE TOP OF THE CHAMBER WHERE THE CAMERAS LOOK THROUGH. THERE IS ANOTHER WINDOW IN THE RADIATION SHIELD AND IN THE BUBBLE CHAMBER WHERE THERE IS BOILING LIQUID H_2 INSIDE. WE HAVE A LIQUID COOLING TANK FOR THE LIQUID H_2 , WE HAVE A BEAM OF PARTICLES INSIDE MAIN CHAMBER. WE HAVE HEAT EXCHANGE WIRES INSIDE MAIN CHAMBER, THESE ARE OUTSIDE MAIN CHAMBER. WE HAVE A BIG BUBBLE AT TOP WHICH IS CAUSING OUR TROUBLE. THERE'S A VACUUM UNIT IN IT OVER HERE, WE HAVE A PISTON! THAT PISTON COMES UP FROM BELOW. NOW THIS IS ALL IN THE BUBBLE CHAMBER. NOW, AROUND THE WHOLE THING WE HAVE A LIQUID N_2 COOLED RADIATION SHIELD. WE HAVE AROUND THE WHOLE THING A 200 TON IRON CYLINDER SHIELDING THE SURROUNDINGS FROM STRONG MAGNETIC FIELD. NOW WHAT WE HAVE GIVEN YOU RIGHT HERE IS A LIQUID H_2 BUBBLE CHAMBER. THE CENTRAL CHAMBER CONTAINS H_2 MAINTAINED IN LIQUID FORM ABOVE ITS NORMAL BOILING POINT. THAT'S MAINTAINED BY THE PRESSURE OF A PISTON, THE MOMENTARY RELIEF OF THE PRESSURE LEAVES THE H_2 IN A SUPER HEATED STATE AND THE PASSAGE OF PARTICLES PRODUCES A STREAM OF

THIS INFORMATION CAN BE FOUND ON PAGE 375 - BOOK #3
OF THE ILLUSTRATED SCIENCE AND INVENTIONS ENCYCLOPEDIA.

227 ~~340~~
339

FLIGHT 3/28/79-1F

SHIPMAN/WATSON

TIME: 1600-1700

East edge of the plume was at Hummelstown, west edge at Rutherford Heights. Levels were about 0.2 mr at 7 miles north of plant. 0.1 mr at 16 miles north. Plume extended at least as far as the ridge to the north of Harrisburg. Flown at 150 to 1000 feet. No change in count rate.

FLIGHT 3/28/79-2F

SHIPMAN/WATSON

TIME: 1900-2000

East edge of the plume was at Rutherford Heights. West edge was at Camp Hill. Levels were slightly lower. Top of plume was at about 3000 feet.

FLIGHT 3/29/79-1F

SHIPMAN/WATSON

TIME: 1000-1100

West edge of the plume was at Mechanicsburg. East edge was at Hershey with the maximum at a point about 2 miles west of the river. The top was at about 3200 feet, the max at 2100 feet and the bottom at 500 feet.

FLIGHT 3/29/79-2F

SHIPMAN/WATSON

TIME: 1600-1700

The east edge of the plume was at Hummelstown. The west edge at Mechanicsburg at 10 miles. The maximum was about 0.2 mr. Near Hummelstown the top of the plume was at 1200 feet, the maximum at 1000 feet, and the bottom

at 800 feet. The plume/cloud to the north of the plant appeared to be dissipating and a new plume was forming to the south. At 1/2 mile south at 500 feet, the highest level was 0.5 mr. At the site boundary to the south at 500 feet the levels were 10 mr.

FLIGHT 3/29/79-3F

SHIPMAN/TIPTON/EICHER

TIME: 0700

Circled plant at a distance of 8 miles. Saw no plume; only residues of about 100 ^{mR/hr} ~~mR/hr~~ to northwest of airport.

FLIGHT 3/29/79-4F

TIPTON/WATSON

TIME: 2230-2330

Plume low and close to plant. Top at about 500 feet. Level at 1/2 mile of about 1/2 mr. Plume did not extend more than 5 miles from plant. Wind from 130 degrees at 8 knots. Ridge to northwest split plume with some trapped behind ridge and some going up river at very low altitude.

FLIGHT 3/30/79-1F

MAGUIRE/WATSON

TIME: 1030-1130

Maximum level of 20-30 mR at 300' altitude and 1/4 mile SW of plant. From 1/2 mile out plume is SE of plant. At 1 mile from plant highest levels are in the SW to the NNE. Approximate 0.5-1.0 mR/hr at SE. Top at 1 mile approximately 1500' altitude. Did not extend more than 5-6 miles in SE direction. At 1/4 mile 500' altitude 8 mR, W of plant.

227 341

FLIGHT 3/30/79-2F

SHIPMAN/ZICHER

TIME: 1600-1800

Plume is very narrow. Leaving plant on a bearing of 280 degrees. Hottest point near ground. Top at 1200'.

DISTANCE FROM PLANT (Mi)

Mr

1	9
1.5	8
2	8
2.5	8
3	7
3.5	4
5	2


Predominantly up river valley.

FLIGHT 3/30/79

TIPTON/WATSON

TIME: 2130-2230

Flew a circle around the plant at 1 mile out at 500' altitude and 1000' altitude. Cloud approximately 30degrees-40 degrees wide going to the NW. Maximum reading approximately 1/2 mR (with scintillation counter)



Flew altitude spiral from 1500' to 300' approximately 3 miles from plant at a heading of 330 degrees. Entered the cloud at approximately 1000', maximum at approximately 500', decreasing down to 300' where had to level off.



Flew a radial at a heading of approximately 330 degrees out from the plant. Seeing levels varying from 100 to 200 ~~μR~~ hr all the way out, 18 miles from plant until broke off line due to ridge. Radial flown at 500' altitude.

Flew half circle at distance of 5 miles out from plant. Still approximately 30-40 degrees wide. Altitude 500'.

227 342



Perform a circle around the plant at 1 mile out at 500' altitude, and 1000' altitude.





Wind out of 240 degrees

Flew a radial at 500' altitude in a direction of approximately 020 degrees out for 18 miles before breaking off. Did not run out of the plume. Levels were about 100 R/hr along the path of the plume. Measured approximately 20 degrees angular spread out at 18 miles as did at 1 mile.

Did an altitude spiral about 6 miles out from the site in a direction of 020 degrees from 1500' to 300'. Entered the cloud at 800'. Continued to increase all the way down to 300' where had to level out. Maximum reading at 300' was 150 R/hr.

Flew a circle around the plant at 1 mile out at 500' altitude and 1000' altitude.



Wind out of 245 degrees (25 knots) @ 500' alt.

227 343



Flew a radial at 500' altitude in a direction of approximately 060 degrees out for 20 miles. Plume extends past 20 miles. Narrow cone (approx. 5 degrees) at 14 miles had levels of 100-200 R/hr.

Flew altitude spiral at 2.5-3 miles out in a direction of 060 degrees from the plant. At 1100'-1500' altitude $\sim 20 \mu\text{R/hr}$ - 700' - 1100' altitude $30 \mu\text{R/hr}$. Sharp top between 600' and 700'. Levels rise to approximately 1 mR between 600' and 700' altitude. Stay constant down to 200' altitude.

FLIGHT 3/31/79

MAGUIRE/EICHER

TIME: 0600-0715



Ground winds 8 knots @ 245 degrees

Flew out along 050° radial. Levels dropped from 1 mR/hr at approximately 1.5 miles out and dropped to 100-200 $\mu\text{R/hr}$ at 13 miles. Levels stayed constant out to 30 miles from the plant. Top of plume is sharp at 600'. 100-200 $\mu\text{R/hr}$ levels were present to the ground. Width of plume appeared the same at 4 miles out and 20 miles out (approximately 2 miles wide).

All along plume top appeared at 600' with constant levels from 0-500' altitude.

FLIGHT 3/31/79

SHIPMAN/WATSON

TIME: 0900-1000

At 1 mile and 1000' plume was between 030 and 060 with maximum at 045 of 3 mR/hr. At 1 mile and 1100' plume was between 030 and 060 with maximum at 045 of 0.5 mR/hr. At 3 miles in center of plume top was at 800 feet and went to ground level. Dose rate nearly constant throughout value of 1 mR/hr.

227 227 344
34

At 3 miles plume was from 030-050 radial away from plant on 045 was 3 mR/hr out to 2 miles, 2 mR/hr at 3 miles dropped to 1 mR/hr by 10 miles.

Followed plume to Myerstown, about 22 miles where the level was about 0.1 mR/hr.

FLIGHT 3/31/79

SHIPMAN/WATSON

TIME: 1215-1330

No major change. No 1³¹. Plume at 500' and 1 mile between 030 and 060 maximum value of 1.5 mR/hr. At 3 miles plume between 030 and 060 maximum value of 1.5 mR at 300' top of plume at 2800' bottom on ground. At 10 miles maximum value of 0.2 mR/hr maximum at 1800'.

227 345

DOE
AND
NRC
TEAMS

1640	RT 441 + ENGLE RD	0.6	MP/HR.
1650	RT 441 + FALMOUTH RD	0.5	
1705	KEENE RD, 1/2 MI EAST 441	0.5	
1715	RT 441 AND KINGSD	0.12	
1720	AMOSITE RD .3 MI EAST OF 441	0.6	"
1730	RT 441 + 241	0.4	
1735	RACE ST AT MAYTOWN	0.17	
1740	STONE HILL RT 441	0.17	
1745	SAIN BRIDGE RD AT 441	0.2	
1800	INSIDE NRC VAN	0.15	
1930	RT 441 ACROSS FROM COOLING TOWERS	1.5	

MET. DATA.

1544	FROM 315°	12 MPH
1740	" 280	4-5
1829	" 135	2
1846	" 220	4
1900	" 225	2

ARMS FLIGHT REQUESTED AT ~1830

1945 DOE TEAM DEPLOYED ON WEST SIDE OF RIVER, NO DATA YET,
NEAR GOLDSBORO AREA


227 346

36 ENVIRONMENTAL STATIONS HAVE BEEN ESTABLISHED


1945 FUEL BLDG AREA MONITOR 140 MR/yr.

227 347

U



CONTOUR INTERVAL 20 FEET



— RAT - DOE
 - - - NRC

SITE TOPOGRAPHY 5 MILE RADIUS
 THREE MILE ISLAND NUCLEAR STATION UNIT 1



FIGURE 2-2
 (AM. 41 7-16-73)

227 348

Keferal Jim N.Y. Nat. Dietit

10:45
AM
4/1/79

Dr. Joseph Hanak
RCA Labs.

Princeton, N.J.

609-882-6906

Claims to be able to assist
in hydrogen gas bubble problem.
Apparently something about
synthesis of unsaturated
hydrocarbons. RI did not
talk to Hanak.

Transmitted to
Budnitz

4/1 2:40
PM

C

RECOM run
190/day - capacity

EMER POWER: ^{unit}
Navy 3 15 MW, 4KV diesel
on skills

need 54

ask Bettosta if needs
also 8 2 MW, 4KV gas
unit

no gasoline

Dedicated offsite power

Chirama 6 pm

In Core Probe & H-8
Nerheim will do meas

- (1) is channel damaged?
- (2) if peaks where is fuel

See Carl on Cont. Plans
Hulman

Is PORV, black valve on vital pipe - yes.


Time - Dep Bubble plot

Loose Part Monitor

LPM loose parts

sees any thing going on
noise is quiet

830 765



D-10	490.4	OF
E-11	421.4	
K-11	369.3	
H-5	289.6	
H-8	381.7	
E-7	337.5	
E-13	303.0	

Write His

I, E / MET ED - status in little work

SG-B fill ^{operation} water disconn w/ B&W in Area B

Did Hartne ever go out procedure for reconnection operation?

How get primary coolant sample, who wants them & how much?

	H ₂	O ₂	N ₂
H ₂ in contact 10:00	2.0%		
12:00	2.2%	19%	78.8%

Bubble Calc w/ GPU - H₂ change since 10:00 - 100

Measurement over 1 hr

1 change Press Press

no change to monitoring

4 men to P - add water - about same as

bubble shrinkage

Bubble should be gone by Noon 4/2

4-1-79 (2000-2400)

METEOROLOGY DATA

			<u>MONITOR</u>
2000	DIRECTION 036	SPEED 4 MPH	100 MR
2035	030	3	
2100	090	4	100 MR
2122	120	15	
2200	135	15-25	
2230	130	15-20	200 MR
2300	110	10-15	

PLUMB SURVEY

AIR GRAB SAMPLES TAKEN BY DOE #3 (CHARCOAL FILTER)
1843 0.2 miles NORTH OF 262 AND RIVER ROAD
RESULTS: NO ACTIVITY ABOVE BACKGROUND
MINIMUM SENSITIVITY: $2 \times 10^{-7} \mu\text{Ci}/\text{MR}$

1903 0.5 miles NORTH OF INTERSECTION 262 AND
RIVER ROAD.

RESULTS: NO ACTIVITY ABOVE BACKGROUND
MINIMUM SENSITIVITY SAME AS ABOVE.

MISC

2140

IT REPORTED INCREASE IN CONTROL ROOM
RESPIRATION LEVELS FROM 0.1 TO 1.0 MR/HR.
AIR SAMPLE STARTED. ATTRIBUTED TO WIND SHIFT.

1800 ARMS FLIGHT: 1 MR/HR @ 500 FT 1 mile FROM
plant.

227 353



Map shows areas within five- and 10-mile radius of the Three Mile Island nuclear power plant.

— TLD READINGS IN mR
AVERAGE TIME OF EXPOSURE 22.5 HOURS

227 354

U




4 PM

227 355

H₂ Problem

1. Venting Press. now raised
2. Off gas to cont. from let down tank
3. Hydrogen in containment ?
4. Radiolysis $\approx 45 \text{ H}^2/\text{hour}$
5. Continued M-W ?
- 6.

* When to activate the recombiner



this machine

227 357

C

Special Problems

— Boron concentration?

D.C.
Harwell

— How reliable are in-core TC

Richings

Can we local instability
due to point state flow?
Best estimate decay heat?

Develop better understanding
of events that have
occurred aimed at
evaluating core damage.

— Procedures for the explosion
vessel, pressurizer, containment

— Small portable filtration
for decay heat removal
pits. St Lucy has one

3/31/74

0500 - 0630

Tongue & Hunt

Wind direction & speed
from WSW @ 2 mph

All readings in micro

Security Building

Operating Floor of
Turbine Building

Service Building

Control Tower

Fuel Handling Building

Auxiliary Building

Auxiliary & Fuel
Handling Building

Reactor Building
Unit #2

Diesel
Generator Building

Turbine Building

227 35

SE-47

SE-47

SE-8

SE-5

1269

Sunny Morn.

Open Window

WEST WIND STATION
NORTH FLOOR PLAN
SHOWING CONTROLS AND
SERVICES BUILDINGS

↑ radiolink
↑ waste drums

0.5

1.7

0.8

1.0

0.1

0.3

0.5

2.0

1.5

1.5

2.0

0.5

0.1

1.0

0.7

1.0

0.3

0.9

0.3

0.6

0.4

0.3

0.2

0.2

10.0

7.0

1.5

1.5

0.1

0.1

0.1

0.1

0.1

0.1

0.1

0.1

0.1

0.1

0.1

0.1

0.1

0.1

0.15

0.85

0.15

0.15

0.15

0.15

0.15

0.15

0.15

0.15

0.15

0.15

0.15

0.15

0.15

0.15

0.15

0.15

0.1

0.1

0.1

0.1

0.1

0.1

0.1

0.1

0.1

0.1

0.1

0.1

0.1

0.1

0.1

0.1

0.1

0.1

0.1

0.1

0.1

0.1

0.1

0.1

0.1

0.1

0.1

0.1

0.1

0.1

0.1

0.1

0.1

0.1

0.1

0.1

0.1

0.1

0.1

0.1

0.1

0.1

0.1

0.1

0.1

0.1

0.1

0.1

0.1

0.1

0.1

0.1

0.1

0.1

GPU SERVICE CORPORATION

W. B. MURRAY

Venting Problems

Aux Bldg

1. Loss of off-site power
2. Spills
3. High rad. fields
4. Loss of crit. instruments + controls
5. Overlooked release paths
6. Component System Failures
7. Access (HydroAux) of Instrument Equipment

227-360








IMAGE EVALUATION
TEST TARGET (MT-3)










IMAGE EVALUATION
TEST TARGET (MT-3)











IMAGE EVALUATION
TEST TARGET (MT-3)



Loose Parts Monitor

- ① Bubble movement will be monitored + we will be alerted
- ② Any structural degradation will be monitored
- ③ Loose parts will be monitored

Now Very Quiet

RC pumps smooth

Not 47 - 3 egles of

- tip pumps

- more valves

- reduce pressure

Agenda Plan priorities

6:00 Bldg 26 of Pa Air NG



- ①
- ②
- ③

NRC ~~=====~~ Status of Plant that we understand

GPU Comment

Summary of Problems Areas

Zubrowski - Fuel situation & Hydrogen

Levinson - what do we know about current mode of cooling w/bubble

Owen - contingency for loss of current mode

interaction with NRC



- ④

Other Activities

Boron precipitation
Waste Management

- ⑤

Summary of Decisions to be made or information to be gathered

- ①

- ✓ Betts report on water chemistry
- ✓ ~~=====~~ Airborne gas sample in containment
- ✓ Recombiner status & plans (both installed, ^{shielded} not purged)
- ✓ Planning for transfer to decay heat
- ✓ H₂ bubble & O₂ evolution
- Environmental Qualification inside & outside containment