

TMI DOCUMENTS

DOCUMENT NO: TM-0644

COPY MADE ON 6/5/79 OF DOCUMENT PROVIDED BY
METROPOLITAN EDISON COMPANY.

RLA
Supervisor, Document Control, NRC

7906180665

228 305

REC 1330
5/17/79

576

11

Beberck & Wilcox

TO: LEE ROGERS

150

123
5-17-79

"B" Bleed Tank sample corrected to 1200 on 5/10/79

I-131	67 uci/gram
Cs-134	7.5 uci/gram
Cs-136	2.1 "
Cs-137	34 "
Ba-140	2.4

R.C. Sample Taken on 3/29 corrected to 1700 on 3/29/79

I-131	2.0×10^4 uci/gram
Cs-134	74 uci/gram
Cs-137	170 uci/gram
Ba-140	NOT DETECTABLE

Will Try Turn alpha + Strontium REFW of RC Sample.

RCBT-B 5/10

u-2 Primary 3/29

POOR ORIGINAL

228 306