

TMI DOCUMENTS

DOCUMENT NO: TM-0648

COPY MADE ON 6/6/79 OF DOCUMENT PROVIDED BY
METROPOLITAN EDISON COMPANY.

RA
Supervisor, Document Control, NRC

7906180685 .

229 002

DATE PRINTED 03/03/79 SURVEILLANCE PERFORMANCE FORM NET-ED T M I UNIT 2 EARLY DATE 03-18-79 **SCHED DATE 03-25-79** LATE DATE 03-30-79

PROCEDURE NO 2303-M 1 TECH/SPEC REF 4.0.5 4.1.2.3 4.1.2.4 DEPT RESP - OPERATIONS TASK NO - 2303-M1R MU-PIA/R/C PUMP TESTING

DEPENDENT TASK WORK ORDER NO. - 036000326 ACCOUNT NO. - 520.1 GC CODE - 20 COMPONENT NO - TMI-2303-M 1- COMPONENT DESC - STANDARD TECH SPEC ITEM COMP LOCATION - B06 LVL GRID SPECIAL COMMENT - MODE 4/5:RC PHS REOD PLANT CONDITION 1-1-1-1-0-1-1

ASSIST DEPT FREQUENCY M QUALITY CONTROL 1 SPECIFIC DAY CONTRACTOR 0 INTERFERENCE 0 PRIORITY 1 COMPONENT STATUS 1

*** COMPLETE THIS SECTION ***

(1) (5) (38) 401CTMI2303M 1 036002TS2303-M1R790840 + COMP NO ++ CSU+ + TASK ++SCHD+

RESULTS (51) DATE PERFORMED (39) 10 31 12 31 79 MONTH DAY YEAR PERFORMED OR RECEPTIONS ACTUAL MANHOURS (45) 000081.0 ACTION TAKEN CODE (52) L L I REASON NOT PERFORMED (54) L L I ABNORMAL OCC REPT (56) L L L L I

PERFORMED BY EMPLOYEE NUMBER (60) 101641131 SIGNATURE - Ron Fountain APPROVED BY EMPLOYEE NUMBER (65) 10549181 SIGNATURE - KR Hoyt WITNESSED BY EMPLOYEE NUMBER (70) L L L L L I SIGNATURE - CORRECTIVE MAINTENANCE JOB TICKET NUMBER (75) L L L L L I

403A (1) - DUPLICATE AS ABOVE (5-38) 402A (1) DUPLICATE AS ABOVE (5-38) RESULTS DESCRIPTION ASSISTING DEPARTMENTS L0L1L I (39) CODE (39) L L L L L I L I (61) HOURS (44) L L L L L I . L I

404A (1) DUPLICATE AS ABOVE (5-38) CODE (50) L L L L L I L0L1L I (39) HOURS (55) L L L L L I . L I L I (61)

DATA SHEET "A"
"A" MAKEUP PUMP RECIRC OPERATING TEST

1. Pump Idle Suction Pressure (MU-PI-0732) 32 psig.
2. Pump Running Suction Header Pressure (MU-PI-0732) 28 psig.
3. Pump Running Strainer Differential Pressure (MU-DPI-1574) 0 inches H₂O
0 psig.
4. Pump Running Inlet Pressure (#2-#3) 0" H₂O x 0.0361 = 0 psig.
25 psig.
5. Pump Outlet Pressure (MU-22-PI1) 3000 psig.
6. Pump Differential Pressure (#5-#4) 2972 psi.
7. Lube Oil Level (Initial if satisfactory) R.F.
8. Pump inboard bearing vibration (mils) H .7
V 1.5

QUANTITY	MEASURED VALUE	ACCEPTABLE RANGE	ALERT RANGE		REQUIRED ACTION RANGE		REFERENCE VALUES
			LOW	HIGH	LOW	HIGH	
PUMP IDLE INLET PRESS. (Psig)	32	>0	NA	NA	<0	NA	40
PUMP RUNNING INLET PRESS (Psig)	28	>0	NA	NA	<0	NA	28
PUMP RUNNING DISCHARGE PRESS. (PSIG)	3000	≥1125	NA	NA	<1125	NA	2900
Δ PRESS. (PSIG)	2972	≥2401	2329 to 2401	NA	<2329	NA	2872
RADIAL BGR. TEMP (°F)*	NA	<180	NA	NA	NA	≥180	141.0
THRUST BGR. TEMP (°F)*	NA	<180	NA	NA	NA	≥180	141.0
MAX. VIBRATION (mils)	1.5 V	0 to 3.4	NA	3.4 to 5.1	NA	>5.1	1.7v

*Only measured once per year.

DATA SHEET "B"
"B" MAKEUP PUMP RECIRC OPERATING TEST

1. Pump Idle Suction Pressure (MU-PI-0732) 32 psig.
2. Pump Running Suction Header Pressure (MU-PI-0732) 28 psig.
3. Pump Running Strainer Differential Pressure (MU-DPI-1575) 0 in H₂O
 $\underline{0}$ in H₂O x 0.0361 = $\underline{0}$ psig 0 psig.
4. Pump Running Inlet Pressure (#2 - #3) 28 psig.
5. Pump Outlet Pressure (MU-22-PI2) 2750 psig.
6. Pump Differential Pressure (#5 - #4) 2722 psi.
7. Lube Oil Level (Initial if satisfactory) 27
8. Pump inboard bearing vibration $\frac{H}{V} \frac{.5}{1.5}$

QUANTITY	MEASURED VALUE	ACCEPTABLE RANGE	ALERT RANGE		REQUIRED ACTION RANGE		REFERENCE VALUES
			LOW	HIGH	LOW	HIGH	
PUMP IDLE INLET PRESS. (Psig)	32	>0	NA	NA	≤0	NA	39
PUMP RUNNING INLET PRESS (Psig)	28	>0	NA	NA	≤0	NA	32
PUMP RUNNING DISCHARGE PRESS. (Psig)	2750	≥1125	NA	NA	≤1125	NA	2750
Δ PRESS (Psi)	2722	≥2401	2329 to 2401	NA	≤2401	NA	2718
RADIAL BGR. TEMP (°F)*	NA	<180	NA	NA	NA	≥180	135.4
THRUST BGR. TEMP (°F)*	NA	<180	NA	NA	NA	≥180	146.1
Max Vibration (mils)	1.5 ✓	0 to 2.5	NA	2.5 to 3.75	NA	>3.75	1.25

*Only measured once per year.

DATA SHEET "C"
"C" MAKEUP PUMP RECIRC OPERATING TEST

1. Pump Idle Suction Pressure (MU-PI-0732) 30 psig.
2. Pump Running Suction Header Pressure (MU-PI-0732) 28 psig.
3. Pump Running Strainer Differential Pressure (MU-DPI-1576) 0 in H₂O
0 " H₂O x 0.0361 = 0 psi . 0 psi.
4. Pump Running Inlet Pressure (#2 - #3) 28 psig.
5. Pump Outlet Pressure (MU-22-PI3) 3000 psig.
6. Pump Differential Pressure (#5 - #4) 2972 psi.
7. Lube Oil Level (Initial if satisfactory) R.F.
8. Pump inboard bearing vibration H: 6
V: 2.5

QUANTITY	MEASURED VALUE	ACCEPTABLE RANGE	ALERT RANGE		REQUIRED ACTION RANGE		REFERENCE VALUES
			LOW	HIGH	LOW	HIGH	
PUMP IDLE INLET PRESS. (Psig)	30	>0	NA	NA	≤0	NA	29
PUMP RUNNING INLET PRESS (Psig)	28	>0	NA	NA	≤0	NA	30
PUMP RUNNING DISCHARGE PRESS. (Psig)	3000	≥1125	NA	NA	<1125	NA	2900
Δ PRESS (Psi)	2172	≥2401	2329 to 2401	NA	<2329	NA	2870
RADIAL BGR. TEMP (°F)*	N/A	<180	NA	NA	NA	≥180	123.5
THRUST BGR. TEMP (°F)*	N/A	<180	NA	NA	NA	≥180	160.5
MAX VIBRATION (Mils)	2.5V	0 to 1.3	NA	1.8 to 2.7	NA	>2.7	0.9H

*To be measured yearly.

229 006

Performed by: Ken Fountain Date 3/23/79 Time 0900

Approved by: KR Hoyt Date 3/23/79

ANALYSIS:

all data fall in acceptable range
all three pumps ok

Analysis by: KR Hoyt Date 3/23/79 Time 1200

DATE PRINTED
02/07/79

SURVEILLANCE PERFORMANCE FORM
MEI-ED T M 1 UNIT 2

EARLY DATE 02-18-79
SCHED DATE 02-25-79
LATE DATE 03-04-79

PROCEDURE NO TECH/SPEC REF

2303-M 1

4.0.5
4.1.2.3
4.1.2.4

DEPT RESP - OPERATIONS

TASK NO - 2303-M1B
MU-PIA/B/C PUMP TESTING

DEPENDENT TASK

WORK ORDER NO. - 036000326
ACCOUNT NO. - 520.1
GC CODE - 20
COMPONENT NO - TMI-2303-M 1-
COMPONENT DESC - STANDARD TECH SPEC ITEM
COMP LOCATION - BDG LVL GRID

SPECIAL COMMENT - MODE 4/5:HC PRS REQD

PLANT CONDITION 1-1-1-1-0-1-1

ASSIST DEPT

FREQUENCY M QUALITY CONTROL 1

SPECIFIC DAY

CONTRACTOR 0 INTERFERENCE 0

PRIORITY 1 COMPONENT STATUS 1

*** COMPLETE THIS SECTION ***

(1) (5) (38)
401CTMI2303M 1 036002TS2303-M1B790560
* COMP NO ** CSU* * TASK **SCHD*

RESULTS(51)

DATE PERFORMED(39) 02 23 79
MONTH DAY YEAR

CHECK ONE ONLY

PERFORMED OK

ACTUAL MANHOURS(45) 0204 12.00

2 EXCEPTIONS

ACTION TAKEN CODE(52) L L I

3 DEFICIENCIES

REASON NOT PERFORMED(54) L L I

4 BOTH E S AND D S

ABNORMAL OCC REPT(56) L L L I

5 NOT PERFORMED

PERFORMED BY EMPLOYEE NUMBER(60)

06368 SIGNATURE - *D. Kauderwald*

APPROVED BY EMPLOYEE NUMBER(65)

05844 SIGNATURE - *J. Schenau*

WITNESSED BY EMPLOYEE NUMBER(70)

L L L L L I SIGNATURE -

CORRECTIVE MAINTENANCE JOB TICKET NUMBER(75) L L L L L I

403A (1) DUPLICATE AS ABOVE (5-38)

402A (1) DUPLICATE AS ABOVE (5-38)

RESULTS DESCRIPTION

ASSISTING DEPARTMENTS

L0L1L L L I L L L L L L L L L L L L L L L I(39)

CODE(39) L L L L L I

L I(61)

HOURS(44) L L L L L I L I

404A (1) DUPLICATE AS ABOVE (5-38)

CODE(50) L L L L L I

L0L1L I(39)

HOURS(55) L L L L L I L I

L I(61)

229 JUB

DATA SHEET "A"
"A" MAKEUP PUMP RECIRC OPERATING TEST

1. Pump Idle Suction Pressure (MU-PI-0732) 27 psig.
2. Pump Running Suction Header Pressure (MU-PI-0732) 25 psig.
3. Pump Running Strainer Differential Pressure (MU-DPI-1574) 1 inches H₂O
 $\frac{1}{2}$ " H₂O x 0.0361 = 0.036 psig. 0.0 sig.
4. Pump Running Inlet Pressure (#2-#3) 24.957 psig.
5. Pump Outlet Pressure (MU-22-PI1) 29.50 psig.
6. Pump Differential Pressure (#5-#4) 2925.036 psi.
7. Lube Oil Level (Initial if satisfactory)
8. Pump inboard bearing vibration (mils) H 1.0
V 1.8

Signature

QUANTITY	MEASURED VALUE	ACCEPTABLE RANGE	ALERT RANGE		REQUIRED ACTION RANGE		REFERENCE VALUES
			LOW	HIGH	LOW	HIGH	
PUMP IDLE INLET PRESS. (Psig)	27	>0	NA	NA	≤0	NA	40
PUMP RUNNING INLET PRESS (Psig)	25	>0	NA	NA	≤0	NA	28
PUMP RUNNING DISCHARGE PRESS. (PSIG)	2950	≥1125	NA	NA	<11.0		900
Δ PRESS. (PSIG)	2925	≥2401	2329 to 2401	NA	<2329	NA	2872
RADIAL BGR. TEMP (°F)*	NA	<180	NA	NA	NA	≥180	141.0
THRUST BGR. TEMP (°F)*	NA	<180	NA	NA	NA	≥180	141.0
MAX. VIBRATION (mils)	1.8 ✓	0 to 3.4	NA	3.4 to 5.1	NA	>5.1	1.7v

*Only measured once per year.

229 009

DATA SHEET "B"
"B" MAKEUP PUMP RECIRC OPERATING TEST

1. Pump Idle Suction Pressure (MU-PI-0732) 25 psig.
2. Pump Running Suction Header Pressure (MU-PI-0732) 22 psig.
3. Pump Running Strainer Differential Pressure (MU-DPI-1575) 1 in H_2O = 0.036 psig.
4. Pump Running Inlet Pressure (#2 - #3) 21.964 psig.
5. Pump Outlet Pressure (MU-22-PI2) 2750 psig.
6. Pump Differential Pressure (#5 - #4) 2728.036 psi.
7. Lube Oil Level (Initial if satisfactory) OK
8. Pump inboard bearing vibration H 0.7
V 0.5

QUANTITY	MEASUREMENT VALUE	ACCEPTABLE RANGE	ALERT RANGE		REQUIRED ACTION RANGE		REFERENCE VALUES
			LOW	HIGH	LOW	HIGH	
PUMP IDLE INLET PRESS. (Psig)	25	>0	NA	NA	<0	NA	39
PUMP RUNNING INLET PRESS (Psig)	21.964	>0	NA	NA	<0	NA	32
PUMP RUNNING DISCHARGE PRESS. (Psig)	2750	>1125	NA	NA	<1125	NA	2750
Δ PRESS (Psi)	2728.036	≥2401	2329 to 2401	NA	<2329	NA	2718
RADIAL BGR. TEMP (°F)*	NA	<180	NA	NA	NA	≥180	135.4
THRUST BGR. TEMP (°F)*	NA	<180	NA	NA	NA	≥180	146.1
Max Vibration (mils)	0.7H	0 to 2.5	NA	2.5 to 3.75	NA	>3.75	1.25

*Only measured once per year.

DATA SHEET "C"
"C" MAKEUP PUMP RECIRC. OPERATING TEST

1. Pump Idle Suction Pressure (MU-PI-0732) 22 psig.
2. Pump Running Suction Header Pressure (MU-PI-0732) 21 psig.
3. Pump Running Strainer Differential Pressure (MU-DPI-1576) 0 in "0"
0 " H₂O x 0.0361 = 0 psi. 0 psi.
4. Pump Running Inlet Pressure (#2 - #3) 21 psig.
5. Pump Outlet Pressure (MU-22-PI3) 2950 psig.
6. Pump Differential Pressure (#5 - #4) 2929 psi.
7. Lube Oil Level (Initial if satisfactory)
8. Pump inboard bearing vibration H 0.8
V 1.0

QUANTITY	MEASURED VALUE	ACCEPTABLE RANGE	ALERT RANGE		REQUIRED ACTION RANGE		REFERENCE VALUES
			LOW	HIGH	LOW	HIGH	
PUMP IDLE INLET PRESS. (Psig)	22	>0	NA	NA	≤0	NA	29
PUMP RUNNING INLET PRESS (Psig)	21	>0	NA	NA	≤0	NA	30
PUMP RUNNING DISCHARGE PRESS. (Psig)	2950	125	NA	NA	<1125	NA	2900
Δ PRESS (Psi)	2929	≥2401	2329 to 2401	NA	<2329	NA	2870
RADIAL BGR. TEMP (°F)*	NA	<180	NA	NA	NA	≥180	123.5
THRUST BGR. TEMP (°F)*	NA	<180	NA	NA	NA	≥180	160.5
MAX VIBRATION (Mils)	1.0 V	0 to 1.8	NA	1.8 to 2.7	NA	>2.7	0.9H

*To be measured yearly.

229 011

Performed by: *D. P. [Signature]* Date 2/23/79 Time 1455
Approved by: *J. Schumann* Date 2/23/79

ANALYSIS:

APPEARS TO MEET ALL ACCEPTANCE DATA

Analysis by: *[Signature]* Date 2/23/79 Time 1900

229 012

DATE PRINTED
01/17/79

SURVEILLANCE PERFORMANCE FORM
MET-ED T M I UNIT 2

EARLY DATE 01-22-79
SCHED DATE 02-13-79
LATE DATE 03-06-79

PROCEDURE NO
2303-M 1

TECH/SPEC REF
4.0.5
4.1.2.3
4.1.2.4

DEPT RESP - OPERATIONS
TASK NO - 2303-M1A
MU-PIA/H/C PUMP & VALVE TESTING

WORK ORDER NO. - 036000326
ACCOUNT NO. - 520.1
GC CODE - 20
COMPONENT NO - TMI-2303-M 1-
COMPONENT DESC - STANDARD TECH SPEC ITEM
COMP LOCATION - HDG LVL GRID

DEPENDENT TASK

SPECIAL COMMENT - MODE 4/5:RC PRS REQD
PLANT CONDITION 1-1-1-1-0-1-1

ISI DATA

EVALUATION REQUIRED

ASSIST DEPT _____ FREQUENCY 0 _____ QUALITY CONTROL 1 _____
BY 1840 / 2-18-79 _____ SPECIFIC DAY _____
TIME/DATE _____ CONTRACTOR 0 _____ INTERFERENCE 0 _____
PRIORITY 1 _____ COMPONENT STATUS 1 _____

*** COMPLETE THIS SECTION ***

(1) (5) (38)
401CTMI2303M 1 036002TS2303-M1A790440
* COMP NO ** CSU* * TASK **SCHED*

RESULTS(51) _____ DATE PERFORMED(39) 02 / 14 / 79
MONTH DAY YEAR
CHECK ONE ONLY
() 1 PERFORMED OK
() 2 EXCEPTIONS
() 3 DEFICIENCIES
() 4 BOTH E S AND D S
() 5 NOT PERFORMED
ACTUAL MANHOURS(45) 0587.3
ACTION TAKEN CODE(52) _____
REASON NOT PERFORMED(54) _____
ABNORMAL OCC REPT(56) _____

PERFORMED BY EMPLOYEE NUMBER(60) 05491 I SIGNATURE - [Signature]
APPROVED BY EMPLOYEE NUMBER(65) 05873 I SIGNATURE - [Signature]
WITNESSED BY EMPLOYEE NUMBER(70) _____ I SIGNATURE - _____
CORRECTIVE MAINTENANCE JOB TICKET NUMBER(75) _____

403A (1) DUPLICATE AS ABOVE (5-38) 402A (1) DUPLICATE AS ABOVE (5-38)
RESULTS DESCRIPTION ASSISTING DEPARTMENTS
L0L1L I (39) CODE(39) L L L L L I
L I (61) HOURS(44) L L L L L I.L I
404A (1) DUPLICATE AS ABOVE (5-38) CODE(50) L L L L L I
L0L1L I (39) HOURS(55) L L L L L I.L I
L I (61)

CONTROLLED COPY
 CONTROL ROOM
 WORKING COPY

2303-MI A/B
 Revision 5
 09/22/78

THREE MILE ISLAND NUCLEAR STATION
 UNIT #2 SURVEILLANCE PROCEDURE 2303-M1A/B
 MAKEUP PUMP AND VALVE FUNCTIONAL TEST

Table of Effective Pages

Page	Date	Revision	Page	Date	Revision	Page	Date	Revision
1.0	09/22/78	5	26.0			51.0		
2.0	09/22/78	5	27.0			52.0		
3.0	09/22/78	5	28.0			53.0		
4.0	09/22/78	5	29.0			54.0		
5.0	09/22/78	5	30.0			55.0		
6.0	09/22/78	5	31.0			56.0		
7.0	09/22/78	5	32.0			57.0		
8.0	09/22/78	5	33.0			58.0		
9.0	09/22/78	5	34.0			59.0		
10.0	09/22/78	5	35.0			60.0		
11.0	09/22/78	5	36.0			61.0		
12.0	09/22/78	5	37.0			62.0		
13.0	09/22/78	5	38.0			63.0		
14.0	09/22/78	5	39.0			64.0		
15.0	09/22/78	5	40.0			65.0		
16.0	09/22/78	5	41.0			66.0		
17.0	09/22/78	5	42.0			67.0		
18.0	09/22/78	5	43.0			68.0		
19.0	09/22/78	5	44.0			69.0		
20.0	09/22/78	5	45.0			70.0		
21.0	09/22/78	5	46.0			71.0		
22.0			47.0			72.0		
23.0			48.0			73.0		
24.0			49.0			74.0		
25.0			50.0			75.0		

Unit 1 Staff Recommends Approval Approval <u>NA</u> Date _____ Cognizant Dept. Head	Unit 2 Staff Recommends Approval Approval <u>NA</u> Date _____ Cognizant Dept. Head
Unit 1 PORC Recommends Approval <u>NA</u> Date _____ Chairman of PORC	Unit 2 PORC Recommends Approval <u>J. F. [Signature]</u> Date <u>9/22/78</u> Chairman of PORC
Unit 1 Superintendent Approval <u>NA</u> Date _____	Unit 2 Superintendent Approval <u>J. L. [Signature]</u> Date <u>9/22/78</u>
Manager Generation Quality Assurance Approval _____	<u>NA</u> Date _____

DATA SHEET "A"
"A" MAKEUP PUMP RECIRC OPERATING TEST

1. Pump Idle Suction Pressure (MU-PI-0732) 32 psig.
2. Pump Running Suction Header Pressure (MU-PI-0732) 28 psig.
3. Pump Running Strainer Differential Pressure (MU-DPI-1574) 0 inches H₂O
0 " H₂O x 0.0361 = 0 psig.
4. Pump Running Inlet Pressure (#2-#3) 28 psig.
5. Pump Outlet Pressure (MU-22-PI1) 3000 psig.
6. Pump Differential Pressure (#5-#4) 28 psi.
7. Lube Oil Level (Initial if satisfactory) 1
8. Pump inboard bearing vibration (mils) $\frac{H = 5}{V = 7}$

QUANTITY	MEASURED VALUE	ACCEPTABLE RANGE	ALERT RANGE		REQUIRED ACTION RANGE		REFERENCE VALUES
			LOW	HIGH	LOW	HIGH	
PUMP IDLE INLET PRESS. (Psig)	32	>0	NA	NA	<=0	NA	40
PUMP RUNNING INLET PRESS (Psig)	28	>0	NA	NA	<=0	NA	28
PUMP RUNNING DISCHARGE PRESS. (PSIG)	3000	>=1125	NA	NA	<1125	NA	2900
Δ PRESS. (PSIG)	29.2	<2329	2329 to 2401	NA	<2329	NA	2872
RADIAL BGR. TEMP (°F)*	130.1 147.9	<180	NA	NA	NA	>=180	141.0
THRUST BGR. TEMP (°F)*	147.9	<180	NA	NA	NA	>=180	141.0
MAX. VIBRATION (mils)	7	0 to 3.4	NA	3.4 to 5.1	NA	>5.1	1.7v

*Only measured once per year.

DATA SHEET "B"
 "B" MAKEUP PUMP RECIRC OPERATING TEST

1. Pump Idle Suction Pressure (MU-PI-0732) 34 psig.
2. Pump Running Suction Header Pressure (MU-PI-0732) 30 psig.
3. Pump Running Strainer Differential Pressure (MU-DPI-1575) 0 in H₂O
 $\frac{0}{12} \text{ in H}_2\text{O} \times 0.0361 = \underline{0}$ psig 0 psig.
4. Pump Running Inlet Pressure (#2 - #3) 30 psig.
5. Pump Outlet Pressure (MU-22-PI2) 2900 psig.
6. Pump Differential Pressure (#5 - #4) 2870 psi.
7. Lube Oil Level (Initial if satisfactory) AW
8. Pump inboard bearing vibration H .6
 V 1.7

QUANTITY	MEASURED VALUE	ACCEPTABLE RANGE	ALERT RANGE		REQUIRED ACTION RANGE		REFERENCE VALUES
			LOW	HIGH	LOW	HIGH	
PUMP IDLE INLET PRESS. (Psig)	34	>0	NA	NA	≤0	NA	39
PUMP RUNNING INLET PRESS (Psig)	30	>0	NA	NA	≤0	NA	32
PUMP RUNNING DISCHARGE PRESS. (Psig)	2900	≥1125	NA	NA	≤1125	NA	2750
Δ PRESS (?)	2870	≥2401	2329 to 2401	NA	<2329	NA	2718
RADIAL BGR. TEMP (°F)*	N/A	<180	NA	NA	NA	≥180	135.4
THRUST BGR. TEMP (°F)*	N/A	<180	NA	NA	NA	≥180	146.1
Max Vibration (mils)	1.7	0 to 2.5	NA	2.5 to 3.75	NA	>3.75	1.25

*Only measured once per year.

DATA SHEET "C"
"C" MAKEUP PUMP RECIRC OPERATING TEST

1. Pump Idle Suction Pressure (MU-PI-0732) 32 psig.
2. Pump Running Suction Header Pressure (MU-PI-0732) 25 psig.
3. Pump Running Strainer Differential Pressure (MU-DPI-1576) 0 in H₂O
0 " H₂O x 0.0361 = 0 psi .
0 psi.
4. Pump Running Inlet Pressure (#2 - #3) 25 psig.
5. Pump Outlet Pressure (MU-22-PI3) 2950 psig.
6. Pump Differential Pressure (#5 - #4) 2925 psi.
7. Lube Oil Level (Initial if satisfactory) ok
8. Pump inboard bearing vibration H .5
V .8

QUANTITY	MEASURED VALUE	ACCEPTABLE RANGE	ALERT RANGE		REQUIRED ACTION RANGE		REFERENCE VALUES
			LOW	HIGH	LOW	HIGH	
PUMP IDLE INLET PRESS. (Psig)	32	>0	NA	NA	<=0	NA	29
PUMP RUNNING INLET PRESS (Psig)	25	>0	NA	NA	<=0	NA	30
PUMP RUNNING DISCHARGE PRESS. (Psig)	2950	≥1125	NA	NA	<1125	NA	2900
Δ PRESS (Psi)	2925	≥2401	2329 to 2401	NA	<2329	NA	2670
RADIAL BGR. TEMP (°F)*	NA	<180	NA	NA	NA	≥180	123.5
THRUST BGR. TEMP (°F)*	NA	<180	NA	NA	NA	≥180	160.5
MAX VIBRATION (Mils)	.8	0 to 1.8	NA	1.8 to 2.7	NA	>2.7	0.9H

*To be measured yearly.

DATA SHEET "D"
 MAKEUP SYSTEM
 VALVE OPERABILITY TEST

<u>Valve No.</u>	<u>Functional Requirement</u>	<u>Initial/Date</u>
MU-V143 A	(Check valve) Open	<u>WCS</u>
MU-V143 A	(Check valve) Close	<u>WCS 2-12-79</u>
MU-V143 B	(Check valve) Open	<u>WCS 2-12-79</u>
MU-V143 B	(Check valve) Close	<u>WCS</u>
MU-V143C	(Check valve) Open	<u>WCS</u>
MU-V143C	(Check valve) Close	<u>WCS</u>
MU-V161 A	(Stop check valve) Open	<u>WCS</u>
MU-V161 B	(Stop check valve) Open	<u>WCS</u>
MU-V161 C	(Stop check valve) Open	<u>WCS</u>
MU-V161 D	(Stop check valve) Open	<u>WCS</u>

Valve No. MU-V439 Closes In 14.3 Acceptable Time Limit 19 sec.

Performed by: ZOU Date 2-14-79 Time 1829

Approved by: J Miller Date 2-14-79

ANALYSIS: The above valves have meet their acceptance criteria + therefore are operational

Analysis by: Joseph Barbato Date 2/15/79 Time 0900

Performed by: L. B. Wright Date 2-14-79 Time 1800

Approved by: A. Miller Date 2-14-79

ANALYSIS:

The valves on Page 20.0 have meet their acceptance
criteria & therefore are operational.

Analysis by: Joseph Roshita Date 2/15/79 Time 0900

R. H. Payne / M. L. ... 7-79

DATE PRINTED
01/19/79

SURVEILLANCE PERFORMANCE FORM
NET-ED T M 1 UNIT 2

EARLY DATE 01-18-79
SCHED DATE 01-25-79
LATE DATE 02-01-79

PROCEDURE NO TECH/SPEC REF

2303-M 1

4.0.5
4.1.2.3
4.1.2.4

DEPT RESP - OPERATIONS

TASK NO - 2303-M14
M14-R14/R/C PUMP TESTING

DEPENDENT TASK

WORK ORDER NO. - 036000325
ACCOUNT NO. - 520.1
GC CODE - 20
COMPONENT NO - T-1-2303-M 1-
COMPONENT DESC - STANDARD TECH SPEC ITEM
COMP LOCATION - R06 LVL GRID

SPECIAL COMMENT - MODE 4/5:RC PRS REQD

PLANT CONDITION 1-1-1-1-0-1-1

ASSIST DEPT

FREQUENCY M QUALITY CONTROL 1

SPECIFIC DAY

CONTRACTOR 0 INTERFERENCE 0

PRIORITY 1 COMPONENT STATUS 1

*** COMPLETE THIS SECTION ***

(1) (5) (34)
40101 412303M 1 0360021S2303-M14740250
+ COMP NO + CSU + TASK + SCHO +

RESULTS(S1)

DATE PERFORMED(39) L0L1I 12L9T L7L9I
MONTH DAY YEAR

CHECK ONE ONLY

- () 1 PERF - OK
- () 2 RACE
- () 3 DEFICIENCIES
- () 4 BOTH E'S AND D'S
- () 5 NOT PERFORMED

ACTUAL HOURS(45) L L L U L 21.10I
ACTION TAKEN CODE(52) L L I
REASON NOT PERFORMED(54) L L I
ABNORMAL OCC REPT(56) L L L L I

PERFORMED BY EMPLOYEE NUMBER(60) L0L5L4L7L9I SIGNATURE - Dennis Olson

APPROVED BY EMPLOYEE NUMBER(65) L0L5L8L7L3I SIGNATURE - Miller

WITNESSED BY EMPLOYEE NUMBER(70) L L L L L I SIGNATURE -

CORRECTIVE MAINTENANCE JOB TICKET NUMBER(75) L L L L L I

403A (1) DUPLICATE AS ABOVE (5-34) 402A (1) DUPLICATE AS ABOVE (5-34)

RESULTS DESCRIPTION ASSISTING DEPARTMENTS

L0L1L I (39) CODE(39) L L L L L I
L I (61) HOURS(44) L L L L L I L I

404A (1) DUPLICATE AS ABOVE (5-34) CODE(50) L L L L L I

L0L1L I (39) HOURS(55) L L L L L I L I
L I (61)

CONTROLLED COPY
 CONTROL ROOM
 WORKING COPY

2303-M1 A/B
 Revision E
 09/22/78

THREE MILE ISLAND NUCLEAR STATION
 UNIT #2 SURVEILLANCE PROCEDURE 2303-M1A/B
 MAKEUP PUMP AND VALVE FUNCTIONAL TEST

Table of Effective Pages

<u>Page</u>	<u>Date</u>	<u>Revision</u>	<u>Page</u>	<u>Date</u>	<u>Revision</u>	<u>Page</u>	<u>Date</u>	<u>Revision</u>
1.0	09/22/78	5	26.0			51.0		
2.0	09/22/78	5	27.0			52.0		
3.0	09/22/78	5	28.0			53.0		
4.0	09/22/78	5	29.0			54.0		
5.0	09/22/78	5	30.0			55.0		
6.0	09/22/78	5	31.0			56.0		
7.0	09/22/78	5	32.0			57.0		
8.0	09/22/78	5	33.0			58.0		
9.0	09/22/78	5	34.0			59.0		
10.0	09/22/78	5	35.0			60.0		
11.0	09/22/78	5	36.0			61.0		
12.0	09/22/78	5	37.0			62.0		
13.0	09/22/78	5	38.0			63.0		
14.0	09/22/78	5	39.0			64.0		
15.0	09/22/78	5	40.0			65.0		
16.0	09/22/78	5	41.0			66.0		
17.0	09/22/78	5	42.0			67.0		
18.0	09/22/78	5	43.0			68.0		
19.0	09/22/78	5	44.0			69.0		
20.0	09/22/78	5	45.0			70.0		
	09/22/78	5	46.0			71.0		
21.0			47.0			72.0		
22.0			48.0			73.0		
24.0			49.0			74.0		
25.0			50.0			75.0		

Unit 1 Staff Recommends Approval
 Approval NA Date _____
 Cognizant Dept. Head

Unit 2 Staff Recommends Approval
 Approval NA Date _____
 Cognizant Dept. Head

Unit 1 PORC Recommends Approval
NA Date _____
 Chairman of PORC

Unit 2 PORC Recommends Approval
J. J. [Signature] Date 9/22/78
 Chairman of PORC

Unit 1 Superintendent Approval
NA Date _____

Unit 2 Superintendent Approval
J. L. [Signature] Date 9/22/78

Manager Generation Quality Assurance Approval NA Date _____

DATA SHEET "A"
"A" MAKEUP PUMP RECIRC OPERATING TEST

1. Pump Idle Suction Pressure (MU-PI-0732) 40 psig.
2. Pump Running Suction Header Pressure (MU-PI-0732) 40 psig.
3. Pump Running Strainer Differential Pressure (MU-DPI-1574) 0 inches H₂O
4. Pump Running Inlet Pressure (#2-#3) $\frac{0}{0} \text{ " H}_2\text{O} \times 0.0361 = \underline{0}$ psig. 0 psig.
5. Pump Outlet Pressure (MU-22-PI1) 40 psig.
6. Pump Differential Pressure (#5-#4) 2950 psig.
7. Lube Oil Level (Initial if satisfactory) 2910 psi.
8. Pump inboard bearing vibration (mils) 4.5 ~~00~~

H 1.0
V 0.7

QUANTITY	MEASURED VALUE	ACCEPTABLE RANGE	ALERT RANGE		REQUIRED ACTION RANGE		REFERENCE VALUES
			LOW	HIGH	LOW	HIGH	
PUMP IDLE INLET PRESS. (Psig)	40	>0	NA	NA	<0	NA	40
PUMP RUNNING INLET PRESS (Psig)	40	>0	NA	NA	<0	NA	28
PUMP RUNNING DISCHARGE PRESS. (PSIG)	2950	≥1125	NA	NA	<1125	NA	2900
Δ PRESS. (PSIG)	2910	≥2401	2329 to 2401	NA	<2329	NA	28"
RADIAL BGR. TEMP (°F)*	T ₁ = 118.7 T ₂ = 120.6 T ₃ = 121.8	<180	NA	NA	NA	≥180	141.0
THRUST BGR. TEMP (°F)*	T ₁ = 139.9 T ₂ = 141.9 T ₃ = 143.4	<180	NA	NA	NA	≥180	141.0
MAX. VIBRATION (mils)	1.0 (H)	0 to 3.4	NA	3.4 to 5.1	NA	>5.1	1.7v

*Only measured once per year.

DATA SHEET "B"
"B" MAKEUP PUMP RECIRC OPERATING TEST

1. Pump Idle Suction Pressure (MU-PI-0732) 40 psig.
2. Pump Running Suction Header Pressure (MU-PI-0732) 40 psig.
3. Pump Running Strainer Differential Pressure (MU-DPI-1575) 1" in H₂O
1 in H₂O x 0.0361 = .0361 psig .0361 psig.
4. Pump Running Inlet Pressure (#2 - #3) 39.96 psig.
5. Pump Outlet Pressure (MU-22-PI2) 2850 psig.
6. Pump Differential Pressure (#5 - #4) 2810 psi.
7. Lube Oil Level (Initial if satisfactory) yes
8. Pump inboard bearing vibration H .9
V .3

QUANTITY	MEASURED VALUE	ACCEPTABLE RANGE	ALERT RANGE		REQUIRED ACTION RANGE		REFERENCE VALUES
			LOW	HIGH	LOW	HIGH	
PUMP IDLE INLET PRESS. (Psig)	40	>0	NA	NA	<0	NA	39
PUMP RUNNING INLET PRESS (Psig)	39.96	>0	NA	NA	<0	NA	32
PUMP RUNNING DISCHARGE PRESS. (Psig)	2850	≥1125	NA	NA	≤1125	NA	2750
Δ PRESS (Psi)	2810	≥2401	2329 to 2401	NA	NA	NA	2718
RADIAL BGR. TEMP (°F)*	T ₁ = 128.5 T ₂ = 128.5 T ₃ = 128.5	<180	NA	NA	NA	≥180	135.4
THRUST BGR. TEMP (°F)*	T ₁ = 145.4 T ₂ = 145.2 T ₃ = 145.2	<180	NA	NA	NA	≥180	146.1
Max Vibration (mils)	.9 (H)	0 to 2.5	NA	2.5 to 3.75	NA	>3.75	1.25

*Only measured once per year.

DATA SHEET "C"
"C" MAKEUP PUMP RECIRC OPERATING TEST

1. Pump Idle Suction Pressure (MU-PI-0732) 40 psig.
2. Pump Running Suction Header Pressure (MU-PI-0732) 40 psig.
3. Pump Running Strainer Differential Pressure (MU-DPI-1576) 2" in H₂O
2 " H₂O x 0.0361 = .072 psi . .072 psi.
4. Pump Running Inlet Pressure (#2 - #3) 39.92 psig.
5. Pump Outlet Pressure (MU-22-PI3) 2950 psig.
6. Pump Differential Pressure (#5 - #4) 290 psi.
7. Lube Oil Level (Initial if satisfactory) Yes
8. Pump inboard bearing vibration H .75
V .6

QUANTITY	MEASURED VALUE	ACCEPTABLE RANGE	ALERT RANGE		REQUIRED ACTION RANGE		REFERENCE VALUES
			LOW	HIGH	LOW	HIGH	
PUMP IDLE INLET PRESS. (Psig)	40	>0	NA	NA	<=0	NA	29
PUMP RUNNING INLET PRESS (Psig)	39.92	>0	NA	NA	<=0	NA	30
PUMP RUNNING DISCHARGE PRESS. (Psig)	2950	>=1125	NA	NA	<1125	NA	2900
Δ PRESS (Psi)	290	>=2401	2329 to 2401	NA	<2329	NA	2870
RADIAL BGR. TEMP (°F)*	T ₁ = 112.2 T ₂ = 113.4 T ₃ = 115.3	<180	NA	NA	NA	>=180	123.5
THRUST BGR. TEMP (°F)*	T ₁ = 159.1 T ₂ = 159.2 T ₃ = 159.4	<180	NA	NA	NA	>=180	160.5
MAX VIBRATION (Mils)	.75 (H)	0 to 1.8	NA	1.8 to 2.7	NA	>2.7	0.9H

*To be measured yearly.

Performed by: Dennis Olson Date 1-29-79 Time 1340
Approved by: A. Miller Date 1-29-79

ANALYSIS:

Data is satisfactory

Analysis by: A. Miller Date 1-29-79 Time 1335