

TMI DOCUMENTS

DOCUMENT NO: TM-0651

COPY MADE ON 6/4/79 OF DOCUMENT PROVIDED BY
METROPOLITAN EDISON COMPANY.

PJH
Supervisor, Document Control, NRC

7906180711

779 334

rcsl

DATE: 5/28, 79 REACTOR COOLANT LEAKAGE TEST
TIME: 1:28: 1 SP 2301-301

NOTE: IF OPERATOR ACTION DECREASES RCS VOLUME THE DATA ENTRY FOR THAT ACT. MUST BE NEG.
...YOU MUST ENTER DEC. PT. WITH LEAKAGE VALUES...

INTERVAL (1-8 HOURS)

OPERATOR CAUSED CHANGES TO THE RCOT FROM DS 4 (2301-301)

0.0

ENTER OPERATOR CAUSED CHANGES FROM DS 4 (2301-301)

305.

ENTER IDENTIFIED LEAKAGE FROM DS 3 (2301-301) (GPM)

0.0

ENTER PRIMARY TO SECONDARY OTSG TUBE LEAK (GPM)

0.0

TIME	TCA (F)	THA (F)	TCS (F)	THS (F)	TAVE (F)	PRIO LVL (IN)	MUTEK LVL (IN)	RCOT LVL (INCHES)
1:34:13:	557.070	605.961	557.641	605.906	581.641	229.302	72.907	74.492
2:34:13:	556.844	605.983	557.508	605.805	581.500	229.657	69.886	78.620

GROSS LEAK RATE (<30 GPM):

6.9438 GPM

TOTAL IDENTIFIED RCS LEAK RATE (<10 GPM):

4.9926 GPM

6.93

NET UNIDENTIFIED LEAK RATE (<1 GPM):

1.9512 GPM

.01

OPERATOR:

Craig C Faust

APPROVED:

A Miller

229 336

Attachment 1A

Note: This attachment is not valid if operator caused RCDT level changes were noted
 record RCDT temperature (from computer pit 1032) 70.0

Calculate density (in $\frac{lb}{ft^3}$) of water in RCDT. Use line A, an assumed pressure of 15 psia, and Table 1. Interpolate.

Temperature (°F)	Density (lb/ft ³)	Pressure (psia)	Density (lb/ft ³)
50	.016024	0	.015998
70	.0160664	15	.0160412
100	.016130	500	.016106

Handwritten notes: 216063644, 227407, 20716, 2000000504, 200000216

(Density $[\frac{lb}{ft^3}] = \frac{1}{v} [\frac{1}{\frac{cu}{ft}}]$) Density = 62.2468 $\frac{lb}{ft^3}$

1) Calculate density of RC. Use average Tave and Figure 1. Density = 44.560698 $\frac{lb}{ft^3}$

2) Convert identified leak rate, collected in RC drain tank, to equivalent RC gallons.

Ident Leak Rate 4.9926 (from print out) $\times \frac{\text{Density of RCDT}}{\text{Density of RCs}}$ = 62.24 / 44.56 = 1.390

RC equivalent Identified Leak Rate = 6.93 gpm.

Subtract Equivalent Identified Leak Rate from Total Leak Rate to get Unidentified.

Attachment 1A cont.

Total Leak Rate	<u>6.94</u>	gpm
- Existing Ident Leak Rate	<u>6.93</u>	gpm
Net Ident Leak Rate	<u>0.01</u>	gpm.

Accept Criteria

Total Leak Rate must be ≤ 30 gpm.

Total Identified Leak Rate must be ≤ 10 gpm.

Net Identified Leak Rate must be ≤ 1 gpm.

POOR ORIGINAL

DATA SHEET 4

RCS LEAK RATE

OPERATOR CAUSED CHANGES TO RCS INVENTORY

1. Identify operation that caused change: Added
303 FTe MIT

2. Time Operation Started: 0145

Time Operation Completed: 0147

3. Calculations: _____

4. Total change to RCS inventory: 303 gal.

NOTE 1: If change is to RCDT enter in section 7 of Data Sheet 1
Line 25 or Data Sheet 2 Line 38.

NOTE 2: If change is to any other part of the system, enter in
section 5 of Data Sheet 1 Line 20 or Data Sheet 2 Line 33.

NOTE 3: SIGNS: Removals from the system have a negative (-) sign.
Additions to the system have a positive (+) sign.

PERFORMED BY C. J. C. Faust

DATE 3/28/79

APPROVED BY J. Miller

DATE 3-28-79

RC FLOW
 RCS FLOW DETERMINATION

DATE: 3/27/73

TIME: 23:51: 0

NOTE: RC AND FW PRESS ARE ASSUMED VALUES

	TEMPERATURE	PRESSURE	ENTHALPY
THA	605.898	2150.	622.367
THD	606.172	2150.	622.766
TCA	557.523	2150.	556.781
TCD	557.531	2150.	556.797
TSA	595.104	923.103	1254.047
TSD	594.133	920.789	1253.453
TFA	464.160	1700.	446.445
TFB	460.465	1700.	442.273

AVERAGE RC TCOLD = 557.52 DENSITY = 46.283

LOOP A FDW FLOW (KPPH) = 5778.13

LOOP B FDW FLOW (KPPH) = 5757.06

RC FLOW VALUES

LOOP A (GPH)	LOOP B (GPH)	TOTAL (GPH)	MEASURED (GPH)
71.147	70.783	141.938	130.357

RCS FLOW (GPH) = 332344.

PERCENT OF DESIGN FLOW = 108.619

*** TECH SPEC GRM (CORRECTED) = 376608.

AVERAGE CORE THERMAL POWER (MW) = 2715.

DOES FLOW FOR PRESENT POWER/PUMPS MEET SPEC

YES NO

PERFORMED BY

Cheryl Faust

APPROVED BY

J. Scherman

STOP

0

229 340

cal

DATA SHEET #1 (2302-S1)

CALIBRATE OUT-OF-CORE DETECTORS

DATE: 3/27/79

TIME: 23:10:26

	N15	N16	N17	N18	CORE THERMAL OUTPUT	INCORE IMBALANCE
VALUE (%)	97.525	97.280	97.477	97.320	97.565	-2.040
ELP (%)	-0.038	-0.275	-0.087	-0.243		
IMBAL (%)	-2.912	-3.409	-3.295	-3.157		
O.S. (%) ERROR	-0.323	-0.987	-0.783	-0.579		
C.F. LA1	1.001	1.005	1.002	1.003		
C.F. LA2	1.000	1.001	1.000	1.002		

CONSOLE INDICATOR (%) 96.2 96.2 97.5 96.3

IS THE ABSOLUTE VALUE OF ELP EQUAL TO OR LESS THAN 2 % FOR ALL CHANNELS? YES NO

IS THE ABSOLUTE VALUE OF O.S. ERROR EQUAL TO OR LESS THAN 3.5 % FOR ALL CHANNELS? YES NO

IS EACH CONSOLE INDICATOR WITHIN 2 % OF CORE THERMAL POWER? YES NO

ACCEPTANCE CRITERIA : ALL ANSWERS YES

VOLTMETER MODEL AND SERIAL # _____

LAST CAL _____

DUE DATE _____

OPERATOR: *Craig E. Funt*

APPROVED: *[Signature]*

229 341

"TEMPORARY CHANGE"

Still

AP 1001

Figure 1001 - 5

Three Mile Island Nuclear Station
Temporary Change Notice (TCN)

SIDE 1

NOTE: Instructions and guidelines in AP 1001 must be followed when completing this form.

TCN NO. 2-79-070
(From TCN Log Index)

Unit No. 2

Date 3/16/79

1. Procedure 2301-3D1 RCS Inventory
No Title

2. Change (Include page numbers, paragraph numbers, and exact wording of change.)
see attached

3. Reason for Change:
To more accurately account for RCS leakage collected in the drain tank.

4. Recommended by J.E. March 3/16/79 5. J.E. March 3/16/79
Date Supervisor's Signature Date

6. Duration of TCN: No longer than ninety days from effective date of TCN or as in (a) or (b) below whichever occurs first.
(a) TCN will be cancelled by a procedure revision issued as a result of a Procedure Change Request to be submitted by MORCK (Submit PCR as soon as possible)
Supervisor Submitting TCN
(b) TCN is not valid after _____ (fill in circumstances which will result in TCN being cancelled)

7. (a) Is the procedure on the Nuclear Safety Related Procedure List? (Sec. AP 1001 - Appendix B)
If "Yes", complete Nuclear Safety Evaluation. (Side 2 of this Form) Yes No
(b) Is the procedure on the Environmental Impact Procedure List? (Sec. AP 1001 - Appendix B)
If "Yes", complete Environmental Evaluation. (Side 2 of this Form) Yes No
(c) Does the change effect the intent of the original procedure? Yes No

NOTE: If all answers are "no" the change may be approved by the Shift Supervisor. If (c) is answered "yes", the change must be reviewed by the PORC and approval by the Station/Unit Superintendent prior to implementation. If the answer to question (c) is "no" the change may be approved by two members of the plant management staff at least one of whom holds a senior reactor operators license on the unit affected in accordance with paragraph 3.6.4.2 of AP 1001.

8. Review and Approval

Block (c) "yes"	Block (c) "no"
Approved <u>[Signature]</u> <u>3/16/79</u> <small>Shift Supervisor/Foreman Date</small>	Approved _____ <small>SRO License Date</small>
Reviewed <u>[Signature]</u> <u>3/16/79</u> <small>Member Plant Mrg. Staff Date</small>	Reviewed _____ <small>Chairman of PORC Date</small>
Members Of PORC <u>[Signature]</u> <u>3/16/79</u> <small>Reviewed Date</small>	Approved _____ <small>Unit Superintendent Date</small>
Contacted <u>[Signature]</u> <u>3/16/79</u> <small>PORC Members Date</small>	Approved _____ <small>Unit Superintendent Date</small>
Approved <u>[Signature]</u> <u>3/16/79</u> <small>Unit Superintendent Date</small>	

NOTE: The block (c) "Yes" review and approval chain may be followed at anytime.

9. Approval
Manager, Generation Quality Assurance _____ Date _____
NOTE: M.G.Q.A. approval required only on certain Administrative Procedures listed in Enclosure 7 of AP 1001

10. TCN is Cancelled _____ Date _____
Shift Supervisor/Shift Foreman Date

229 343

"EVALUATION"

Three Mile Island Nuclear Station

SIDE 2

Form 100, 4

Nuclear Safety/Environmental Impact Evaluation

1. Procedure 2301-3D1 RCS Inventory
No. Title Temporary Change Notice No.

2. Nuclear Safety Evaluation

Does the attached procedure change:

- * (a) increase the probability of occurrence or the consequences of an accident or malfunction of equipment important to safety? yes no
- * (b) create the possibility for an accident or malfunction of a different type than any evaluated previously in the safety analysis report? yes no
- * (c) reduce the margin of safety as defined in the basis for any technical specification? yes no

Details of Evaluation (Explain why answers to above questions are "no". Attach additional pages if required.)

Change more accurately takes into account RC leakage collection and control in the RCS DT. Change does not affect any operating conditions, and has no effect on nuclear safety.
Evaluation By JE Noack Date 3/16/79

3. Environmental Impact Evaluation

Does the attached procedure change:

- (a) possibly involve a significant environmental impact? yes no
(if (a) is "yes", answer questions (b) and (c) and fill in "Details of Evaluation" below. If "no", state why by filling in the "Details of Evaluation" below) yes no
- * (b) have a significant adverse effect on the environment? yes no
- * (c) involve a significant environmental matter or question not previously reviewed and evaluated by the N.R.C. yes no

Details of Evaluation (Attach additional pages if required)

AM

Evaluation By _____ Date _____

1. Unit Superintendent requests PORC review Check if YES.

5. Approval

Evaluation Accompanying PCR

[Signature] 3/16/79
Unit Superintendent Date

Evaluation Accompanying TCN

Approval _____
SRO Licensee Date

Reviewed _____
Member of Plant Staff Date

Approval _____
Unit Superintendent 229 344 Date

The Evaluation "Accompanying a PCR" evaluation and approval chain may be followed at anytime.

DATA SHEET 4

RCS LEAK RATE

OPERATOR CAUSED CHANGES TO RCS INVENTORY

1. Identify operation that caused change: add water to MU-T-1

2. Time Operation Started: 0600
Time Operation Completed: 0608

3. Calculations:

4. Total change to RCS Inventory: 301 gal.

NOTE 1: If change is to RCDD enter in section 7 of Data Sheet 1
Line 15 or Data Sheet 2 Line 38.

NOTE 2: If change is to any other part of the system, enter in
section 5 of Data Sheet 1 Line 20 or Data Sheet 2 Line 33.

NOTE 3: SIGNS: Removals from the system have a negative (-) sign.
Additions to the system have a positive (+) sign.

PERFORMED BY [Signature]

DATE 3/25/79

APPROVED BY [Signature]

DATE 3/25/79

DATE: 3/25/77
TIME: 5:24:15

REACTOR COOLANT LEAKAGE TEST
SP 2301-301

NOTE: IF OPERATOR ACTION DECREASES RCS LEVELS THE DATA ENTRY FOR THAT POINT SHOULD BE NEGATIVE,
...YOU MUST ENTER NEG. PT. WITH LEAKAGE VALUES...

DESIGNATED INTERVAL (1-8 HOURS)

1
ENTER OPERATOR CAUSED CHANGES TO THE RCS FROM DS 4 (2301-301)

0.0
ENTER OPERATOR CAUSED CHANGES FROM DS 4 (2301-301)

301.0
ENTER IDENTIFIED LEAKAGE FROM DS 3 (2301-301) (GPM)

0.0
ENTER PRIMARY TO SECONDARY OTS/TUBE LEAK (GPM)

0.0

TIME	TCA (F)	TIA (F)	TIB (F)	TID (F)	TAVE (F)	PRER LVL (IN)	MURK LVL (IN)	ROBT LVL (INCHES)
5:25:12:	557.797	606.430	558.403	607.799	582.200	207.005	70.700	74.740
6:25:12:	557.009	606.510	558.301	606.277	582.148	211.075	71.937	79.305

GROSS LEAK RATE (< 10 GPM) 6.5057 GPM

TOTAL IDENTIFIED RCS LEAK RATE (< 10 GPM): 4.4250 GPM

6.16 49063

NET UNIDENTIFIED LEAK RATE (< 10 GPM): 2.1737 GPM

43179370

OPERATOR: *E. K. Keddick*

APPROVED: *F. Sherman*

POOR ORIGINAL

3700 0

1

229 346

rcsl

DATE: 3/24/79
TIME: 5:40:15

REACTOR COOLING LEAKAGE TEST
SP 2501-301

NOTE: IF OPERATOR ACTION DECREASES RCL VOLUME THE DATA ENTERED FOR TIME ACTION SHOULD BE MARKED
...YOU MUST ENTER DEC. PT. WITH LEAKAGE VALUE...

DESIRED INTERVAL (1-4 HOURS)

1

ENTER OPERATOR CAUSED CHANGE TO T.M. RCLF FROM DS 4 (2501-301)

0.0

ENTER OPERATOR CAUSED CHANGE FROM DS 4 (2501-301)

206.0

ENTER IDENTIFIED LEAKAGE FROM DS 3 (2501-301) (GPM)

0.0

ENTER PRIMARY TO SECONDARY OTS/TUBE LEAK (GPM)

0.0

TIME	TCA (F)	TMA (F)	TCS (F)	TID (F)	TAVE (F)	PRZR LVL (IN)	MTRK LVL (IN)	RODT LVL (INCHES)
5:40:14	557.242	506.274	557.701	600.151	501.000	225.100	75.001	70.532
6:40:44	571	506.280	557.340	600.270	501.011	230.55	60.174	80.370

GROSS LEAK RATE (<30 GPM):

0.5510 GPM

TOTAL IDENTIFIED RCS LEAK RATE (<10 GPM):

4.5770 GPM

NET UNIDENTIFIED LEAK RATE (<1 GPM):

1.9744 GPM

*TEN Connections

6.3919 gpm-

0.160 gpm

OPERATOR:

APPROVED:

STOP 0

229 348

This attachment is not valid if operator caused RCDT level changes were.

Record RCDT Temperature (from computer pit 1032) 72.0°F

ⓐ Calculate density (in $\frac{lb}{ft^3}$) of water in RCDT. Use line A, an assumed pressure of 15 psia, and Table 1. Interpolate.

Temperature (°F)	Density (lb/ft³) at 0 psia	Density (lb/ft³) at 15 psia
<u>50°F</u>	.016024	.015798
<u>100°F</u>	.016130	.016106

(Density $[\frac{lb}{ft^3}] = \frac{1}{v} [\frac{ft^3}{lb}]$) Density = 62.2354 $\frac{lb}{ft^3}$

ⓑ Calculate density of RC. Use average Tave and Figure 1. Density = 44.570 $\frac{lb}{ft^3}$

ⓒ Convert identified leak rate, collected in RC drum, to equivalent RC gallons.

Ident Leak Rate 4.5776 (from print-out) \times $\frac{\text{Density of RCDT line RC } 62.2354}{\text{Density of RCS line C } 44.570}$

RC equivalent Identified Leak Rate = 6.3919 gpm


ⓓ Subtract Equivalent Identified Leak Rate from Total Leak Rate to get Unidentified.

229 ~~350~~

Total Leak Rate	<u>6.5519</u>	
- Existing Ident Leak Rate	<u>6.3919</u>	gpm
Net Unident Leak Rate	<u>0.160</u>	gpm
		gpm

Accept Criteria

- Total Leak Rate must be < 30 gpm.
- Total Identified Leak Rate must be < 10 gpm.
- Net Unidentified Leak Rate must be < 1 gpm.

Performed 
Approved C. Adams

rcsl

DATE: 3/22/79 REACTOR COOLANT LEAKAGE TEST
TIME: 2:59:52 SP 2301-301

NOTE: IF OPERATOR ACTION DECREASES RCS VOLUME THE DATA ENTRY FOR THAT ACTION MUST BE NEGATIVE,
...YOU MUST ENTER DEC. PT. WITH LEAKAGE VALUES...

DESIRED INTERVAL (1-8 HOURS)

1
ENTER OPERATOR CAUSED CHANGES TO THE RCOT FROM DS 4 (2301-301)

0
ENTER OPERATOR CAUSED CHANGES FROM DS 4 (2301-301)

200.
ENTER IDENTIFIED LEAKAGE FROM DS 3 (2301-301) (GR.)

0
ENTER PRIMARY TO SECONDARY OTSG TUBE LEAK (LPH)

0

TIME	TCA (F)	TIA (F)	TCB (F)	TIB (F)	TAVE (F)	PRZR LVL (IN)	MUTK LVL (IN)	RCOT LVL (INCHES)
3: 0:16:	556.74		557.430	605.048	581.594	224.125	77.220	76.335
4: 0:18:	556.703		557.477	605.750	581.422	225.047	72.235	79.801

GROSS LEAK RATE (<30 GR.): 6.7274 GR.

TOTAL IDENTIFIED RCS LEAK RATE (<10 GR.): 4.4006 GR.

NET UNIDENTIFIED LEAK RATE (<1 GR.): 2.3268 GR. - COLLECTED .5807 gpm

OPERATOR: *H. M. ...*

APPROVED: *[Signature]*

STOP 0

229 352

Attachment 1A

- Note: This attachment is not valid if operator caused RCDT level changes were not Record RCDT temperatures. (from computer pt 1032) 75

② Calculate density (in $\frac{lb}{ft^3}$) of water in RCDT. Use line A, an assumed pressure of 15 psia, and Table 1. Interpolate.

<u>50 °F</u>	<u>0 psia</u> 0.016024	<u>500 psia</u> 0.015198
<u>100 °F</u>	0.016130	0.016106

$$\left(\text{Density} \left[\frac{lb}{ft^3} \right] \right) = \frac{1}{v} \left[\frac{L}{ft^3} \right] \quad \text{Density} = \frac{62.227}{1.12} \frac{lb}{ft^3}$$

③ Calculate density of RC. Use average Tave and Figure 1.

$$\text{Density} = \frac{44.55}{1.12} \frac{lb}{ft^3}$$

④ Convert identified leak rate, collected in RC drum tank, to equivalent RC gallons.

$$\text{Ident Leak Rate (from post-out)} \frac{44006}{1} \times \frac{\text{Density of RCDT line A} \frac{62.227}{1.12}}{\text{Density of RCS line C} \frac{44.55}{1.12}}$$

$$\text{RC equivalent Identified Leak Rate} = \frac{6.1467}{1} \text{ gpm}$$

⑤ Subtract equivalent Identified leak rate from Total Leak Rate to get Unidentified.

229 353

Attachment 1A cont.

Total Leak Rate	<u>6.7274</u>	gpm	3.9396
- Equiv. Ident Leak Rate	<u>6.1467</u>	gpm	2.8136
Net Unident Leak Rate	<u>.5807</u>	gpm	1.116

Accept Criteria

Total Leak Rate must be < 30 gpm.

Total Identified Leak Rate must be < 10 gpm.

Net Unidentified Leak Rate must be < 1 gpm.

DATA SHEET 4

RCS LEAK RATE

OPERATOR CAUSED CHANGES TO RCS INVENTORY

1. Identify operation that caused change: ADDED 200 gal
DEMIN H₂O TO MU-T.1

2. Time Operation Started: 0351

Time Operation Completed: 0353

3. Calculations:

4. Total change to RCS inventory: 200 gal.

NOTE 1: If change is to RCDT enter in section 1 of Data Sheet 1 Line 25 or Data Sheet 2 Line 38.

NOTE 2: If change is to any other part of the system, enter in section 5 of Data Sheet 1 Line 20 or Data Sheet 2 Line 33.

NOTE 3: SIGNS: Removals from the system have a negative (-) sign. Additions to the system have a positive (+) sign.

PERFORMED BY And. J. L...

DATE 3-22-79

APPROVED BY E. Guthrie

DATE 3-22-79

rsl

DATE: 3/21/70 REACTOR COOLA A LEAKAGE TEST
TIME: 1:14:33 SP 2301-301

NOTE: IF OPERATOR ACTION DECREASED RCS VOLUME THE DATA ENTRY FOR THAT ACTION MUST BE RECORDED ... YOU MUST ENTER DEC. PT. WITH LEAKAGE VALUE ...

DESIRED INTERVAL (1-3 HOURS)

1

ENTER OPERATOR CAUSED CHANGES TO THE ROOT FROM DS 4 (2301-301)

0

ENTER OPERATOR CAUSED CHANGES FROM DS 4 (2301-301)

207.

ENTER IDENTIFIED LEAKAGE FROM DS 3 (2301-301) (GPM)

0

ENTER PRIMARY TO SECONDARY OTSU TUBE LEAK (GPM)

0

TIME	TCA (F)	TIA (F)	TOD (F)	TIB (F)	TAVE (F)	PRZR LVL (IN)	MUT. LVL (IN)	RCDY LVL (INCHES)
	556.030	605.700	557.040	605.727	501.100	215.301	75.700	76.000
2:14:00	556.041	605.555	557.450	605.510	501.201	225.100	71.400	79.100

GROSS LEAK RATE (<30 GPM): 0.0510 GPM

TOTAL IDENTIFIED RCS LEAK RATE (<10 GPM): 4.1831 GPM

NET UNIDENTIFIED LEAK RATE (<1 GPM): 1.8680 GPM

OPERATOR: *Earl O. Hemmels*

APPROVED: *C. Smith*

Collected - 22 GPM

229 357

STOP 0

W. M. King

AP 1001

Three Mile Island Nuclear Station
Temporary Change Notice (TCN)

SIDE 1

Figure 1001 - 5

TCN NO. 2-79-025

(From TCN List to...)

Unit No. 2

Date 3/16/79

NOTE: Instructions and guidelines in AP 1001 must be followed when completing this form.

1. Procedure 2301-3A1 RCS Inventory
No. Title

2. Change (Include page numbers, paragraph numbers, and exact wording of change.)
see attached

3. Reason for Change:
To more accurately account for RCS leakage collected in the drain tank.

4. Recommended by JE Morck 3/14/79 5. JE Morck 3/16/79
Date Supervisor's Signature Date

6. Duration of TCN - No longer than ninety days - effective date of TCN or as (a) or (b) below whichever occurs first.
(a) TCN will be cancelled by a procedure revision issued as a result of a Procedure Change Request to be submitted by MORCK (Submit PCR as soon as possible)
Supervisor Submitting TCN
(b) TCN is not valid after _____ (fill in circumstances which will result in TCN being cancelled)

7. (a) Is the procedure on the Nuclear Safety Related Procedure List? (Sec. AP 1001 - Appendix B)
If "Yes", complete Nuclear Safety Evaluation. (Side 2 of this Form) Yes No
(b) Is the procedure on the Environmental Impact Procedure List? (Sec. AP 1001 - Appendix B)
If "Yes", complete Environmental Evaluation. (Side 2 of this Form) Yes No
(c) Does the change effect the intent of the original procedure? Yes No

NOTE: If all answers are "no" the change may be approved by the Shift Supervisor. If question (c) is answered "yes", the change must be reviewed by the PORC and approval by the Station/Unit Superintendent prior to implementation. If the answer to question (c) is "no" the change may be approved by two members of the plant management staff at least one of whom holds a senior reactor operators license on the unit affected in accordance with paragraph 3.6.4.2 of AP 1001.

8. Review and Approval

Block (c) "yes"	Block (c) "no"
Approved <u>[Signature]</u> <u>3/16/79</u> Shift Supervisor/Foreman Date	Approved _____ SRO License Date
Reviewed <u>JE Morck</u> <u>3/14/79</u> <u>JE Morck</u> <u>3/14/79</u> Members Date	Reviewed _____ Member Plant Mrg. Staff Date
Members Of PORC <u>[Signature]</u> <u>3/16/79</u> <u>[Signature]</u> <u>3/16/79</u> Date	Reviewed _____ Chairman of PORC Date
Contacted <u>[Signature]</u> <u>3/16/79</u> PORC Members Date	Approved _____ Unit Superintendent Date
Approved <u>[Signature]</u> <u>3/16/79</u> Unit Superintendent Date	

NOTE: The block (c) "Yes" review and approval chain may be followed at anytime.

9. Approval
Manager, Generation Quality Assurance _____ Date _____
NOTE: M/GQA approval required only on certain Administrative Procedures listed in Enclosure 7 of AP 1001

10. TCN is Cancelled _____
Shift Supervisor/Shift Foreman Date

1001-4

Nuclear Safety/Environmental Impact Evaluation

Procedure 2301-3D1

RCS Inventory

Temporary Change Notice No.

2. Nuclear Safety Evaluation

Does the attached procedure change:

- * (a) increase the probability of occurrence or the consequences of an accident or malfunction of equipment important to safety? yes no
- * (b) create the possibility for an accident or malfunction of a different type than any evaluated previously in the safety analysis report? yes no
- * (c) reduce the margin of safety as defined in the basis for any technical specification? yes no

Details of Evaluation (Explain why answers to above questions are "no". Attach additional pages if required.)

Change more accurately takes into account RC leakage, collect & record in the RC DT. Change does not affect any operating conditions, and has no effect on nuclear safety.

Evaluation By J E Mouch Date 3/16/79

3. Environmental Impact Evaluation

Does the attached procedure change:

- (a) possibly involve a significant environmental impact? yes no
(if 3(a) is "yes", answer questions (b) and (c) and fill in "Details of Evaluation" below. If "no", state why by filling in the "Details of Evaluation" below) yes no
- * (b) have a significant adverse effect on the environment? yes no
- * (c) involve a significant environmental matter or question not previously reviewed or evaluated by the N.R.C. yes no

Details of Evaluation (Attach additional pages if required)

NA

Evaluation By _____ Date _____

4. Unit Superintendent requests PORC review Check if YES.

5. Approval

Evaluation Accompanying PCR

Evaluation Accompanying TCN

[Signature] 3/16/79
Unit Superintendent Date

Approval _____ SRO Licensee Date _____
Reviewed _____ Member of Plant Staff Date _____
Approval _____ Unit Superintendent Date _____

The Evaluation Accompanying a PCR evaluation and approval chain may be followed at anytime.

229 359

Attachment 1A

Note: This attachment is not valid if operator caused RCDT level changes were recorded RCDT temperature (from computer pt 1032) 65

Ⓒ Calculate density (in $\frac{lb}{ft^3}$) of water in P-DT. Use line A, an assumed pressure of 15 psia, and Table 1. Interpolate.

<u>50 °F</u>	$\frac{0 \text{ psia}}{.016024}$	$\frac{500 \text{ psia}}{.015198}$
<u>100 °F</u>	.016130	.016106

(Density $[\frac{lb}{ft^3}] = \frac{1}{v} [\frac{ft^3}{lb}]$) Density = $\frac{62.1}{\frac{1}{ft^3}}$

Ⓒ Calculate density of RC. Use average Tave and Figure 1. Density = $\frac{44.57}{ft^3}$

Ⓒ Convert identified leak rate collected in RC drain tank, to equivalent RC gallons.

Ident Leak Rate $\frac{4.1839}{\text{(from print-out)}}$ X $\frac{\text{Density of RCDT line A } 62.1}{\text{Density of RCs line C } 44.57}$

RC equivalent Identified Leak Rate = $\frac{5.8294}{\text{gpm}}$

Ⓒ Subtract Equivalent Identified Leak Rate from Total Leak Rate to get Unidentified.

229 360

POOR ORIGINAL









IMAGE EVALUATION
TEST TARGET (MT-3)










IMAGE EVALUATION
TEST TARGET (MT-3)









IMAGE EVALUATION
TEST TARGET (MT-3)










IMAGE EVALUATION
TEST TARGET (MT-3)



Attachment 1A cont.

Total Leak Rate	<u>6.0519</u>	gpm	3.9396
- Equals Identified Leak Rate	<u>5.8294</u>	gpm	2.8136
Net Unidentified Leak Rate	<u>.2225</u>	gpm	1.116

Accept Criteria

- Total Leak Rate must be < 30 gpm.
- Total Identified Leak Rate must be < 10 gpm.
- Net Unidentified Leak Rate must be < 1 gpm.

POOR ORIGINAL 230 001



efpd
EFPD: 86.327

lrcsl

DATE: 3/19/79 REACTOR COOLANT LEAKAGE TEST
TIME: 0:58:10 SP 2301-301

NOTE: IF OPERATOR ACTION DECREASES ROD VOLUME AND DVM ENTRY PALS SAME NOT IN LOGS IDENTIFY
...YOU MUST ENTER DEC. PV. WITH LEAKAGE VALUES...

DESIRABLE INTERVAL (1-8 HOURS)

1 ENTER OPERATOR CAUSED CHANGES TO THE ROD FROM DS 4 (2301-301)

0 ENTER OPERATOR CAUSED CHANGES FROM DS 4 (2301-301)
200.

ENTER IDENTIFIED LEAKAGE FROM DS 3 (2301-301) (2301)

ENTER PRIMARY TO SECONDARY OTOR TUBE LEAK (2301)

TIME	TCA (F)	TIA (F)	TOS (F)	TIS (F)	TAVE (F)	PRIM LVL (IN)	MULT LVL (IN)	RODT LVL (IN)
0:58:43	556.953	605.005	557.713	605.773	581.555	223.403	74.807	...
1:58:43	556.453	605.303	557.003	605.414	581.073	220.873	60.657	81.253

GROSS LEAK RATE (<3) GPM): 5.3520 GPM

TOTAL IDENTIFIED ROJ LEAK RATE (<1) GPM): 3.9801 GPM

NET UNIDENTIFIED LEAK RATE (<1 GPM): 1.3900 GPM

Collected Equivalent - .185

OPERATOR: *Hugh M. Green*

APPROVED: *C. G. White*

POOR ORIGINAL

230 003

"TEMPORARY CHANGE" Working

AP 1001

Three Mile Island Nuclear Station
Temporary Change Notice (TCN)

SIDE 1

Figure 1001-5

NOTE: Instructions and guidelines in AP 1001 must be followed when completing this form.

TCN NO. 2-77-004
(From TCN List Index)

Unit No. 2

Date 3/16/79

1. Procedure 2301-3D1 RCS Inventory
No Title

2. Change (List page numbers, paragraph numbers, and exact wording of change.)
see attached

3. Reason for Change:
To more accurately account for RCS leakage collected in the drain tank.

4. Recommended by JE Murch 3/16/79 5. JE Murch 3/16/79
Date Supervisor's Signature Date

6. Duration of TCN - No longer than ninety days from effective date of TCN or as in (a) or (b) below whichever occurs first.
(a) TCN will be cancelled by a procedure revision issued as a result of a Procedure Change Request to be submitted by MURCK (Submit PCR as soon as possible)
Supervisor Submitting TCN
(b) TCN is not valid after _____
(fill in circumstances which will result in TCN being cancelled)

7. (a) Is the procedure on the Nuclear Safety Related Procedure List? (Sec. AP 1001 - Appendix B)
If "Yes", complete Nuclear Safety Evaluation. (Side 2 of this Form) Yes No
(b) Is the procedure on the Environmental Impact Procedure List? (Sec. AP 1001 - Appendix B)
If "Yes", complete Environmental Evaluation. (Side 2 of this Form) Yes No
(c) Does the change affect the intent of the original procedure? Yes No

NOTE: If all answers are "no" the change may be approved by the Shift Supervisor. If question (c) is answered "yes", the change must be reviewed by the PORC and approval by the Station/Unit Superintendent prior to implementation. If the answer to question (c) is "no" the change may be approved by two members of the plant management staff at least one of whom holds a senior reactor operators license on the unit affected in accordance with paragraph 3.6.4.2 of AP 1001.

8. Review and Approval

Block (c) "yes"		Block (c) "no"	
Approved	<u>[Signature]</u> <u>3/16/79</u> Shift Supervisor/Foreman Date	Approved	_____ SRO License Date
Reviewed	<u>JE Murch</u> <u>3/16/79</u> _____ Date	Reviewed	_____ Member Plant Mrg. Staff Date
Members	<u>[Signature]</u> <u>3/16/79</u> _____ Date	Reviewed	_____ Chairman of PORC Date
Of PORC	<u>[Signature]</u> <u>3/16/79</u> _____ Date	Approved	_____ Unit Superintendent Date
Contacted	<u>[Signature]</u> <u>3/16/79</u> _____ Date	Approved	_____ Unit Superintendent Date
Approved	<u>[Signature]</u> <u>3/16/79</u> _____ Date		

NOTE: The block (c) "Yes" review and approval chain may be followed at anytime.

9. Approval
Manager, Generation Quality Assurance _____ Date _____

NOTE: MGR A approval required only on certain Administrative Procedures listed in Enclosure 7 of AP 1001

230 004

10. TCN is Cancelled _____
Shift Supervisor/Shift Foreman Date

"EVALUATION"

Three Mile Island Nuclear Station

SIDE 2

1001-4

Nuclear Safety/Environmental Impact Evaluation

Procedure

2301-301

PCS Inventory

Temporary Change Notice No.

2 Nuclear Safety Evaluation

Does the attached procedure change:

- (a) increase the probability of occurrence or the consequences of an accident or malfunction of equipment important to safety? yes no
- (b) create the possibility for an accident or malfunction of a different type than any evaluated previously in the safety analysis report? yes no
- (c) reduce the margin of safety as defined in the basis for any technical specification? yes no

Details of Evaluation (Explain why answers to above questions are "no". Attach additional pages if required.)

Change now accurately takes into account RC leakage, collect and cooled in the RCDT. Change does not affect any operating conditions, and has no effect on nuclear safety

Evaluation By J.E. Morck Date 3/16/79

3 Environmental Impact Evaluation

Does the attached procedure change:

- (a) possibly involve a significant environmental impact? yes no
(if 3(a) is "yes", answer questions (b) and (c) and fill in "Details of Evaluation" below. "no" by filling in the "Details of Evaluation" below) yes no
- (b) have a significant effect on the environment? yes no
- (c) involve a significant environmental matter or question not previously reviewed and evaluated by the N.R.C. yes no

Details of Evaluation (Attach additional pages if required)

[Handwritten signature]

Evaluation By _____ Date _____

4 Unit Superintendent requests PORC review Check if YES.

5 Approval

Evaluation Accompanying PCR

[Signature] 3/16/79
 Unit Superintendent Date

Evaluation Accompanying TCN

Approval _____ Date _____
 SRO Licensee
 Reviewed _____ Date _____
 Member of Plant Staff
 Approval _____ Date _____
 Unit Superintendent

The Evaluation Accompanying a PCR evaluation and approval chain may be followed at anytime

230 005

Attachment 1A

Note: This attachment is not valid if operator caused RCDT level changes were not record RCDT temperature (from computer pt 1032) 72

(C) Calculate density (in $\frac{lb}{ft^3}$) of water in RCDT. Use line H, assumed pressure of 15 psia, and Table 1. Interpolate.

<u>50°F</u>	<u>0 psia</u> 0.016024	<u>500 psia</u> 0.015198
<u>100°F</u>	0.016130	0.016106

$$\left(\text{Density} \left[\frac{lb}{ft^3}\right] = \frac{1}{v} \left[\frac{L}{ft^3}\right]\right) \quad \text{Density} = \frac{62.3}{1} \frac{lb}{ft^3}$$

(D) Calculate density of RC. Use average Tave and Figure 1. Density = $\frac{44.55}{1} \frac{lb}{ft^3}$

(E) Convert identified leak rate, collected in RC drum tank, to equivalent RC gallons.

$$\text{Ident Leak Rate (from print-out)} \frac{3.9601}{1} \times \frac{\text{Density of RCDT line RD} \frac{62.3}{1}}{\text{Density of RCs line C} \frac{44.55}{1}}$$

$$\text{RC equivalent Identified Leak Rate} = \frac{5.5379}{1} \text{ gpm.}$$

(F) Subtract Equivalent Identified Leak Rate from Total Leak Rate to get Unidentified.

Attachment 1A cont.

Total Leak Rate	<u>5.3528</u>	gpm	3.09396
- Equals Ident Leak Rate	<u>5.5379</u>	gpm	2.8136
Net Unident Leak Rate	<u>- .1851</u>	gpm	1.116

Accept Criteria

Total Leak Rate must be < 30 gpm.

Total Identified Leak Rate must be < 10 gpm.

Net Unidentified Leak Rate must be < 1 gpm.

DATA SHEET 4

RCS LEAK RATE

OPERATOR CAUSED CHANGES TO RCS INVENTORY

1. Identify operation that caused change: ADDED D.W. TO
MAINTENANCE TK

2. Time Operation Started: 0150

Time Operation Completed: 0152

3. Calculations:

4. Total change to RCS inventory: 200 gal.

NOTE 1: If change is to RCDT enter in section 7 of Data Sheet 1
Line 25 or Data Sheet 2 Line 38.

NOTE 2: If change is to any other part of the system, enter in
section 5 of Data Sheet 1 Line 20 or Data Sheet 2 Line 33.

NOTE 3: SIGNS: Removals from the system have a negative (-) sign.
Additions to the system have a positive (+) sign.

PERFORMED BY [Signature]

DATE 3-17-79

APPROVED BY [Signature]

DATE 3-19-79

rcsl

DATE: 3/17/73 REACTOR COOLANT LEAKAGE TEST
TIME: 2:47:43 SP 2301-301

NOTE: IF OPERATOR ACTION DECREASES RCS VOLUME THE DATA ENTRY FOR THAT ACTION MUST BE NEGATIVE,
...YOU MUST ENTER NEG. PP. WITH LEAKAGE VALUES...

DESIRED INTERVAL (1-8 HOURS)

1
ENTER OPERATOR CAUSED CHANGES TO THE ROOT FROM DS 4 (2301-301)

0
ENTER OPERATOR CAUSED CHANGES FROM DS 4 (2301-301)

207.
ENTER IDENTIFIED LEAKAGE FROM DS 3 (2301-301) (GPM)

0
ENTER PRIMARY TO SECONDARY D730 TUBE LEAK (G)

TIME	TCA (F)	TIA (F)	TCD (F)	TIB (F)	TAVE (F)	PRZR LVL (IN)	MUTK LVL (IN)	RODT LVL (INCHES)
2:40:13:	557.016	600.148	557.736	600.234	581.731	228.330	69.241	76.102
3:40:13:	557.305	600.531	558.031	600.523	582.014	230.623	67.500	79.300

GROSS LEAK RATE (<10 GPM): 4.4297 GPM

TOTAL IDENTIFIED RCS LEAK RATE (<10 GPM): 3.8798 GPM

NET UNIDENTIFIED LEAK RATE (<1 GPM): 0.5497 GPM

OPERATOR:

Hugh W. Lamm

WRITER:

C. Guthrie

230 010

DATA SHEET 1

RCS LEAK RATE

OPERATOR CAUSED CHANGES TO RCS INVENTORY

1. Identify operation that caused change: Adding H₂O To
MU-T-1

2. Time Operation Started: 0340
Time Operation Completed: 0345

3. Calculations:

4. Total change to RCS inventory: 207 gal.

NOTE 1: If change is to the reactor in section 7 of Data Sheet 1
Line 25 or Data Sheet 2 Line 38.

NOTE 2: If change is to any other part of the system, enter in
section 5 of Data Sheet 1 Line 20 or Data Sheet 2 Line 33.

NOTE 3: SIGNS: Removals from the system have a negative (-) sign.
Additions to the system have a positive (+) sign.

PERFORMED BY Shelby M. Brown

DATE 3-17-79

APPROVED BY C. Guthrie

DATE 3-17-79

AP 1001

SIDE 1

Three Mile Island Nuclear Station
Temporary Change Notice (TCN)

Figure 1001-5

TCN NO. 2 19-000

(From TCN List Index)

NOTE: Instructions and guidelines in AP 1001 must be followed when completing this form.

Unit No. 2

Date 3/16/79

1 Procedure 2301-3A1 RCS Inventory

No

Title

2 Change (Include page numbers, paragraph numbers, and exact wording of change.)

see attached

3 Reason for Change:

To more accurately account for RCS leakage collected in the drain tank.

4 Recommended by J.E. March 3/16/79 5. J.E. March 3/16/79

Date

Supervisor's Signature

Date

6 Duration of TCN - No longer than ninety days from effective date of TCN or as in (a) or (b) below whichever occurs first.

(a) TCN will be cancelled by a procedure revision issued as a result of a Procedure Change Request to be submitted by MORCK (Submit PCR as soon as possible)

Supervisor Submitting TCN

(b) TCN is not valid after _____ (fill in circumstances which will result in TCN being cancelled)

- 7 (a) Is the procedure on the Nuclear Safety Related Procedure List? (Sec. AP 1001 - Appendix B) If "Yes", complete Nuclear Safety Evaluation. (Side 2 of this Form) Yes No
- (b) Is the procedure on the Environmental Impact Procedure List? (Sec. AP 1001 - Appendix B) If "Yes", complete Environmental Evaluation. (Side 2 of this Form) Yes No
- (c) Does the change effect the intent of the original procedure? Yes No

NOTE: If all answers are "no" the change may be approved by the Shift Supervisor. If question (c) is answered "yes", the change must be reviewed by the PORC and approval by the Station/Unit Superintendent prior to implementation. If the answer to question (c) is "no" the change may be approved by two members of the plant management staff at least one of whom holds a senior reactor operators license on the unit affected in accordance with paragraph 3.6.4.2 of AP 1001.

8. Review and Approval

Block (c) "yes"	Block (c) "no"
Approved <u>[Signature]</u> <u>3/16/79</u>	Approved _____
Shift Supervisor/Foreman	SRO License
Reviewed <u>[Signature]</u> <u>3/16/79</u>	Reviewed _____
Members of PORC	Member Plant Mrg. Staff
Reviewed <u>[Signature]</u> <u>3/16/79</u>	Reviewed _____
Members of PORC	Chairman of PORC
Contacted <u>[Signature]</u> <u>3/16/79</u>	Contacted _____
PCRC Members	Unit Superintendent
Approved <u>[Signature]</u> <u>3/16/79</u>	Approved _____
Unit Superintendent	Unit Superintendent

NOTE: The block (c) "Yes" review and approval chain may be followed at anytime.

Approval
Manager, Generation Quality Assurance _____ Date _____

NOTE: MGR approval required only on certain Administrative Procedures listed in Enclosure 7 of AP 1001

10 TCN is Cancelled _____ Date _____

Shift Supervisor/Shift Foreman

230 012

1001-4

Nuclear Safety/Environmental Impact Evaluation

Procedure 2301-3D1 RCS Inventory Temporary Change Notice No. _____

Nuclear Safety Evaluation

Does the attached procedure change:

- * (a) increase the probability of occurrence or the consequences of an accident or malfunction of equipment important to safety? yes no
- * (b) create the possibility for an accident or malfunction of a different type than any evaluated previously in the safety analysis report? yes no
- * (c) reduce the margin of safety as defined in the basis for any technical specification? yes no

Details of Evaluation (Explain why answers to above questions are "no". Attach additional pages if required.)

Change more accurately takes into account RC leakage, either and cooled in the RC DT. Change does not affect any operating conditions, and has no effect on nuclear safety.

Evaluation By J E Morck Date 3/16/79

3. Environmental Impact Evaluation

Does the attached procedure change:

- (a) possibly involve a significant environmental impact? yes no
(if 3(a) is "yes", answer questions (b) and (c) and fill in "Details of Evaluation" below. If "no", state why by filling in the "Details of Evaluation" below) yes no
- * (b) have a significant adverse effect on the environment? yes no
- * (c) involve a significant environmental matter or question not previously reviewed and evaluated by the N.R.C. yes no

Details of Evaluation (Attach additional pages if required)

NA

Evaluation By _____ Date _____

1 Unit Superintendent requests PORC review Check if YES.

2 Approval

Evaluation Accompanying PCR

[Signature] [Signature]
Unit Superintendent Date

Evaluation Accompanying TCN

Approval _____ SRO Licensee _____ Date _____

Reviewed _____ Member of Plant Staff _____ Date _____

Approval _____ Unit Superintendent _____ Date _____

The Evaluation Accompanying a PCR evaluation and approval chain may be followed at anytime.

230 013

... attachment is not valid if operator caused RCDT level changes were
 ... old RCDT temperature (from computer pt 1032) 58.1

② Calculate density (in $\frac{lb}{ft^3}$) of water in RCDT. Use line A, an assumed pressure of 15 psia, and Table 1. Interpolate.

	0 psia	500 psia
50 °F	.016024	.015798
	.016098	
100 °F	.016130	.016106

(Density $[\frac{lb}{ft^3}] = \frac{1}{v} [\frac{ft^3}{lb}]$) Density = $\frac{62.31}{1.1}$ $\frac{lb}{ft^3}$

③ Calculate density of RC. Use average Tave and Figure 1. Density = $\frac{44.55}{1.1}$ $\frac{lb}{ft^3}$

④ Convert identified leak rate, 3.8798 in RC drum tank, to equivalent RC gallons.

Ident Leak Rate $\frac{3.8798}{(from\ pint\ out)}$ $\times \frac{\text{Density of RCDT line A}}{\text{Density of RCs line C}} = \frac{62.31}{44.58}$

RC equivalent Identified Leak Rate = $\frac{5.4264}{1.1}$ $\frac{gpm}{1.1}$

⑤ Subtract Equivalent Identified Leak Rate from Total Leak Rate to get Unidentified.

Total Leak Rate	4.4297	
- Equiv. Ident Leak Rate	5.4264	gpm
Net Unident Leak Rate	- .9967	gpm
		gpm.

Accept Criteria

- Total Leak Rate must be < 30 gpm.
- Total Identified Leak Rate must be < 10 gpm.
- Net Unidentified Leak Rate must be < 1 gpm.

1rcsl

DATE: 3/16/73 REACTOR COOLANT LEAKAGE TEST
TIME: 20: 8:44 SP 2301-301

NOTE: IF OPERATOR ACTION DECREASED RCS VOLUME THE DATA ENTRY FOR THAT ACTION MUST BE NEGATIVE,
...YOU MUST ENTER DEC. PT. WITH LEAKAGE VALUE...

DESIRED INTERVAL (1-3 HOURS)

ENTER OPERATOR CAUSED CHANGES TO THE RCS FROM DS 4 (2301-301)

.0
ENTER OPERATOR CAUSED CHANGES FROM DS 4 (2301-301)

204.0
ENTER IDENTIFIED LEAKAGE FROM DS 3 (2301-301) (GPM)

.0
ENTER PRIMARY TO SECONDARY OFSG TUBE LEAK (GPM)

.0

TIME	TON	TIA (F)	TOD (F)	THD (F)	TAVE (F)	PRER LVL (IN)	MTRK LVL (IN)	RCDT LVL (INCHES)
20: 9: 7:	556.713	600.000	557.000	600.000	581.602	228.300	62.301	76.182
21: 9: 7:	556.713	600.000	557.000	600.000	581.583	228.300	59.920	79.480

GROSS LEAK RATE (<30 GPM): 4.8614 GPM

TOTAL IDENTIFIED RCS LEAK RATE (<10 GPM): 4.0099 GPM

NET UNIDENTIFIED LEAK RATE (<1 GPM): 0.8514 GPM

OPERATOR:

Craig C Faust

APPROVED:

F Schemm

230 017

TEMPORARY CHANGE

AP 1001

Three Mile Island Nuclear Station
Temporary Change Notice (TCN)

SIDE 1

Figure 1001 - 5

NOTE: Instructions and guidelines in AP 1001 must be followed when completing this form.

TCN NO. 2-79-070
(From TCN Log Index)
Unit No. 2
Date 3/16/79

1. Procedure 2301-3D1 RCS Inventory
No. Title

2. Change (Include page numbers, paragraph numbers, and exact wording of change.)
see attached

3. Reason for Change:
To more accurately account for RCS leakage collected in the drain tank.

4. Recommended by JE Morck 3/16/79 5. JE Morck 3/16/79
Date Supervisor's Signature Date

6. Duration of TCN - No longer than ninety days from effective date of TCN or as in (a) or (b) below whichever occurs first.

- (a) TCN will be cancelled by a procedure revision issued as a result of a Procedure Change Request to be submitted by MORCK (Submit PCR as soon as possible)
Supervisor Submitting TCN
- (b) TCN is not valid after _____ (fill in circumstances which will result in TCN being cancelled)

- 7. (a) Is the procedure on the Nuclear Safety Related Procedure List? (Sec. AP 1001 - Appendix B)
If "Yes", complete Nuclear Safety Evaluation. (Side 2 of this Form) Yes No
- (b) Is the procedure on the Environmental Impact Procedure List? (Sec. AP 1001 - Appendix B)
If "Yes", complete Environmental Evaluation. (Side 2 of this Form) Yes No
- (c) Does the change effect the intent of the original procedure? Yes No

NOTE: If all answers are "no" the change may be approved by the Shift Supervisor. If question (c) is answered "yes", the change must be reviewed by the PORC and approval by the Station/Unit Superintendent prior to implementation. If the answer to question (c) is "no" the change may be approved by two members of the plant management staff at least one of whom holds a senior reactor operators license on the unit affected in accordance with paragraph 3.6.4.2 of AP 1001.

8. Review and Approval

Block (c) "yes"	Block (c) "no"
Approved <u>[Signature]</u> <u>3/16/79</u> Shift Supervisor/Foreman Date	Approved _____ SRO License Date
Reviewed <u>JE Morck</u> <u>3/16/79</u> <u>[Signature]</u> <u>3/16/79</u> Date	Member Plant Mrg. Staff Date
Members <u>[Signature]</u> <u>3/16/79</u> Of PORC <u>[Signature]</u> <u>3/16/79</u> Date	Reviewed _____ Chairman of PORC Date
Contacted <u>[Signature]</u> <u>3/16/79</u> Date	Approved _____ Unit Superintendent Date
Approved <u>[Signature]</u> <u>3/16/79</u> Unit Superintendent Date	

NOTE: The block (c) "Yes" review and approval chain may be followed at anytime.

9. Approval
Manager, Generation Quality Assurance _____ Date _____

NOTE: MGQA approval required only on certain Administrative Procedures listed in Enclosure of AP 1001

10. TCN is Cancelled _____
Shift Supervisor/Shift Foreman Date

230-018

"EVALUATION"

AP 1001

Three Mile Island Nuclear Station

SIDE 2

Figure 1001-4

Nuclear Safety/Environmental Impact Evaluation

1. Procedure 2301-3D1 RCS Inventory
No. Title Temporary Change Notice No.

2. Nuclear Safety Evaluation

Does the attached procedure change:

- * (a) increase the probability of occurrence or the consequences of an accident or malfunction of equipment important to safety? yes no
- * (b) create the possibility for an accident or malfunction of a different type than any evaluated previously in the safety analysis report? yes no
- * (c) reduce the margin of safety as defined in the basis for any technical specification? yes no

Details of Evaluation (Explain why answers to above questions are "no". Attach additional pages if required.)

Change more accurately takes into account RC leakage, collection and cooled in the RC DT. Change does not affect any operating conditions, and has no effect on nuclear safety.
Evaluation By J E Morck Date 3/16/79

3. Environmental Impact Evaluation

Does the attached procedure change:

- (a) possibly involve a significant environmental impact? yes no
(if 3(a) is "yes", answer questions (b) and (c) and fill in "Details of Evaluation" below.
If "no", state why by filling in the "Details of Evaluation" below) yes no
- * (b) have a significant adverse effect on the environment? yes no
- * (c) involve a significant environmental matter or question not previously reviewed evaluated by the N.R.C. yes no

Details of Evaluation (Attach additional pages if required)

NA
Evaluation By _____ Date _____

4. Unit Superintendent requests PORC review Check if YES.

5. Approval

Evaluation Accompanying PCR

Evaluation Accompanying TCN

[Signature] 3/16/79
Unit Superintendent Date

Approval _____
SRO Licensee Date

Reviewed _____
Member of Plant Staff Date

Approval _____
Unit Superintendent Date

(E) The Evaluation "Accompanying a PCR" evaluation and approval chain may be followed at anytime.

230 019

Attachment 1A

Note: This attachment is not valid if operator caused RCDT level changes were not

① Record RCDT temperature (from computer pt 1032) 100

② Calculate density (in $\frac{lb}{ft^3}$) of water in RCDT. Use line A, an assumed pressure of 15 psia, as Table 1. Interpolate

<u>50 °F</u>	<u>0 psia</u> 0.016024	<u>500 psia</u> 0.015198
<u>100 °F</u>	0.016130	0.016106

61.99628

$$\left(\text{Density} \left[\frac{lb}{ft^3} \right] = \frac{1}{v} \left[\frac{ft^3}{lb} \right] \right) \quad \text{Density} = \underline{0.016130} \frac{lb}{ft^3}$$

③ Calculate density of RC. Use average Tave and Figure 1. 44.286195
Density = 0.0225804 $\frac{lb}{ft^3}$

④ Convert identified leak rate, collected in RC drum tank, to equivalent RC gallons.

$$\begin{array}{r} \text{Ident Leak Rate} \\ \text{(from print out)} \end{array} \frac{\cancel{3.614} \times 100000}{\cancel{3.614}} \times \frac{\text{Density of RCDT}}{\text{Density of RCs}} = \frac{61.99628}{44.286195}$$

RC equivalent Identified leak rate = 5.613 gpm.

⑤ Subtract Equivalent Identified leak rate from Total Leak rate to get Unidentified.

230 020

POOR ORIGINAL

Attachment 1A cont.

Total Leak Rate	<u>4.5614</u>	gpm
- Equiv. Ident Leak Rate	<u>5.6136788</u>	gpm
Net Unident Leak Rate	<u>-1.0522</u>	gpm.

Accept Criteria

Total Leak Rate must be < 30 gpm.

Total Identified Leak Rate must be < 10 gpm.

Net Unidentified Leak Rate must be < 1 gpm.

POOR ORIGINAL

230 021

rcsl

DATE: 5/15/79 REACTOR COOLANT LEAKAGE TEST
TIME: 4:50: 8 SF 2301-3D1

NOTE: IF OPERATOR ACTION DECREASES RCS VOLUME THE DATA ENTRY FOR THAT ACTION MUSTBE NEGATIVE,
...YOU MUST ENTER DEC. PT. WITH LEAKAGE VALUES...

DESIRED INTERVAL (1-8 HOURS)

1 ENTER OPERATOR CAUSED CHANGES TO THE RCOT FROM DS 4 (2301-3D1)

0 ENTER OPERATOR CAUSED CHANGES FROM DS 4 (2301-3D1)

0 ENTER IDENTIFIED LEAKAGE FROM DS 3 (2301-3D1) (CPM)

0 ENTER PRIMARY TO SECONDARY OTSG TUBE LEAK (CPM)

TIME	TCA (F)	THA (F)	TCB (F)	THP (F)	TAVE (F)	PPZP LVL (IN)	MUTK LVL (IN)	RCOT LVL (INCHES)
4:50:32	557.209	605.659	557.992	605.828	581.734	220.777	71.762	75.578
5:50:32	557.508	605.945	558.250	606.945	581.908	220.168	66.386	70.652

CROSS LEAK RATE (<30 CPM): 3.0098 CPM

TOTAL IDENTIFIED RCS LEAK RATE (<10 CPM): 3.7516 CPM

NET UNIDENTIFIED LEAK RATE (<1 CPM): 0.0562 CPM

OPERATOR: *Brooke*

APPROVED: *B. Smith*

POOR ORIGINAL

STOP

230 023

DATE: 3/14/79
TIME: 12: 5: 3

REACTOR COOLANT LEAKAGE TEST
SP 2301-301

NOTE: IF OPERATOR ACTION DECREASES RCS VOLUME THE DATA ENTRY FOR THAT ACTION MUST BE NEGATIVE
... YOU MUST ENTER DEC. PT. WITH LEAKAGE VALUES...

DESIRED INTERVAL (1-8 HOURS)

1
ENTER OPERATOR CAUSED CHANGES TO THE VOT FROM DS 4 (2301-301)
500.0

ENTER OPERATOR CAUSED CHANGES FROM DS 4 (2301-301)

0
ENTER IDENTIFIED LEAKAGE FROM DS 3 (2301-301) (GPM)

ENTER PRIMARY TO SECONDARY VOTSGTUBE LEAK (GPM)

0

TIME	TCA (F)	TIA (F)	TCB (F)	TIB (F)	TAVE (F)	PRZR LVL (IN)	MIXR LVL (IN)	ROBT LVL (INCHES)
12: 5:28:	557.130	606.117	557.836	606.141	531.813	227.461	72.741	76.738
13: 5:28:	556.703	605.797	557.433	605.950	531.445	228.302	72.833	73.222

GROSS LEAK RATE (<30 GPM): -6.7463 GPM


TOTAL IDENTIFIED RCS LEAK RATE (<10 GPM): -6.4372 GPM

NET UNIDENTIFIED LEAK RATE (<1 GPM): -0.2436 GPM

OPERATOR:



APPROVED:



POOR ORIGINAL

STOP 0

230 025

DATA SHEET 4

RCS LEAK RATE

OPERATOR CAUSED CHANGES TO RCS INVENTORY

1. Identify operation that caused change: Increase mo Tank level

2. Time Operation Started: 1155
Time Operation Completed: 1200
3. Calculations:

4. Total change to RCS inventory: 305 gal.

NOTE 1: If change is to RCDT enter in section 7 of Data Sheet 1 Line 25 or Data Sheet 2 Line 38.

NOTE 2: If change is to any other part of the system, enter in section 5 of Data Sheet 1 Line 20 or Data Sheet 2 Line 33.

NOTE 3: SIGNS: Removals from the system have a negative (-) sign.
Additions to the system have a positive (+) sign.

PERFORMED BY Dennis Olson

DATE 3/13/79

APPROVED BY A Miller

DATE 3-13-79

rcs1

DATE: 3/13/79 REACTOR COOLANT LEAKAGE TEST
TIME: 10:59: 4 SP 2301-3D1

NOTE: IF OPERATOR ACTION DECREASES RCS VOLUME THE DATA ENTRY FOR THAT ACTION MUST BE NEGAT
... YOU MUST ENTER DEC. PT. WITH LEAKAGE VALUES...

DESIRED INTERVAL (1-8 HOURS)

1

ENTER OPERATOR CAUSED CHANGES TO THERC D FROM DS 4 (2301-3D1)

0

ENTER OPERATOR CAUSED CHANGES FROM DS 4 (2301-3D1)

305.

ENTER IDENTIFIED LEAKAGE FROM DS 3 (2301-3D1) (GPM)

0

ENTER PRIMARY TO SECONDARY OTSG TUBE LEAK (GPM)

0

TIME	TCA (F)	TIA (F)	TCB (F)	TIB (F)	TAVE (F)	PRZR LVL (IN)	MUTK LVL (IN)	RODT LVL (INCHES)
11: 5: 6:	557.530	603.535	558.500	605.572	582.383	228.885	71.735	76.769
12: 5: 6:	557.523	606.388	558.219	605.713	582.281	229.816	72.351	77.937

GROSS LEAK RATE (<30 GPM): 4.5188 GPM

TOTAL IDENTIFIED RCS LEAK RATE (<10 GPM): 3.7994 GPM

NET UNIDENTIFIED LEAK RATE (<1 GPM): 0.5194 GPM

OPERATOR:

D. Olson

APPROVED:

A Miller

230 028

STOP

A

rcl

DATE: 3/13/79 REACTOR COOLANT LEAKAGE TEST
TIME: 2: 0: 6 SP 2301-3D1

NOTE: IF OPERATOR ACTION DECREASES RCS VOLUME THE DATA ENTRY FOR THAT ACTION MUST BE NEGATIVE,
...YOU MUST ENTER DEC. PT. WITH LEAKAGE VALUES...

DESIRED INTERVAL (1-8 HOURS)

1

ENTER OPERATOR CAUSED CHANGES TO THERCOT FROM DS 4 (2301-3D1)

0

ENTER OPERATOR CAUSED CHANGES FROM DS 4 (2301-3D1)

0

ENTER IDENTIFIED LEAKAGE FROM DS 3 (2301-3D1) (GPM)

0

ENTER PRIMARY TO SECONDARY OTSG TUBE LEAK (GPM)

0

TIME	TCA (F)	THA (F)	TC3 (F)	TH3 (F)	TAVE (F)	PRZR LVL (IN)	MUTK LVL (IN)	RODT LVL (INCHES)
------	------------	------------	------------	------------	-------------	------------------	------------------	----------------------

2: 0:28:	557.344	606.586	558.000	606.406	582.078	228.023	64.082	75.608
----------	---------	---------	---------	---------	---------	---------	--------	--------

3: 0:28:	557.508	606.766	558.313	606.414	582.242	227.443	60.174	79.629
----------	---------	---------	---------	---------	---------	---------	--------	--------

GROSS LEAK RATE (<30 GPM): 3.6252 GPM

TOTAL IDENTIFIED RCS LEAK RATE (<10 GPM): 3.6407 GPM

NET UNIDENTIFIED LEAK RATE (<1 GPM): -0.0155 GPM

OPERATOR: *Mark Korman*

APPROVED: *XR Hoyt*

230 020

**GENERATION MAINTENANCE SYSTEM
MANUAL PERFORMANCE FORM**

DATE ISSUED _____

SCHED. DATE _____

REFERENCE MANUAL _____

PROCEDURE NO.
2301-3D1

DEPT RESP - _____

TASK NO. - _____

WORK ORDER NO. - _____

ACCOUNT NO. - _____

PART NO QUAN SPEC EQUIPMENT

GC CODE - _____

COMPONENT NO. - _____

COMPONENT DESC - _____

PLANT CONDITION (MODE) SU(2) OP(1) HD(4) CD(5) RF(6) PS(3) LR(1)

FREQUENCY _____ COMPONENT STATUS _____

DEPENDENT TASKS ASSIST DEPT

SPECIFIC DAY _____ INTERFERENCE _____

PRIORITY _____

COMP. LOCATION - BDG _____ LVL _____ GRID _____

SHIFT FOREMAN APPROVAL TO COMMENCE WORK

SIGNATURE DATE RWP NO TAG NO

QC NOTIFIED BEFORE STARTING WORK (IF APPLICABLE ONLY)

SIGNATURE DATE

COMPONENT RETURNED TO SERVICE (SHIFT FOREMAN)

SIGNATURE DATE

TXN. CD.	ACT.	COMPONENT NO.			LOCATION/UNIT	TYPE TASK	TASK IDENTIFICATION	SCHEDULE NUMBER			
		SYS.	COM.	TYPE							
4	0	A	T	M	I	23013D	11	1036002752301-3D1	79	071	M

RESULTS (51)

COMPLETE THIS SECTION (401A)

DATE PERFORMED (39)

7 / 21 / 81
MONTH DAY YEAR

CHECK ONE ONLY

- 1 PERFORMED OK
- 2 EXCEPTIONS
- 3 DEFICIENCIES
- 4 BOTH E S AND D S
- 5 NOT PERFORMED

ACTUAL MANHOURS (45) 10990.15
ACTION TAKEN CODE (52) L L I
REASON NOT PERFORMED (54) L L I

PERFORMED BY EMPLOYEE NUMBER (60)

05488

SIGNATURE - _____

APPROVED BY EMPLOYEE NUMBER (65)

05873

SIGNATURE - _____

WITNESSED BY EMPLOYEE NUMBER (70)

L L L L L I

SIGNATURE - _____

CORRECTIVE MAINTENANCE JOB TICKET NUMBER (75) L L L L L I

403A (1) DUPLICATE AS ABOVE (5-38) 402 (1) DUPLICATE AS ABOVE (5-38)

RESULTS DESCRIPTION

ASSISTING DEPARTMENTS

L0L1L I (39)

CODE (39) L L L L L I

L I (61)

HOURS(44) L L L L L I L L I

404A (1) DUPLICATE AS ABOVE (5-38)

L0L1L I

CODE (50) L L L L L I

L I (61)

HOURS(55) L L L L L I L L I

230 031

efpd
EFPD: 78.531

!rcsl

DATE: 3/12/79
TIME: 1:32:14

REACTOR COOLANT LEAKAGE TEST
SP2301-3D1

NOTE: IF OPERATOR ACTION DECREASES RCS VOLUME THE DATA ENTRY FOR THAT ACTION MUST BE NEGATIVE
...YOU MUST ENTER DEC. PT. WITH LEAKAGE VALUES...

DESIRED INTERVAL (1-8 HOURS)

1
ENTER OPERATOR CAUSED CHANGES TO OTHER CDT FROM DS 4 (2301-3D1)

0
ENTER OPERATOR CAUSED CHANGES FROM DS 4 (2301-3D1)

0
ENTER IDENTIFIED LEAKAGE FROM DS 3 (2301-3D1) (GPM)

0
ENTER PRIMARY TO SECONDARY OTSG TUBE LEAK (GPM)

TIME	THA (F)	THB (F)	TCA (F)	TCH (F)	TAVE (F)	PRZRLVL (IN)	MUTK LVL (IN)	RCDT LVL (INCHES)
1:32:38:	557.055	606.211	557.789	606.063	581.773	228.141	71.812	76.147
2:32:38:	556.594	605.361	557.308	605.781	581.430	227.215	65.520	79.166

GROSS LEAK RATE (<30 GPM): 3.9384 GPM

TOTAL IDENTIFIED RCS LEAK RATE (<10 GPM): 3.6763 GPM

NET UNIDENTIFIED LEAK RATE (<1 GPM): 0.2620 GPM

OPERATOR:

APPROVED:

Raymond J. Gorka
Amella

230 032

rcs1

DATE: 3/10/79
TIME: 3:51:0

REACTOR COOLANT LEAKAGE TEST
SP 2301-301

NOTE: IF OPERATOR ACTION DECREASES RCS VOLUME THE DATA ENTRY FOR THAT ACTION MUST BE ...YOU MUST ENTER DEC. IN. WITH LEAKAGE VALUES...

DESIRED INTERVAL (1-8 HOURS)

1

ENTER OPERATOR CAUSED CHANGES TO THE ROOT FROM DS 4 (2301-301)

0

ENTER OPERATOR CAUSED CHANGES FROM DS 4 (2301-301)

3

ENTER IDENTIFIED LEAKAGE FROM DS 3 (2301-301) (GPM)

0

ENTER PRIMARY TO SECONDARY OTSG TUBE LEAK (GPM)

0

TIME	TCA (F)	THA (F)	TOB (F)	THB (F)	TAVE (F)	PRZR LVL (IN)	MTRK LVL (IN)	ROOT LVL (INCHES)
3:51:23:	557.344	606.555	558.031	608.250	582.030	220.400	81.300	76.500
4:51:23:	557.719	606.700	558.410	608.510	582.352	220.070	74.015	79.261

GROSS LEAK RATE (<30 GPM): 4.0724 GPM

TOTAL IDENTIFIED RCS LEAK RATE (<10 GPM): 3.2074 GPM

NET UNIDENTIFIED LEAK RATE (<1 GPM): 0.8650 GPM

OPERATOR: *[Signature]*

APPROVED: *KR Hoyt*

STOP 0

230 034

rcl

DATE: 3/ 9/73
TIME: 3:20:58

REACTOR COOLANT LEAKAGE TEST
SP 2301-301

NOTE: IF OPERATOR ACTION DECREASES RCS VOLUME THE DATA ENTRY FOR THAT ACTION MUST BE NEGATIVE
...YOU MUST ENTER DEC. PT. WITH LEAKAGE VALUES...

DESIRED INTERVAL (1-8 HOURS)

1

ENTER OPERATOR CAUSED CHANGES TO THE RCS FROM DS 4 (2301-301)

0

ENTER OPERATOR CAUSED CHANGES FROM DS 4 (2301-301)

181.

ENTER IDENTIFIED LEAKAGE FROM DS 3 (2301-301) (GPM)

0

ENTER PRIMARY TO SECONDARY OVER TUBE LEAK (GPM)

0

TIME	TCA (F)	THA (F)	TCD (F)	TIB (F)	TAVE (F)	PRZR LVL (IN)	ACTK LVL (IN)	RCDT LVL (INCHES)
3:23:42	557.344	606.756	559.172	606.531	582.203	228.734	67.793	73.849
4:23:42	557.312	606.7	559.172	77	582.153	228.208	66.153	78.692

GROSS LEAK RATE (<3) GPM):

4.3402 GPM

TOTAL IDENTIFIED RCS LEAK RATE (<10 GPM):

3.4851 GPM

NET UNIDENTIFIED LEAK RATE (<1 GPM):

0.8551 GPM

OPERATOR: *L. W. Smith*

APPROVED: *HA King*

STOP 0

230 036

rcsl

DATE: 3/ 8/79
TIME: 5: 5:5

REP OR COOLANT LEAKAGE TEST
SP 2301-301

NOTE: IF OPERATOR ACTION DECREASES ROD VOLUME THE DATA ENTRY FOR THAT ACTION MUST BE NEGATIVE
...YOU MUST ENTER DEC. PT. WITH LEAKAGE VALUES...

DESTINED INTERVAL (1-8 HOURS)

1 ENTER OPERATOR CAUSED CHANGES TO THE ROOT FROM DS 4 (2301-301)

2 ENTER OPERATOR CAUSED CHANGES FROM DS 4 (2301-301)

228. ENTER IDENTIFIED LEAKAGE FROM DS 3 (2301-301) (300)

0 ENTER PRIMARY TO SECONDARY OTCS TUBE LEAK (300)

TIME	TCA (F)	TVA (F)	TCS (F)	TDS (F)	TA/2 (F)	PRZR LVL (F)	NUTR LVL (F)	ROBT LVL (F)
3: 6:10:	557.523	606.338	553.273	607.088	582.003	227.212	73.400	
4: 6:10:	557.300	606.330	553.303	606.074	582.001	227.014	73.500	78.700

GROSS LEAK RATE (<30 GPM): 3.5783 GPM

TOTAL IDENTIFIED ROD LEAK RATE (<10 GPM): 3.1087 GPM

NET UNIDENTIFIED LEAK RATE (<1 GPM): 0.4679 GPM

REPORTOR: Dennis Olson

APPROVER: A Miller

230 038

DATA SHEET 4

RCS LEAK RATE

OPERATOR CAUSED CHANGES TO RCS INVENTORY

1. Identify operation that caused change: Increase MUT level

2. Time Operation Started: 0400

Time Operation Completed: 0405

3. Calculations:

4. Total change to RCS inventory: 228 gal.

NOTE 1: If change is to RCDD enter in section 7 of Data Sheet 1 Line 25 or Data Sheet 2 Line 25.

NOTE 2: If change is to any other part of a system, enter in section 5 of Data Sheet 1 Line 20 or Data Sheet 2 Line 33.

NOTE 3: SIGNS: Removals from the system have a negative (-) sign. Additions to the system have a positive (+) sign.

PERFORMED BY D. Olson

DATE 3-8-79

APPROVED BY A. Miller

DATE 3-8-79

rcl

DATE: 3/ 6/73
TIME: 3:21:24

REACTOR COOLANT LEAKAGE TEST
SP 2301-301

NOTE: IF OPERATOR ACTION DECREASES RCS VOLUME THE DATA ENTRY FOR THAT ACTION MUST BE RELATIVE
...YOU MUST ENTER DEC. PT. WITH LEAKAGE VALUE...

DESIGNED INTERVAL (1-8 HOURS)

1 ENTER OPERATOR CAUSED CHANGES TO THE ROOT FROM DO 4 (2301-301)

0 ENTER OPERATOR CAUSED CHANGES FROM DO 4 (2301-301)

100 ENTER IDENTIFIED LEAKAGE FROM DO 3 (2301-301) (GR)

0 ENTER PRIMARY TO SECONDARY OTSG TUBE LEAK (GR)

TIME	TCA (F)	THA (F)	TCS (F)	THB (F)	TAVE (F)	PRZR LVL (IN)	NOTE LVL (IN)	RODT LVL (INCHES)
3:21:47	557.565	606.625	558.130	606.638	582.105	225.744	79.22	76.255
4:21:47	557.706	606.630	557.835	606.100	581.852	225.021	77.007	76.435

GROSS LEAK RATE (<33 GR): 3.487 GR

TOTAL IDENTIFIED RCS LEAK RATE (<10 GR): 2.7130 GR

NET UNIDENTIFIED LEAK RATE (<1 GR): 0.774 GR

OPERATOR: *[Signature]*

APPROVED: *[Signature]*

POOR ORIGINAL

230 041

STOP 0

rcsl

DATE: 5/ 5/73 REACTOR COOLANT LEAKAGE TEST
TIME: 3:13:20 SP 2301-301

NOTE: IF OPERATOR ACTION DECREASES RCS VOLUME THE DATA ENTRY FOR THAT ACTION MUST BE NEGATIVE
...YOU MUST ENTER DEC. PT. WITH LEAKAGE VALUES...

DESIRED INTERVAL (1-8 HOURS)

1 ENTER OPERATOR CAUSED CHANGES TO THE ROOT FROM DS 4 (2301-301)

0 ENTER OPERATOR CAUSED CHANGES FROM DS 4 (2301-301)

128. ENTER IDENTIFIED LEAKAGE FROM DS 3 (2301-301) (GPM)

0 ENTER PRIMARY TO SECONDARY OTSG TUBE LEAK (SP1)

TIME	TCA (F)	THA (F)	TCD (F)	THD (F)	TAVE (F)	PRIM LVL (IN)	MUTK LVL (IN)	ROOT LVL (INCHES)
3:20: 0:	556.922	606.133	557.594	607.111	581.835	226.025	68.107	76.271
4:20: 0:	557.031	606.297	557.915	607.111	581.835	224.733	67.141	78.521

GROSS LEAK RATE (<30 GPM): 3.6104 GPM

TOTAL IDENTIFIED RCS LEAK RATE (<10 GPM): 2.7680 GPM

NET UNIDENTIFIED LEAK RATE (<1 GPM): 0.8635 GPM

OPERATOR: *D Olson*

APPROVAL: *A Miller*

POOR ORIGINAL

STOP 0

230 043

rcl

DATE: 3/ 4/79 REACTOR COOLANT LEAKAGE TEST
TIME: 1:42: 7 SP 2301-301

NOTE: IF OPERATOR ACTION DECREASES RCS VOLUME THE DATA ENTRY FOR THAT ACTION MUST BE RE-
...YOU MUST ENTER DEG. PT. WITH LEAKAGE ANALYSIS...

DESIRED INTERVAL (1-6 HOURS)

1

ENTER OPERATOR CAUSED CHANGES TO THE RCS FROM DS 4 (2301-301)

3

ENTER OPERATOR CAUSED CHANGES FROM DS 4 (2301-301)

238.

ENTER IDENTIFIED LEAKAGE FROM DS 3 (2301-301) (LRI)

3

ENTER PRIMARY TO SECONDARY OTSG TUBE LEAK (LRI)

3

TIME	TCA (F)	TFA (F)	TCS (F)	TIS (F)	TA/E (F)	PRR LVL (IN)	MTRK LVL (IN)	RCS LVL (INCHES)
2:30:	557.315	606.338	517.314	606.403	502.900	224.564	84.433	76.805
2:42:30:	556.760	605.797	557.523	605.314	501.472	224.162	84.443	73.177

GROSS LEAK RATE (<10 GPM): 2.0300 GPM

TOTAL IDENTIFIED RCS LEAK RATE (<10 GPM): 2.0370 GPM

NET UNIDENTIFIED LEAK RATE (<1 GPM): -0.0070 GPM

OPERATOR: *Coleman*

APPROVED: *A Miller*

POOR ORIGINAL

STOP 0

230 045

res1

DATE: 5/ 3/73 REACTOR COOLANT LEAKAGE TEST
TIME: 2:58:15 SP 2301-301

NOTE: IF OPERATOR ACTION DECREASES RCS VOLUME THE DATA ENTRY FOR THAT ACTION MUST BE NEGATIVE,
...YOU MUST ENTER DEC. PT. WITH LEAKAGE VALUES...

DESIRED INTERVAL (1-8 HOURS)

- 1 ENTER OPERATOR CAUSED CHARGES TO THE RODS FROM DS 4 (2301-301)
- 0
- 0 ENTER OPERATOR CAUSED CHARGES FROM DS 4 (2301-301)
- 152.
- 0 ENTER IDENTIFIED LEAKAGE FROM DS 5 (2301-301) (LRA)
- 0
- 0 ENTER PRIMARY TO SECONDARY DIPS TUBE LEAK (LRA)
- 0

TIME	TCA (F)	TDA (F)	TCS (F)	TDS (F)	TAVE (F)	PRIM LVL (IN)	SEC LVL (IN)	ROD LVL (INCHES)
2:30:36:	557.070	600.164	557.701	605.304	581.750	227.029	75	70.257
3:58:56:	558.904	600.211	557.828	605.300	581.750	228.304	7	250

GROSS LEAK RATE (<30 GPM): 2.7738 GPM

TOTAL IDENTIFIED RCS LEAK RATE (<10 GPM): 2.4577 GPM

NET UNIDENTIFIED LEAK RATE (<1 GPM): 0.3162 GPM

OPERATOR:

D. Olson
H.R. Hitz

APPROVED:

POOR ORIGINAL

230 047

STOP

0

rcsl

DATE: 3/ 2/79
TIME: 1:37: 2

REACTOR COOLANT LEAKAGE TEST
SP 2301-501

NOTE: IF OPERATOR ACTION DECREASES RCS VOLUME THE DATA ENTRY FOR THAT ACTION MUST BE NEGATIVE... YOU MUST ENTER DEC. PT. WITH LEAKAGE VALUES...

DESIRED INTERVAL (1-8 HOURS)

- 1 ENTER OPERATOR CAUSED CHANGES TO THE ROOT FROM DS 4 (2301-501)
- 0 ENTER OPERATOR CAUSED CHANGES FROM DS 4 (2301-501)
- 0 ENTER IDENTIFIED LEAKAGE FROM DS 3 (2301-501) (GR1)
- 0 ENTER PRIMARY TO SECONDARY OTSG TUBE LEAK (GR1)

TIME	TCA (F)	TIA (F)	TCB (F)	TIB (F)	TAVE (F)	PRZR LVL (IN)	WUTK LVL (IN)	ROOT LVL (INCHES)
1:46:41:	556.391	605.547	557.030	605.858	581.158	227.834	68.237	76.574
1:47:00:	556.404	605.570	557.140	605.880	581.211	227.127	63.537	78.827

GROSS LEAK RATE (<30 GRM):

3.6386 GRM

TOTAL IDENTIFIED RCS LEAK RATE (<10 GRM):

2.7476 GRM

NET UNIDENTIFIED LEAK RATE (<1 GRM):

0.9400 GRM

OPERATOR:

M. Coq

APPROVED:

Cada

POOR ORIGINAL 2301-501

STOP

0

DATE: 3/ 2/73
TIME: 19:34:37

REACTOR COOLANT LEAKAGE TEST
SP 2301-301

NOTE: IF OPERATOR ACTION DECREASES RCS VOLUME THE DATA ENTRY FOR THAT ACTION MUST BE WITHIN
...YOU MUST ENTER DEC. PT. WITH LEAKAGE VALUES...

DESIRED INTERVAL (1-8 HOURS)

1 ENTER OPERATOR CAUSED CHANGES TO THE RCOT FROM DS 4 (2301-301)

0 ENTER OPERATOR CAUSED CHANGES FROM DS 4 (2301-301)

3 ENTER IDENTIFIED LEAKAGE FROM DS 3 (2301-301) (GRM)

0 ENTER PRIMARY TO SECONDARY OTSG TUBE LEAK (GRM)

TIME	TCA (F)	TIA (F)	TCB (F)	THB (F)	TAVE (F)	PRZR LVL (IN)	MUTR LVL (IN)	RCOT LVL (INCHES)
19:35:31:	556.352	605.201	557.008	605.375	561.016	226.727	66.041	78.457
20:35:31:	556.091	605.767	557.570	605.807	561.523	226.750	62.055	78.627

GROSS LEAK RATE (<3) GRM: 3.2663 GRM

TOTAL IDENTIFIED RCS LEAK RATE (<10 GRM): 2.6311 GRM

NET UNIDENTIFIED LEAK RATE (<1 GRM): 0.6055 GRM

OPERATOR: *J. Blessing*

APPROVED: *K.R. Hoyt*

STOP

POOR ORIGINAL

230 051

resl

DATE: 3/ 1/79
TIME: 0:40:32

REACTOR COOLANT LEAKAGE TEST
SP 2301-3D1

NOTE: IF OPERATOR ACTION DECREASES RCS VOLUME THE DATA ENTRY FOR THAT ACTION MUST BE NEGATIVE... YOU MUST ENTER DEC. PT. WITH LEAKAGE VALUES...

DESIRED INTERVAL (1-8 HOURS)

- 1 ENTER OPERATOR CAUSED CHANGES TO THE ROOT FROM DS 4 (2301-3D1)
- 0 ENTER OPERATOR CAUSED CHANGES FROM DS 4 (2301-3D1)
- 0 ENTER IDENTIFIED LEAKAGE FROM DS 3 (2301-3D1) (GPM)
- 0 ENTER PRIMARY TO SECONDARY OTSG TUBE LEAK (GPM)

TIME	TC1 (F)	T1A (F)	TC3 (F)	T1B (F)	TAVE (F)	PRZR LVL (IN)	MUTK LVL (IN)	RCDT LVL (INCHES)
0:41: 5:	556.617	605.953	557.331	606.117	581.516	227.549	68.243	77.042
1:41: 5:	556.710	605.891	557.359	606.003	581.492	228.770	63.404	79.104

AK RATE (<30 GPM): 2.9831 GPM

TOTAL IDENTIFIED RCS LEAK RATE (<10 GPM): 2.5787 GPM

NET UNIDENTIFIED LEAK RATE (<1 GPM): 0.4044 GPM

OPERATOR:

Joseph R. Caydon

APPROVED:

CBds

POOR ORIGINAL

STOP

230 053