

TMI DOCUMENTS

DOCUMENT NO: TM-0642

COPY MADE ON 6/5/79 OF DOCUMENT PROVIDED BY  
METROPOLITAN EDISON COMPANY.

DLH  
Supervisor, Document Control, NRC

7906180715

230 054

AIR SAMPLE TO  
CHECK ANALYZER

ANALYSIS RESULTS

TE: 3 / 31 / 79  
VOLUME % HYDROGEN= 0.0  
VOLUME % OXYGEN= 20.5  
VOLUME % NITROGEN= 79.5

Gas Partitioner  
to check  
analyzer

chart units  
H<sub>2</sub> - 0  
O<sub>2</sub> - 16  
N<sub>2</sub> - 46 1/2

3/31/79  
0600 HRS

A

ANALYSIS RESULTS

ST 2 RX BLDG  
TE: 3 / 31 / 79  
VOLUME % HYDROGEN= 1.7  
VOLUME % OXYGEN= 15.7  
VOLUME % NITROGEN= 82.6

chart units

H<sub>2</sub> - 14.5  
O<sub>2</sub> - 12  
N<sub>2</sub> - 47 1/2



1<sup>ST</sup>  
SAMPLE of  
RX BLDG  
AIR

ANALYSIS RESULTS

ST 2 RX BLDG  
TE: 3 / 31 / 78  
VOLUME % HYDROGEN= 1.7  
VOLUME % OXYGEN= 16.5  
VOLUME % NITROGEN= 81.8

chart units

H<sub>2</sub> - 16  
O<sub>2</sub> - 14  
N<sub>2</sub> - 52



J. DeMen  
230 055