



UNITED STATES
NUCLEAR REGULATORY COMMISSION
REGION V
1990 N. CALIFORNIA BOULEVARD
SUITE 202, WALNUT CREEK PLAZA
WALNUT CREEK, CALIFORNIA 94596

TIC

June 11, 1979

Docket No. 50-344

Portland General Electric Company
121 S. W. Salmon Street
Portland, Oregon 97204

Attention: Mr. Charles Goodwin
Assistant Vice President

Gentlemen:

In accordance with our letter dated April 1, 1979 transmitting Bulletin 79-05, we are enclosing Preliminary Notification 79-67AS.

Sincerely,


R. H. Engelken
Director

Enclosure:
PNO-79-67AS

cc w/enclosure:
B. Withers, PGE
F. Gaidos, PGE

273 246

7907 030193

DB

IMMEDIATE
PRELIMINARY NOTIFICATION

June 11, 1979

PRELIMINARY NOTIFICATION OF AN EVENT OR UNUSUAL OCCURRENCE -- PNO-79-67AS

This preliminary notification provides updated information of safety or public interest significance.

Facility: Three Mile Island Unit 2
Middletown, Pennsylvania (DN-50-320)

Subject: NUCLEAR INCIDENT AT THREE MILE ISLAND

Operational:

1. The average coolant temperature is 157 degrees F. The highest incore thermocouple temperature reading is 280 degrees F. Core cooling is being maintained by natural circulation. Pressure is about 340 psi with the pressurizer in solid operation. Steam is being admitted to the main condenser through the turbine bypass valve from the A Steam Generator.
2. Water level in the reactor building is being measured daily, and is 7.3 feet above floor level this morning.
3. Preoperational testing for the Spent Fuel Pool Tank Farm, Once-Through Steam Generator "B" Long-Term Cooling System, the modified rad waste treatment system (EPICOR), and the pressure/volume control system should be completed by June 15.

Environmental Status:

Environmental radiation levels remain consistent with natural background levels. Airborne releases have been below Technical Specification limits. From June 5 - June 10, about 37 air samples were collected by the NRC. All were less than MDA. Vegetation, soil and milk samples collected last week also showed no activity above MDA. EPA air, water and milk samples collected during the week (up to June 8) showed no detectable activity from TMI.

CONTINUED

DUPLICATE DOCUMENT

273 247

Entire document previously entered into system under:

ANO 7906270031

No. of pages: 2