## DCPA FACSIMILE TRANSMITTAL

TO	FROM	PR SOENCE	AOUTI.
Hal Collins  SYMBOL: HONE EXT: 492-7285	NAME: MICHEL PAWLOWSKI OFFICE SYMBOL: HEALTH PHYSICIST TELEPHONE EXT: 926-5544	2915 JZMAR  NUMBER OF PAGES: 2	
(S: (Special Instructions, Fax Identification, Suspense, etc.)		Joseph F. Mealy RELEASER'S) INITIALS::	

PENN 086 REGB

213 03/29/9 14462

29 MAR '79 14:54 Z

DE PENN 001 0881430
R 291420Z MAR 79
M PEMA PENN
TO DCPA RGN 2
RT
UNCLAS

7907100170

THREE MILE ISLAND NUCLEAR FIXED FACILITY

SITUATION REPORT NO. 1

\*ERIOD COVERED 1900 - MARCH 28 TO 0700 - MARCH 29, 1979

ENERAL SITUATION

POUR ORIGINA

AS OF 1900, THE NUCLEAR FACILITY AT THREE MILE ISLAND IS CONDUCTING COOLING ACTIVITIES THROUGH A VENTILATION PROCESS IN ROER TO STABILIZE CONDITIONS AT THE PLANT. DER AND NRC INVOLVED ITH GATHERING AIRBORNE READINGS OF RADIATION LEVELS IN NEAR ROXIMITY OF FACILITY. LEVELS HAVE BEEN REPORTED AS VERY LOW AT HIS TIME. HIGHER RADIATION READINGS DETECTED WITHIN THE CONFINES F THE FACILITY.

THE STATE EMERGENCY OPERATIONS CENTER WAS PLACED ON A LIMITED

558284

CORDINATORS OF CUMBERLAND, DAUPHIN, LANCASTER AND YORK COUNTIES ARE SEING KEPT INFORMED OF CURRENT SITUATION AND ADVISED THAT ALTHOUGH ONDITIONS ARE NOT OF AN EMERGENCY NATURE AT THIS TIME, IT REMAINED OTENTIALLY SERIOUS. THEY WERE FURTHER ADVISED TO REMAIN IN A STATE OF READINESS.

The control of the section of the se

THIS REPORT ALSO FURNISHED TO THE DCPA REGION II DUTY OFFICER. FEATHER DATA CONCERNING WIND DIRECTION AND VELOCITY CONTINUE TO RESATHERED.

NUMEROUS INQUIRIES FROM MEDIA AND CONCERNED CITIZENS CONTINUED BE RECEIVED. OF PARTICULAR NOTE WAS THE IMPACT THAT RADIATION WOULD AVE ON PREGNANCIES. OR. WASHINGTON, DEPUTY SECRETARY OF HEALTH, NO MR. GERUSKY, DER, PROVIDED INFORMATION FOR POSSIBLE RELEASE THAT, NOER PRESENT LEVELS, NO ONE OUTSIDE OF THE PLANT WAS EXPOSED TO MORE HAN 100MR'S DURING THE INCIDENT PERIOD, WHICH IS THE APPROXIMATE MOUNT THE HUMAN BODY NORMALLY ABSORBS IN A YEAR. THEREFORE, EXPOSURE OULD BE OF NEGLIGIBLE IMPACT.

INFORMATION RECEIVED AT 2230 INDICATED THAT PLANT CONDITIONS ERE IMPROVING IN THAT PUMPS WERE WORKING AND THIS FACTOR, COUPLED ITH THE CONTINUED VENTILATION PROCESS, INDICATED A POSSIBILITY OF ITABILIZATION OF THE REACTOR IN APPROXIMATELY 24 HOURS.

DER AND NRC AGENCIES CONTINUE TO SAMPLE AIR, WHICH WAS REPORTED OF CONTAIN MINIMUM LEVELS OF RADIATION. THIS ITUATION REPORT WAS URNISHED TO THE IDENTICAL OFFICIALS NOTED IN PREVIOUS 1900 HOURS INTRY. THESE OFFICIALS WERE ALSO INFORMED THAT ALTHOUGH THE SITUATION IPPEARED SECURE, CONTINUED READINESS WOULD BE REQUIRED UNTIL FURTHER OTICE.

INFORMATION AT 0115 HOURS FROM DER THAT THE REACTOR EXPECTED TO BE WITHIN DESIRED HEAT AND PRESSURE RANGE WITHIN A HALF HOUR.

DER, AT 0240 HOURS, INDICATED THAT PROGRESSION OF THE COOLING ROCESS TO THE DESIRED TEMPERATURE AND PRESSURE HAD FALTERED. IF TO IMPROVEMENT, THEY WILL REVERT TO VENTILATION ONCE MORE.

HENDERSON/DIRECTOR DLH 3T