



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20586

TMZ-2 SITE

4/10/79
6:30 PM

PLEASE TELECOPY ATTACHED TWO
DOCUMENTS (10 PAGES) TO MR. JOSE CALVO
TMI
AT NRC/NRRL SUPPORT GROUP IN BETHESDA, MD.

NEEDED PROMPTLY.

THANKS.

J.R. BEARD
TMI-2 TECH REVIEW GROUP
TRAILER #27.

P.S.

RETURN ORIGINAL FAXED TO TRAILER #27.

7907120643

556244

POOR ORIGINAL

(1)

P

J.W. Beale
3/10/79

Letter from E. F. Dowling to E. A. Womack dated April 1, 1979
Subject Instrumentation Status

General observation of instrument status

1. Flow, level and pressure transmitters are expected to fail at some point due to two mechanisms.
 - (a) high radiation or
 - (b) submersion in water
2. Radiation levels (estimated at 10^3 rad/hr) should start to effect BY transmitters some time after 1200 hours on 4/1/79 (integrated dose 10^5 rad.)

Degradation should be gradual with time, until the integrated dose reaches 10^6 to 10^7 rads (10^6 is to + 41.7 days; 10^7 equal to + 417 days) at which time the transmitter will cease to function.
3. Calculation of water level in the Reactor Building indicates that a large number of transmitters are submerged and have been for a number of days. Few failures have been reported. The transmitters are sealed and have been qualified by tests to high temperature, pressure and steam conditions (286°F , 60 psig), but have not been tested for submersion in water. There is no way to predict how long the submerged transmitters will continue to function.
4. Transmitter failure is expected to be by increase in noise level, gross deviation from redundant indications and finally loss of signal.

Attachment 1 shows which transmitters are vulnerable due to location above building floor and by virtue of radiation resistance. Attachment 2 defines alternative ways to obtain parameter measurements. This attachment will be updated when additional information is available.

Attachment 1

Attachment 2

556245

<u>Level (Water Volume)</u>	<u>(Bldg Elevation)</u>	<u>BY</u>	<u>Transmitter</u>	<u>String No., Parameter</u>	<u>10⁵ Rads</u>	<u>10⁷ Rads</u>
<u>282' 6"</u>						<u>Foxboro</u>
2'-5"	179,630 gal.					✓ SP6B-PT1 SGB Pressure
3'-0"	222,990			RC14A-DPT-3 & 4, Loop A RC Flow		
3'-6"	260,155			RC1-LT 1,2 & 3, Press. Level		✓ SP6B-PT 2 SGB Pressure
				RC14A-DPT 1 & 2, Loop A RC Flow		RC 22 - PT 1 thru 8 Reactor Coolant Pump Seal Cavity Pressure
				RC14B-DPT 3 & 4, Loop B RC Flow		
				SPIA-LT 2 & 3, SG A Operate Level		Note: This group may be located at this level or the next level higher
				SPIA-LT 4 & 5, SGA Start up Level		
				SPIB-LT 1, SGB Full Range Level		
				SPIB-LT 2 & 3, SCB Operate Level		
				SPIB-LT 4 & 5, SGB Startup Level		
5'-2"	384,038			SPIA-LT1, SGA Full Range Level	SP6A-PT 1 & 2 SG-A Pressure	
						✓ RC3A-PT 3 & RC Pressure Wide Range
						RC3A-PT 5 RC Pressure Low Range
						✓ RC3B-PT 3 RC Pressure Wide Range

POOR ORIGINAL

Assumption:

- 1) BY transmitter will begin to fail about 10⁵ Rad.
- 2) Foxboro transmitter will begin to fail above 10⁷ Rad.
- 3) Transmitters have been receiving 1000 R/hr.
- 4) Both BY and Foxboro transmitters may fail if submerged in water.
- 5) Water height is related to volume by 1 ft. per 74,330 gallons.

556346

<u>Measurement Alternative</u>		
<u>Parameter</u>	<u>Primary Source of Measurement</u>	<u>Alternate Source of Measurement</u>
RC Pressure	RC3A-PT 3&4 (Wide) ESFAS	RC22-PT 1 thru 8
	RC3B-PT 4 (wide) ESFAS	RCP Seal Cavity Pressure
		RC2-TA 1&2 Pressurizer Temp.
		CA-PI
		RC Pump Vibration
		RC3A-PT 5 (low)
RC Temperature	Inco/le T/Cs	RC4A-TE 2&3, T_{Hot}
		RC4B-TE 2&3, T_{Hot}
		RC5A-TE 2&4, T_{Cold}
		RC5B-TE 2&4, T_{Cold}
		RC-TE9
		RC4A-TE 1&4, T_H
		RC4B-TE 1&4, T_H
		RC5A-TE 1&3, T_C
		RC5B-TE 1&3, T_C
		RC15A-TE1, T_H
		RC15B-TE1, T_H
		RC15A-TE2, T_C
		RC15B+TE2, T_C
		RC15A-TE3, T_C
		RC15B-TE3, T_C
		RC-TE11
MU-TES		Accounting for Coolin

556247

<u>Parameter</u>	<u>Primary Source of Measurement</u>	<u>Alternate Source of Measurement</u>	<u>Reference Backup Sheet</u>
		DH6-TE 1&2	
		SP3A-TE 1&2	Steam Gen. Saturat ⁿ Temperature
		AP3B-TE 1&2	Steam Gen. Saturat ⁿ Temperature
RC Flow Loop A	RC14A DPT 1,2,3 & 4	RC Pump Motor Current	
RC Flow Loop B	RC14B DPT 1,2,3 & 4	RC Pump Motor Current	
SG Operating Level	SP1A-LT 2&3 SG-A SP1B-LT 2&3 SG-B	SP1A-LT 1 SG-A SP1B-LT 1 SG-B RC Temperature SP1A-LT 4&5 SG-A SP1B-LT 4&5 SG-B Feed Water Status Sample Lines as Level Indicators Press. Transmitter Across Feed Water Line and Main Steam Line	See RC Temp. Sheet
	SP3A-TE 1&2 SG-A	Use one element as heating element by applying low voltage. Other element will read different if element is covered uncovered.	
	SP3B-TE 1&2 SG-B	" " "	" " "

556348

<u>Parameter</u>	<u>Primary Source of Measurement</u>	<u>Alternate Source of Measurement</u>	<u>Reference Backup Sheet</u>
SG Wide Range Level	SP1B-LT1 SG-B SP1A-LT1 SG-A	Sample line as level indication	
Pressurizer Level	RC1-LT1, 2&3	MU14-LT 1&2 (MU Tank Level)	
		MU7-DPT 1,2,3,4 (Seal injection flow)	
		MU4-DPT (Let-down flow)	
Pressurizer Level Alter- nate Calcula- tion Procedure			

Procedure:

Step 1 - Record let-down flow at _____ increments using MU4-DPT

Step 2 - Record RC pump seal injection flow at _____ increments using
MU7-DPT 1,2,3 & 4

Step 3 - Record MU tank level at _____ increment using MU14-LT 1&2

Step 4 - MU tank volume is 4388 gallons. MU tank galls per inch - 31.
Pressurizer volume 11,230 gallons.
Pressurizer gallons per inch - 24.

Step 5 - Determine volume of let-down.
Item 1 x time increment = volume in gallons.

Step 6 - Determines volume of RC pump injection.
Item 2 x time increment

Step 7 - Subtract result of Step 6 from result of Step 5.

Step 8 - Subtract previous MU tank level from level determined at Step 3.

556349

TO: SIG DISTRIBUTION

B&W - Trailer #26

April 10, 1979

Bob Long - Trailer #26

Ivan Porter - Met-Ed Op.

Vic Stello - (NRC)
(Trailer #7)

J.T. BOARD
4/10/79 5:00 PM

Milt Levenson - Bldg. #26

Cable Spreading Room

Bert
~~425~~ Ackermann - Bldg. #26

Attached is a status report by the Special Instrument Group on diagnostic instrumentation.

Report will be updated daily.

R. BALL

R.B:dr

556350

SPECIAL INSTRUMENT GROUP - STATUS REPORT

Date 8/27/91
Time 2555

Instrument Type Or Class	Primary Function In Recovery	Who Is Using	Location & Type of Indication	Vital Signs or Health	Prior Action Results	New Action	Next Step
RTD	Loop temperatures	Control Room	Computer printout	Y hot is coming out on log. RTD's below flow nozzle	Determine RTD bridge avail- ability		
Vent Header	Pressurized to clean up				Can we find leak?		
TC on Pressurizer Relief Valve					Is being read on computer?		
Seal Temperature					What can trip primary pump and what has been disabled?		

550251

SPECIAL INSTRUMENT GROUP - STATUS REPORT

Date 9 April
Time 2030

Instrument Type or Class	Primary Function in Recovery	Who is Using	Location & Type of Indication	Vital Signs of Health	Prior Action Results	New Action	To Refill Per
Pressure and level	Indicate water location for cooling	Control Room	Control Room	On-scale reading fluctuations	<ul style="list-style-type: none"> 1) Lost B OTSG wide range level 2) Procedure written by utility to put in dP between FW flow and steam pressure 3) Have dP cell from Lynchburg 4) Tap is outside 5) Will do on both OTSG's 		
Pressurizer level					<p>Level indicator #2 indicated high noise, then OK</p> <p>Bailey says de-powered last longer</p>	<p>Check all 3 to computer</p> <p>Is one not powered?</p>	<p>Act w/ Sct</p>
Pressure				<p>Have been heavily irradiated Foxboro (not guaranteed for high radiation)</p>	No fluctuation when pump is off-boiling not pressure source	<p>Still monitoring of PSD's</p>	Sct

POOR ORIGINAL

67
2000352

Page 2
RFB

SPECIAL INSTRUMENT GROUP - STATUS REPORT

Date 5 AprilTime 2030

Instrument type or Class	Primary Function in Recovery	Who is Using	Location & Type of Indication	Vital Signs of Health	Prior Action Results	New Action	Responsible Person
SPND (Self-powered neutron detectors)	Indicate lower part of core is whole	Core evaluation	Computer printout	Resistance greater than 10 ⁹ ohms on good ones	Arkansas P&L (Jim Poale) is bringing in TDR	Review by HDW of TDR Will do TC's then SPND's	Ackmar
TC's (Thermocouples)	Core top temperature redistribution	Core Eval. Operators	Two on strip charts in S.R. Control Room computer printout	Resistance continuity and reasonable value	1) Duke is taking some TC resistance 2) Have resistors from computer terminals and to ground 3) 7F & 8F both noisy	1) Compare Duke & TMI for low resistance 2) Ackermann will show Milt 3) What did TC's do as a function of pressure	1) Compare Duke & TMI for low resistance 2) Ackermann will show Milt 3) What did TC's do as a function of pressure
Movable incore	Core integrity	Core Eval.	Spreading Room (S.R.)	Motion	Went 3½ ft. into core in location N-8 (3 ft. into fuel) Solid stop Practically no change in current-detector appears wet and dead		

67
68
69
70
71

JAN 2
2033

SPECIAL INSTRUM GROUP - STATUS REPORT

Date 2/11/70

Time 2030

Instrument Type or Class	Primary Function in Recovery	Who is Using	Location & Type of Indication	Vital Signs of Health	Prior Action Results	New Action	Responsible Person
Computer Backup	TC readings	Control Room	--	Continued operation		1) Cable Available 2) Hookup Put on 2 multi-point	Lionel Banda
Ex Core Detectors	Determine core relocation	Core evaluation	Safety cabinets	D.C. current Resistance (greater than 20 meg)	1) Techs can now do 2) A test procedure was written (Z98A) ~ 3% down	1) How often does Tech group want? Ask Milt	R. M. Ball
BF ₃ counters	Neutron indicator Sub-criticality	Control Room	Recorder on one at a time	Value and fluctuations	Discriminator & gain checked (plateau) 40 c/s = 1 nV _{Tn}	Ask shift to record both BF ₃ 's	Ackermann

556254

Serkowicz
~~SECRET~~ COPY

Letter from E. F. Dowling to E. A. Womack dated April 1, 1979
Subject Instrumentation Status

General observation of instrument status

1. Flow, level and pressure transmitters are expected to fail at some point due to two mechanisms.
 - (a) high radiation or
 - (b) submersion in water
2. Radiation levels (estimated at 10^3 rad/hr) should start to effect BY transmitters some time after 1200 hours on 4/1/79 (integrated dose 10^5 rad.)
Degradation should be gradual with time, until the integrated dose reaches 10^6 to 10^7 rads (10^6 is to + 41.7 days; 10^7 equal to + 417 days) at which time the transmitter will cease to function.
3. Calculation of water level in the Reactor Building indicates that a large number of transmitters are submerged and have been for a number of days. Few failures have been reported. The transmitters are sealed and have been qualified by tests to high temperature, pressure and steam conditions (286°F , 60 psig), but have not been tested for submersion in water. There is no way to predict how long the submerged transmitters will continue to function.
4. Transmitter failure is expected to be by increase in noise level, gross deviation from redundant indications and finally loss of signal.

Attachment 1 shows which transmitters are vulnerable due to location above building floor and by virtue of radiation resistance. Attachment 2 defines alternative ways to obtain parameter measurements. This attachment will be updated when additional information is available.

Attachment 1
Attachment 2

*Bombay Joe 201-345-9512
9513*

556355

POOR ORIGINAL

<u>Parameter</u>	<u>Primary Source of Measurement</u>	<u>Alternate Source of Measurement</u>	<u>Reference Backup Sheet</u>
		DH6-TE 1&2	
		SP3A-TE 1&2	Steam Gen. Saturation Temperature
		AP3B-TE 1&2	Steam Gen. Saturation Temperature
RC Flow Loop A	RC14A DPT 1,2,3 & 4	RC Pump Motor Current	
RC Flow Loop B	RC14B DPT 1,2,3 & 4	RC Pump Motor Current	
SG Operating Level	SP1A-LT 2&3 SG-A SP1B-LT 2&3 SG-B	SP1A-LT 1 SG-A SP1B-LT 1 SG-B	
		RC Temperature	See RC Temp. Sheet
		SP1A-LT 4&5 SG-A	
		SP1B-LT 4&5 SG-B	
		Feed Water Status	
		Sample Lines as Level Indicators	
		Press. Transmitter Across Feed Water Line and Main Steam Line	
		SP3A-TE 1&2 SG-A	Use one element as heating element by applying low voltage. Other element will read different if element is covered or uncovered.
		SP3B-TE 1&2 SG-B	" " "

<u>Parameter</u>	<u>Primary Source of Measurement</u>	<u>Alternate Source of Measurement</u>	<u>Reference Backup Sheet</u>
SG Wide Range Level	SPIB-LT1 SG-B	Sample line as level indication	
	SPIA-LT1 SG-A		
Pressurizer Level	RCL-LT1, 2&3	MU14-LT 1&2 (MU Tank Level)	
		MU7-DPT 1,2,3,4 (Seal injection flow)	
		MU4-DPT (Let-down flow)	
Pressurizer Level Alternate Calculation Procedure			

Procedure:

Step 1 - Record let-down flow at _____ increments using MU4-DPT

Step 2 - Record RC pump seal injection flow at _____ increments using MU7-DPT 1,2,3 & 4

Step 3 - Record MU tank level at _____ increment using MU14-LT 1&2

Step 4 - MU tank volume is 4388 gallons. MU tank galls per inch - 31.
Pressurizer volume 11,230 gallons.
Pressurizer gallons per inch - 24.

Step 5 - Determine volume of let-down.
Item 1 x time increment = volume in gallons.

Step 6 - Determines volume of RC pump injection.
Item 2 x time increment

Step 7 - Subtract result of Step 6 from result of Step 5.

Step 8 - Subtract previous MU tank level from level determined at Step 3.

556257

Step 9 - Multiply result of Step 8 by MU tank volume per inch given in Step 4.

Step 10 - Add or subtract the results of Step 9 to the results of Step 7.

Step 11 - Divide the result of Step 10 by pressurizer gallons/inch to obtain the change in pressurizer level.

Assumptions:

1. Only source of make up is to RC pump seal.
2. No RC leakage other than let down.
3. Constant RC pressure (Procedure can be modified to accommodate varying RC pressure)

556258

<u>10⁵</u> 10 ⁷ 10 ⁷	<u>Rads</u> <u>BY</u> <u>Foxboro</u>
<u>10⁵</u> (Water Volume) Bldg Elevation 282' 6"	Transmitter String No., Parameter
2' 123,722 2'-5" 179,630 gal.	
3'-0" 222,990 284' 6"	✓ RC14A-DPT-3 & 4, Loop A RC Flow
3'-6" 260,155	✓ RC1-LT 1,2 & 3, Press. 424, 425 Level
	RC14A-DPT 1 & 2, Loop A RC Flow
	RC14B-DPT 3 & 4, Loop B RC Flow
	✓ SPLA-LT 2 & 3, SG A Operate Level
	✓ SPLA-LT 4 & 5, SGA Start up Level
	SPLB-LT 1, SGB Full Range Level
	SPLB-LT 2 & 3, SGB Operate Level
	SP1B-LT 4 & 5, SGB Startup Level
5'-2" 384,038	✓ SPLA-LT1, SGA Full Range Level
	✓ SP6A-PT 1 & 2 SG-A Pressure
	✓ RC3A-PT 3 & 4 RC Pressure Wide Range
	✓ RC3A-PT 5 RC Pressure Low Range
	✓ RC3B-PT 3 RC Pressure Wide Range

Assumption:

- 1) BY transmitter will begin to fail about 10⁵ Rad.
 - 2) Foxboro transmitter will begin to fail above 10⁷ Rad.
 - 3) Transmitters have been receiving 1000 R/hr.
- Both BY and Foxboro transmitters may fail if submerged in water.
Water height is related to volume by 1 ft. per 74,330 gallons.

556259

Measurement Alternative

<u>Parameter</u>	<u>Primary Source of Measurement</u>	<u>Alternate Source of Measurement</u>	<u>Reference Backup Sheet</u>
RC Pressure	RC3A-PT 3&4 (Wide) ESFAS	RC22-PT 1 thru 8 RCP Seal Cavity Pressure	Note: Temperature vs saturation pressure via steam tables
	RC3B-PT 4 (wide) ESFAS	RC2-TA 1&2 Pressurizer Temp.	
		CA-PI	Pressurizer steam or water sample pressure
		RC Pump Vibration	
		RC3A-PI 5 (low)	RC Pressure less than 500
RC Temperature	Income T/Cs	RC4A-TE 2&3, T_{Hot} RC4B-TE 2&3, T_{Hot} RC5A-TE 2&4, T_{Cold} RC5B-TE 2&4, T_{Cold} RC-TE9 RC4A-TE 1&4, T_H RC4B-TE 1&4, T_H RC5A-TE 1&3, T_C RC5B-TE 1&3, T_C RC15A-TE1, T_H RC15B-TE1, T_H RC15A-TE2, T_C RC15B+TE2, T_C RC15A-TE3, T_C RC15B-TE3, T_C RC-TE11 MU-TES	

555360
Accounting for Coolant