

OPERATING DATA REPORT

DOCKET NO. 50-133
 DATE 7-2-79
 COMPLETED BY B. C. Gett
 TELEPHONE (707) 443-2787

OPERATING STATUS

1. Unit Name: HBPP No. 3
 2. Reporting Period: June, 1979
 3. Licensed Thermal Power (MWt): 220
 4. Nameplate Rating (Gross MWe): 65
 5. Design Electrical Rating (Net MWe): 65
 6. Maximum Dependable Capacity (Gross MWe): 65
 7. Maximum Dependable Capacity (Net MWe): 65
 8. If Changes Occur in Capacity Ratings (Items Number 3 Through 7) Since Last Report, Give Reasons: N/A

Notes

9. Power Level To Which Restricted, If Any (Net MWe): N/A
 10. Reasons For Restrictions, If Any: N/A

	This Month	Yr.-to-Date	Cumulative
11. Hours In Reporting Period	<u>720</u>	<u>4343</u>	<u>139511</u>
12. Number Of Hours Reactor Was Critical			<u>98171</u>
13. Reactor Reserve Shutdown Hours			<u>0</u>
14. Hours Generator On-Line			<u>97252</u>
15. Unit Reserve Shutdown Hours			<u>0</u>
16. Gross Thermal Energy Generated (MWH)			<u>15618456</u>
17. Gross Electrical Energy Generated (MWH)			<u>4739732</u>
18. Net Electrical Energy Generated (MWH)	<u>-168</u>	<u>-1190</u>	<u>4487577</u>
19. Unit Service Factor			<u>69.7%</u>
20. Unit Availability Factor			<u>69.7%</u>
21. Unit Capacity Factor (Using MDC Net)			<u>51.0%</u>
22. Unit Capacity Factor (Using DER Net)			<u>49.5%</u>
23. Unit Forced Outage Rate			<u>1.91%</u>

24. Shutdowns Scheduled Over Next 6 Months (Type, Date, and Duration of Each): N/A

25. If Shut Down At End Of Report Period, Estimated Date of Startup: Indeterminate

26. Units In Test Status (Prior to Commercial Operation): N/A

	Forecast	Achieved
INITIAL CRITICALITY	_____	_____
INITIAL ELECTRICITY	_____	_____
COMMERCIAL OPERATION	_____	_____

7907180409

364 196

UNIT SHUTDOWNS AND POWER REDUCTIONS

DOCKET NO. 50-133
 UNIT NAME H.B.P.P. No. 3
 DATE 7-2-79
 COMPLETED BY B.C. GCHY
 TELEPHONE (707) 443-2787

REPORT MONTH June, 1979

No.	Date	Type ¹	Duration (Hours)	Reason ²	Method of Shutting Down Reactor ³	License Event Report #	System Code ⁴	Component Code ⁵	Cause & Corrective Action to Prevent Recurrence
76-6	760702	S	720	C, H	1	N/A	22	222222	Seismic Modifications
364	197								

- 1 F: Forced
 S: Scheduled

- 2 Reason:
 A-Equipment Failure (Explain)
 B-Maintenance or Test
 C-Refueling
 D-Regulatory Restriction
 E-Operator Training & License Examination
 F-Administrative

- 3 Method:
 1-Manual
 2-Manual Scram.
 3-Automatic Scram.
 4-Other (Explain)

- 4 Exhibit G - Instructions for Preparation of Data Entry Sheets for License Event Report (LER) File (NUREG-0161)
- 5 Exhibit I - Same Source

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50-133
 UNIT HBPP Na3
 DATE 7-2-79
 COMPLETED BY B.C. Getty
 TELEPHONE (707) 443-2787

MONTH June, 1979

DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)	DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)
1	0	17	0
2	0	18	0
3	0	19	0
4	0	20	0
5	0	21	0
6	0	22	0
7	0	23	0
8	0	24	0
9	0	25	0
10	0	26	0
11	0	27	0
12	0	28	0
13	0	29	0
14	0	30	0
15	0	31	
16	0		

INSTRUCTIONS

On this format, list the average daily unit power level in MWe-Net for each day in the reporting month. Compute to the nearest whole megawatt.

(9/77)