



UNITED STATES
NUCLEAR REGULATORY COMMISSION
REGION III
799 ROOSEVELT ROAD
GLEN ELLYN, ILLINOIS 60137

TIC

JUN 6 1979

Docket No. 50-266

Docket No. 50-301

Wisconsin Electric Power Company
ATTN: Mr. Sol Burstein
Executive Vice President
Power Plants
231 West Michigan
Milwaukee, WI 53201

Gentlemen:

Enclosed is supplement IE Bulletin No. 79-01A. It requires action by you with regard to power reactor facilities with an operating license except for the 11 SEP plants which are listed in Enclosure 3.

This Bulletin is also being sent for information to the 11 SEP plants and all power reactor facilities with a construction permit. No action or written response is required for construction permit facilities or the 11 SEP plants.

Should you have questions regarding this Bulletin or the actions required of you, please contact this office.

Sincerely,

James G. Keppler
James G. Keppler
Director

Enclosure: IE Bulletin
No. 79-01A

cc w/encl:
Mr. G. A. Reed, Manager
Central Files
Director, NRR/DPM
Director, NRR/DOR
C. M. Tremmel, ORB/NRR
PDR
Local PDR
NSIC
TIC
Sandra A. Bast, Lakeshore
Citizens for Safe Energy

343 280

7907190296

U.S. NUCLEAR REGULATORY COMMISSION
OFFICE OF INSPECTION AND ENFORCEMENT

REGION III

June 6, 1979

IE Bulletin No. 79-01A

SUPPLEMENT NO. 79-01A TO IE BULLETIN 79-01 - ENVIRONMENTAL QUALIFICATION OF CLASS IE EQUIPMENT (DEFICIENCIES IN THE ENVIRONMENTAL QUALIFICATION OF ASCO SOLENOID VALVES)

Description of Circumstances:

Recently, a noncompliance report under 10 CFR Part 21 was received by the NRC from the Henry Pratt Company, manufacturer of butterfly valves which are installed in the primary containment at the Three Mile Island Unit 2 Nuclear Station. These butterfly valves are used for purge and exhaust purposes and are required to operate during accident conditions. The report discusses the use of an unqualified solenoid valve for a safety-related valve function which requires operation under accident conditions. The solenoid valve in question is Catalogue No. HT-8331A45, manufactured by the Automatic Switch Company (ASCO) of Florham Park, New Jersey. This pilot valve is used to pilot control the pneumatic valve actuators which are installed on the containment ventilation butterfly valves at this facility.

The deficiency in these solenoid valves identified in the Part 21 Report concerns the parts made of acetal plastic material. The acetal disc holder assembly and bottom plug in the pilot valve assembly are stated by ASCO to have a maximum service limit of 400,000 Rad integrated dosage and 200 degrees F temperature. According to ASCO, exposure of these acetal plastic parts to specified maximum environmental conditions may render the solenoid pilot valve inoperable which would cause the associated butterfly valve to malfunction.

Further investigation at ASCO by the NRC staff has revealed that the valve seals in most ASCO solenoid valves contain Buna "N" elastomer material, which reportedly has a maximum service limit of 7,000,000 Rad integrated dosage and 180 degrees F temperature. The investigation further revealed that ASCO has available a line of qualified solenoid operated pilot valves (ASCO Catalogue No. NP-1) which have no plastic parts, utilize ethylene propylene or viton elastomers and have a continuously energized operating life of four years, under normal ambient conditions up to 140 degrees F. According to the manufacturer, at the end of this period, the coil, manual operator (optional feature) and all resilient parts must be replaced. These preventive maintenance instructions are specified in the installation and instruction bulletins which are provided to the purchaser with each shipment of solenoid valves.

The final items of concern identified are the application of Class "A", "B", or "C" equipment in an accident environment. In this regard,

DUPLICATE DOCUMENT

Entire document previously entered into system under:

ANO

7907020173

No. of pages:

7

343 281