

LICENSEE EVENT REPORT

Report No. 2-79-31/3L

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

REPORT SOURCE	L	6	0	5	0	-	0	2	7	7	1	0	6	2	2	7	9	8	0	7	2	0	7	9	9
	60	61	DOCKET NUMBER						68	EVENT DATE						74	REPORT DATE						80		

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

During electrical storm, both units at power, lightning struck vicinity

of main stack result loss main stack sampling system, initiation of HPCI

& RCIC on Unit 3, and trip of Unit 3 Startup & Emergency feed. Shutdown

of Unit 3 begun due to unavailability of automatic initiation capability

of HPCI & RCIC. Fuse replaced. Shutdown of both units initiated due to

loss of stack sampling system. Shutdowns terminated upon discovery and

replacement of blown fuses. Safety consequences were small.

SYSTEM CODE M C (11)		CAUSE CODE C (12)		CAUSE SUBCODE Z (13)		COMPONENT CODE X X X X X (14)				COMP. SUBCODE Z (15)		VALVE SUBCODE Z (16)	
9 10		11 12		13 14		15 16 17 18				19 20		21 22	
LER/RO REPORT NUMBER 17		EVENT YEAR 7 0 (21) (22)		SEQUENTIAL REPORT NO. 0 3 1 (24) (25) (26)		OCCURRENCE CODE 0 3 (28) (29)		REPORT TYPE L (30)		REVISION NO. 0 (32)			
23 24		25 26		27 28		29 30		31 32		33 34		35 36	
ACTION TAKEN A (18)		FUTURE ACTION Z (19)		EFFECT ON PLANT P (20)		SHUTDOWN METHOD A (21)		HOURS 0 0 0 1 (22) (23) (24) (25)		ATTACHMENT SUBMITTED Y (26)		NPRD-4 FORM SUB. Y (27)	
37 38		39 40		41 42		43 44		45 46		47 48		49 50	
PRIME COMP. SUPPLIER A (25)		COMPONENT MANUFACTURER Z 9 9 9 (26) (27) (28) (29)											

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

FACILITY STATUS (28) 8 10 12 13 44
% POWER 1 0 0 (29)
OTHER STATUS (30) Unit 3 at 45%
METHOD OF DISCOVERY (31) A
DISCOVERY DESCRIPTION (32) Operator observation

ACTIVITY CONTENT
RELEASED OF RELEASE

2 33 2 34 NA

AMOUNT OF ACTIVITY (35)

LOCATION OF RELEASE (36)

NA

PERSONNEL EXPOSURES			DESCRIPTION	
NUMBER	TYPE			
00	37	7	38	NA

421 22580

PERSONNEL INJURIES		
NUMBER	DESCRIPTION	
000	NA	

11 12
LOSS OF OR DAMAGE TO FACILITY (43)
TYPE DESCRIPTION NA
2 (42) 7 907270 221 J

10
PUBLICITY
ISSUED (11) DESCRIPTION (45) NA
68 69 70

NRC USE ONLY

(215) 841-5020