



Commonwealth Edison
 Zion Generating Station
 Shiloh Blvd. & Lake Michigan
 Zion, Illinois 60099
 Telephone 312/746-2084

D. 6114
 TERA
 DEBRA

June 4, 1979

Mr. James G. Keppler
 Nuclear Regulatory Commission
 Region III
 799 Roosevelt Road
 Glen Ellyn, Ill 60132

Dear Mr. Keppler,

With regard to our report for the 2nd Quarter of 1979 confirmatory measurements program dated May 25, 1979, the below revised results are submitted for correction. An error in counting time was discovered after our report was submitted.

Revised Results

<u>Sample Identification</u>	<u>Isotope</u>	<u>Activity</u>	<u>Date of Analysis</u>
Particulate Filter	I-131	1.16E-4 Uci	4-11-79
Gamma Scan Unit	I-133	1.10E-4 Uci	4-11-79
1 Containment	Cs-134	1.38E-4 Uci	4-11-79
	Cs-137	2.50E-4 Uci	4-11-79
	Co-60	4.84E-5 Uci	4-11-79
Unit 1 Charcoal Absorber	I-131	1.77E-11 Uci	4-11-79

In addition, the column of our report reading "Date of Activity" should read, "Date of Analysis".

Sincerely,

Joseph L. Firoved
 Joseph L. Firoved

569345

Approved:

N.E. Wandke
 N.E. Wandke
 Station Superintendent

JUN 14 1979

cc: file

79073 00506