

GENERAL ELECTRIC

NUCLEAR ENERGY  
PROJECTS DIVISION

GENERAL ELECTRIC COMPANY, 175 CURTNER AVE., SAN JOSE, CALIFORNIA 95125  
MC 682, (408) 925-3732

MFN-188-79  
RLG-100-79  
July 20, 1979

U. S. Nuclear Regulatory Commission  
Division of Operating Reactors  
Office of Nuclear Reactor Regulation  
Washington, D. C. 20555

Attention: Mr. C. Y. Cheng  
Engineering Branch

Gentlemen:

SUBJECT: INFORMATION REQUESTED ON PIPE CRACKS

Mr. Bernard Turovlin made several requests on pipe cracks during his visit to San Jose on June 21, 1979. Responses to the questions are attached.

In a subsequent telephone call to you, I have the understanding that you and Mr. Turovlin are cooperating on updating NUREG 0313. Please keep me informed of your progress. Don't hesitate to ask me or H.T. Watanabe for any additional information.

Sincerely,

*H.T. Watanabe*

*for* R. L. Gridley, Manager  
Operating Plant Licensing

RLG:pes/860

Attachment

cc: Mr. Vincent Noonan, Manager  
Engineering Branch  
Division of Operating Reactor

Mr. Bernard Turovlin  
Metallurgy Section  
Division of System Safety

Mr. L. S. Gifford, GE - Bethesda

X601  
S/11

489 011

7908010

57.0.B

ATTACHMENT

INFORMATION REQUESTED DURING  
JUNE 21, 1979 MEETING

1. Provide information to allow the NRC to accept the use of 316 NG S.S.

Response:

Pertinent information is provided in: 1) R. L. Cowan's summary "Review of Plant Materials, Related Development Programs", 7/10/79 (copy enclosed) and 2) "Alternate Alloys for BWR Piping Application, Third Semi-Annual Progress Report", NEUC-23750-5. The latter report was left with Mr. Turovlin during his meeting with R. L. Cowan and N. C. Shirley on July 10, 1979.

2. Provide corrosion information of ferritic pipe.

Response:

Ferritic piping is provided by the Architect-Engineer, therefore, out of GE scope.

3. Define which joints will be solution heat treated.

Response:

This information is shown on Drawing No. 767E212 which was distributed at Progress Report Meeting No. 6 held in San Jose on April 3-4, 1979.

4. Provide more data to demonstrate acceptability of Heat Sink Welding, ECK, and IHSI.

Response:

ECK (EPR) is an NRC program (Mr. Mascara is the Program Manager). IHSI is under development and is not currently applied.

Information on heat sink welding is provided in the first report cited in Item 1.

5. Ensure NRC has the latest GE positions on Regulatory Guides addressing piping materials, e.g., RG 1.44, 1.45 and 1.46.

Response:

GE has transmitted comments on all three guides to the NRC.

6. Provide more correlation data to establish the validity of the Stress Rule Index.

Response:

To date, stress rule values have been calculated for three BWR

piping systems: Core spray line, recirculation bypass line, and recirculation systems. No failures have occurred where stress rule index was below one. Failures did occur where the stress rule index exceeded one. Also, the failure rate increases as the stress rule index increases.

Of the 4,252 welds evaluated for BWR/1, 3, and 4, there were 3,240 welds (76%) with a stress rule index exceeding one. Figure 1 shows the failure rate for these welds as a function of the stress rule index. This figure strongly supports the validity of stress rule index for evaluating IGSCC occurrences.

7. Provide justification for not making the recirculation system service sensitive.

Response:

There is not sufficient justification for reclassifying the main recirculation and recirculation-riser piping to the non-conforming, service-sensitive category. To date, there have been no recorded instances of cracking in these piping in the United States.

8. Provide recommendations for late-in-life inservice inspection requirements.

Response:

GE's recommended inspection requirements would be in accordance with NUREG 0313 and/or an alternative plan mutually and technically acceptable by the Utilities and NRC. The alternative inspection plan would be based on degree of susceptibility to cracking, carbon content, stress level, and previous service/failure history. When this plan has been firmed, GE will request a meeting with the NRC for detailed discussions.

9. Provide recommendations on avoidance of resin intrusion into the primary system.

Response:

Several BWR/4's had occurrences of resin intrusion into the primary system. In 1976, GE issued Service Information Letter (SIL) No. 159, copy enclosed, which included recommended actions. Resin intrusion has not been a problem since the issuance of the SIL.

10. Provide reference material on O<sub>2</sub> control.

Response:

A copy of "BWR Coolant Oxygen Control", NEDO-23631, June 1977 is enclosed.

RLG:pes/861-862

Enclosures

487 013




Figure 1. Stress Rule Index (per new Residual Stress)

JHL 5/79

489 014

GENERAL ELECTRIC COMPANY

NUCLEAR TECHNOLOGY DEPARTMENT

REVIEW OF PLANT MATERIALS

RELATED DEVELOPMENT

PROGRAMS

7/10/79

R.L.COWAN

489 015

PLANT MATERIALS DEVELOPMENT PROGRAMS

- EVALUATION OF STRESS CORROSION CRACKING OF BWR MATERIALS,
  - FUNDAMENTAL UNDERSTANDING
  - PARAMETRIC STUDIES
  - SHORT TERM REMEDIES
  - ALTERNATE MATERIALS
  - IMPROVEMENTS APPLICABLE TO OPERATING PLANTS
  
- EFFECT OF ENVIRONMENT ON FATIGUE PROPERTIES.
  - LOW AND HIGH CYCLE
  - INITIATION AND PROPAGATION
  
- WEAR RESISTANT ALLOYS WITH LOW COBALT.
  
- WELDING TECHNIQUES.
  
- NON DESTRUCTIVE TEST TECHNIQUES.

- |                                                                                                                                                   |
|---------------------------------------------------------------------------------------------------------------------------------------------------|
| <ul style="list-style-type: none"><li>● FOCUS ON INCREASED AVAILABILITY</li><li>● COMPREHENSIVE</li><li>● UTILITY COOPERATION EXCELLENT</li></ul> |
|---------------------------------------------------------------------------------------------------------------------------------------------------|

489 016  
7/10/79  
R.L.COWAN

OUTSIDE FUNDED PROGRAMS IN  
PLANT MATERIALS AREA

NRC ● ELECTROCHEMICAL METHOD FOR DETECTION OF DEGREE OF SENSITIZATION IN STAINLESS STEEL.

EPRI ● PARAMETRIC PIPING STUDIES OF STAINLESS  
● QUALIFICATION OF NEAR TERM PIPING REMEDIES  
● ALTERNATE PIPING MATERIAL QUALIFICATION PROGRAM  
● CARBON STEEL FATIGUE  
● LARGE DIAMETER PIPE SCC MARGIN  
● PIPING RESIDUAL STRESS IMPROVEMENT

DOE (AS SUBCONTRACTOR)


● ALTERNATE BWR WATER CHEMISTRY

- |                                                                                                                                       |
|---------------------------------------------------------------------------------------------------------------------------------------|
| <ul style="list-style-type: none"><li>- HELPS FOCUS DEVELOPMENT WORK ON COMMON OBJECTIVES</li><li>- ACCELERATES APPLICATION</li></ul> |
|---------------------------------------------------------------------------------------------------------------------------------------|

489 017


7/10/79  
R.L.COWAN

# 4 in. VERTICAL PIPE TEST STAND



489 018





COOLANT DESCRIPTION

OXYGEN  $6 \pm 2$  ppm  
 TEMPERATURE  $540 \pm 10^{\circ}\text{F}$  ( $282^{\circ}\text{C} \pm 5^{\circ}\text{C}$ )  
 pH  $5.5 \pm 0.5$

LOADING MODE:

AXIAL 136% OF  $\sigma_{ys}$  AT  $550^{\circ}\text{F}$  ( $288^{\circ}\text{C}$ )  
 PRESSURE  $p_r/2t = 4$  ksi

# QUALIFICATION OF ALTERNATE ALLOY FOR BWR WELDED PIPING

## PROGRAM OBJECTIVE

SELECT, QUALIFY, AND IMPLEMENT INTO BWR  
SERVICE ALTERNATE ALLOYS FOR TYPE-304  
STAINLESS STEEL WHICH WILL NOT EXPERIENCE  
INTERGRANULAR STRESS CORROSION CRACKING  
WITHIN THE PLANT DESIGN LIFETIME.

## METHOD OF ACCOMPLISHMENT:

### 1. SCREENING STUDIES AND SELECTION.

- CHOOSE CANDIDATE ALTERNATE ALLOYS AND PERFORM SCREENING STUDIES.
- SELECT ALTERNATE ALLOYS FOR QUALIFICATION USING DECISION MODEL.

### 2. QUALIFICATION.

- PERFORM STRINGENT TESTS TO DEFINE IGSCC MARGIN OF SELECTED ALTERNATE ALLOYS.
- PERFORM IN-DEPTH PHYSICAL AND METALLURGICAL CHARACTERIZATION OF ALTERNATE ALLOY PIPING OF VARIOUS SIZES AND MANUFACTURING METHODS.

### 3. IMPLEMENTATION INTO BWR SERVICE.

- PROVIDE NUCLEAR GRADE MATERIAL SPECIFICATIONS.
- QUALIFY MATERIAL SUPPLIERS.
- ASSURE CODE AND REGULATORY ACCEPTANCE.

CANDIDATE ALTERNATE ALLOYS

304L/NUCLEAR GRADE

316

316L/NUCLEAR GRADE

347

CF-3

XM-19

489 022

## SCREENING STUDIES

- PIPE TESTING
- FATIGUE INITIATION TESTING
- STATIC CRACK GROWTH
- CYCLIC CRACK GROWTH
- CONSTANT EXTENSION RATE

### FINAL PIPE TEST RESULTS – SCREENING

ALLOY	PIPES TESTED	PIPES FAILED BY IGSCC	MAXIMUM HOURS ACCUMULATED	FACTOR OF IGSCC IMPROVEMENT
REFERENCE TYPE 304	19	14	7800*	1
REFERENCE TYPE 316L/ NUCLEAR GRADE	11	0**	8500	>20
REFERENCE TYPE 304L/ NUCLEAR GRADE	9	0	7800	>20
REFERENCE TYPE 347	8	0***	6900	>20
REFERENCE TYPE 316	3	0	1900	>20
REFERENCE TYPE CF-3	8	0	7400	>20


\*MEAN TIME TO FAILURE FOR REFERENCE TYPE 304 WITH 0.05 TO 0.08% CARBON = 239 HOURS.

\*\*TWO PIPES FAILED BY TRANSGRANULAR MODE WITH MINOR AMOUNT OF INTERGRANULAR FEATURES.

\*\*\*ONE PIPE FAILED BY TRANSGRANULAR MODE WITH MINOR AMOUNT OF INTERGRANULAR FEATURES.

FATIGUE INITIATION TESTING


489 025



- SMOOTH (3/4%, 1-1/4% STRAIN)
- INTERGRANULAR ATTACK, COLD WORKED, AND WELDED
- ALL SAMPLES HAVE 932°F/24 hr LOW TEMPERATURE SENSITIZATION AFTER WELDING

ALLOY	COMPOSITION RANGE	NO OF HEATS
316	0.06%C	1
316 (L)	0.020 - 0.030%C	2
304 (L)	0.018 - 0.027%C	2
347	0.023 - 0.038%C	2
XM-19	0.05%C	1
CF-3	10% $\alpha$ TO 25% $\alpha$	2
REFERENCE 304	COMPLETE IN PREVIOUS PROGRAM	
SAMPLES ON TEST JUNE 1978		





489 027

SELECTION OF ALTERNATE ALLOYS FOR QUALIFICATION

TYPE-316 NUCLEAR GRADE

TYPE-304 NUCLEAR GRADE

CARBON  $\leq 0.020\%$

NITROGEN\* 0.06 – 0.16%

\*NITROGEN CURRENTLY RESTRICTED TO  $\leq 0.10\%$  BY ASME SA-240.

## SUMMARY

- ALL CANDIDATE ALTERNATE ALLOYS EVALUATED (EXCEPT HIGH CARBON TYPE-316) WOULD BE MORE THAN ADEQUATE REPLACEMENTS FOR TYPE-304 STAINLESS STEEL, BASED SOLELY ON IGSCC RESISTANCE.
- CONSIDERING ADVANTAGES AND DISADVANTAGES OF EACH CANDIDATE ALLOY, AS DEFINED AND WEIGHTED BY THE DECISION ANALYSIS, TYPE-316 NUCLEAR GRADE WAS SELECTED AS THE BEST BALANCED CHOICE TO REPLACE TYPE-304 IN THE BWR.

COUNTERMEASURES FOR 304 SS  
PROGRAM STATUS AS OF 6/79

<u>MATERIALS CONDITION</u>	<u>NO. HEATS</u>	<u>WELDS FAILED/ WELDS TESTED</u>	<u>FACTOR OF IMPROVEMENT*</u>
REFERENCE TYPE 304 SS (ALL HEATS)	3	23/53	1
CORROSION RESISTANT CLAD PLUS SOLUTION HEAT TREATMENT (SHOP REMEDY)	3	0/33	~65
CORROSION RESISTANT CLAD AS DEPOSITED (FIELD REMEDY)	2	0/22	~6
REFERENCE TYPE 304 SS SENSITIZED MATERIAL	1	4/11	1
CORROSION RESISTANT CLAD DEPOSITED ON SENSITIZED MATERIAL	1	4/13	~6

\*TO DATE

489 030

COUNTERMEASURES FOR 304 SS  
PROGRAM STATUS AS OF 6/79

<u>MATERIALS CONDITION</u>	<u>NO. HEATS</u>	<u>WELDS FAILED/ WELDS TESTED</u>	<u>FACTOR OF IMPROVEMENT*</u>
REFERENCE TYPE 304 SS (ALL HEATS)	3	23/53	1
SOLUTION HEAT TREATMENT	3	0/33	~ 65
HEAT SINK WELDING	1	2/24	~ 15

\*To DATE

- RECOMMENDED COUNTERMEASURES ARE EFFECTIVE
- GENERIC RECIRCULATION PIPING RECOMMENDATION MADE TO ALL BWR PROJECTS

## EQUATION USED FOR FACTOR OF IMPROVEMENT CALCULATIONS

---

$$\text{LOG TEST TIME} = F + G + \sigma \left[ -Q + U(1/n + r)^{1/2} \right]$$


- WHERE: F = MEAN LOG TIME TO FAILURE OF REFERENCE WELDS
- G = LOG OF DESIRED IMPROVEMENT FACTOR
- $\sigma$  = STANDARD DEVIATION OF LOG TIMES TO FAILURE OF REFERENCE WELDS
- Q = FACTOR ON  $\sigma$  FOR EXPECTED LOCATION OF FIRST ORDER STATISTIC (Q = 1.5864 FOR n OF 11)
- U = NORMAL DISTRIBUTION COEFFICIENT FOR 90% ONE-SIDED LIMIT (U = 1.282)
- n = NUMBER OF TEST WELDS PER CONCEPT (n = 11)
- r = FACTOR ON  $\sigma^2$  FOR VARIANCE OF FIRST ORDER STATISTIC (r = 0.3332) FOR n = 11)

489 032

EQUATION USED FOR FACTOR OF IMPROVEMENT CALCULATIONS

POOR ORIGINAL

# INDUCTION HEATING (RSI) PROCESS



AFTER COOLDOWN  
COMPRESSIVE RESIDUAL STRESS ON INSIDE,  
TENSILE RESIDUAL STRESS ON OUTSIDE.

489 033

POOR ORIGINAL

Program Summary

**TASK 1 Process Development and Optimization**

**TASK 2 Evaluation of IGSCC Margin Improvement**

**TASK 3 Evaluation of Operating Plant Application**

**TASK 4 Implementation Planning and Field Procedure Development**

**POOR ORIGINAL**



# MILESTONE SCHEDULE

	QUARTERS							
	1978 4th	1st	1979			1980		
			2nd	3rd	4th	1st	2nd	
<b>Task 1. Stress Improvement Process Development</b>								
Induction Heating Tests	▨	▨	▨					
Analysis (Battelle-Columbus)	▨	▨	▨	▨	▨			
<b>Task 2. Qualification of IGSCC Margin Improvement</b>								
Residual Stresses	▨	▨	▨	▨	▨	▨		
Metallography, Sensitization, Mech Prop Tests	▨	▨	▨	▨	▨	▨		
Pipe Tests	▨	▨	▨	▨	▨	▨	▨	
<b>Task 3. Evaluation of Operating Plant Application</b>								
Pre-Cracked Pipe Tests			▨	▨	▨	▨	▨	
Residual Stresses Measurements				▨	▨			
Analytical Modeling (Battelle-Columbus)				▨	▨	▨	▨	
<b>Task 4. Implementation Planning and Field Procedure Development</b>								
Field Application Review	▨	▨	▨					
Field Procedure Development			▨	▨	▨	▨		
Specifications							▨	

489 035

POOR ORIGINAL

BASIS FOR SELECTION OF TEMPERATURE

DIFFERENTIAL BETWEEN OUTER AND

INNER PIPE SURFACES ( $\Delta T$ )

PREMISE: THE THERMAL STRESS MUST EXCEED YIELD STRESS

THERMAL STRESS ( $\sigma$ ) - LINEAR GRADIENT


$$\sigma = \frac{E \alpha \cdot \Delta T}{2(1-\nu)}$$

E - YOUNGS MODULUS

$\alpha$  - THERMAL EXPANSION COEFFICIENT

$\nu$  - POISSONS RATIO

$\Delta T$  - TEMPERATURE DIFFERENCE



## OPTIMIZATION TEST RESULTS


### SELECTED RSI PARAMETERS

	PIPE SIZE AND SCHEDULE			
	4 in. PIPE	10 in. PIPE	16 in. PIPE	26 in. PIPE
$\Delta T$	400°C ± 50°	400°C ± 50°	400°C ± 50°	400°C ± 50°
MAX o.d. TEMP	500°C <sup>+50°</sup> -0°	500°C	500°C	500°C
AXIAL TEMP LENGTH	3 in.	4 in.	6 in.	10 in.
TIME TO REACH TEMP	< 13 sec	< 40 sec	< 80 sec	< 200 sec
INDUCT FREQUENCY	3 kHz	3 kHz	3 kHz	3 kHz
COIL DESIGN*	SINGLE TURN	SINGLE TURN	SINGLE TURN	SINGLE TURN
i.d. WATER FLOW	1/2 m/s	1/2 m/s	1/2 m/s	1/2 m/s
COIL AXIAL LENGTH	4 in.	6 in.	10 in.	14 in.
HEATING POWER	120 kW	250 kW	370 kW	390 kW
PRE-HEAT MAX TEMP	< 200°C	< 200°C	< 200°C	< 200°C

\* ALTHOUGH SINGLE TURN COILS ARE SPECIFIED FOR UNIFORMITY IN TEST SPECIMEN TREATMENT, THERE IS NO RESTRICTION IN THE USE OF MULTI-TURN COILS IN PRACTICE

489 037

# YIELD STRESS vs DISTANCE FROM WELD CENTERLINE FOR THE REFERENCE AND RSI-TREATED SPECIMEN



489 038

ESTABLISH MARGIN OF IMPROVEMENT FOR TREATED  
AND REFERENCE PIPES

## PIPE TESTING

- SIMULATE SERVICE EXPOSURE
- ESTABLISH TIME TO FIRST FAILURE FOR TREATED AND REFERENCE PIPES
- ESTABLISH MARGIN OF IMPROVEMENT

LOW TEMPERATURE SENSITIZATION  
INSIDE DIAMETER GRINDING  
RESIDUAL STRESS IMPROVEMENT TREATMENT

## FABRICATION VARIABLES

- LOW TEMPERATURE SENSITIZATION
- INSIDE DIAMETER GRINDING
- RESIDUAL STRESS IMPROVEMENT TREATMENT

489 040

## PROGRESS

### PIPE TESTING, REFERENCE SPECIMEN

- TEST CONDITIONS:

STRESS, 136% OF 288° C Y.S.  
OXYGEN, 8 PPM.  
TEMPERATURE, 288° C.  
CYCLIC RATE, 0.67 CPH.

- FIRST REFERENCE FAILURE (THROUGHWALL CRACK) AFTER 456 CYCLES AT JOINT E.
- VISUAL AND U.T. EXAMINATION PERFORMED: - ALL JOINTS EXCEPT HSW SHOWED SOME DEGREE OF CRACKING.
- SPECIMEN REPAIRED AND TESTING RESUMED. SECOND FAILURE (THROUGHWALL CRACK) 14 CYCLES AFTER TEST RESUMPTION (470 CYCLES TOTAL).
- TESTING OF REFERENCE DISCONTINUED AFTER SECOND FAILURE.
- FRACTURE MODE ON BOTH JOINTS, IGSCC.

POOR ORIGINAL

489 047

PROGRESS

INDUCTION PIPE TESTING, INDUCTION-TREATED SPECIMEN

- FIVE OUT OF SIX JOINTS HAVE ACCUMULATED OVER 2800 CYCLES ( $>6X$  REFERENCE).
- ONE FAILURE (THROUGHWALL CRACKING) AFTER 463 CYCLES AT JOINT B.
- NDE EXAMINATION INDICATED NO CRACKING EXCEPT FOR JOINT B.
- FRACTURE MODE ON JOINT B, IGSCC.
- SPECIMEN REPAIRED AND RETURNED TO TEST. NO ADDITIONAL FAILURES TO DATE.

POOR ORIGINAL



PARAMETRIC STUDIES ON IGSCC OF TYPE-304 STAINLESS STEEL PIPE WELDS

**PURPOSE:** TO DETERMINE THE EFFECT OF PIPE TEST PARAMETERS AND WELDING RESIDUAL STRESSES ON PIPE TEST RESULTS.

**METHOD:** PIPE TESTS WILL BE CONDUCTED WITH VARIATIONS OF TEST PARAMETERS AND RESIDUAL STRESSES. RESULTS WILL BE COMPARED TO REFERENCE SPECIMENS TESTED UNDER THE ACCELERATED CONDITIONS NORMALLY SPECIFIED FOR PIPE TESTING.

TASK ORGANIZATION

**TASK 1** EFFECT OF APPLIED STRESS, OXYGEN CONCENTRATION, CYCLIC RATE AND TEMPERATURE ON PIPE TEST RESULTS.

**TASK 2** EFFECT OF WELDING RESIDUAL STRESSES ON PIPE TEST RESULTS.

POOR ORIGINAL

489

045

**TEST SPECIMEN DESCRIPTION TEST SPECIMEN DESCRIPTION**

- TASK 1** • TEN PIPE SPECIMENS FOR TESTING IN A THREE-YEAR PERIOD.
  - EACH STAINLESS-STEEL PIPE WILL HAVE TEN WELD JOINTS.
  - ALL JOINTS WILL BE GROUND.
  - ALL PIPES FROM ONE SUSCEPTIBLE HEAT OF MATERIAL.
- 
- TASK 2** • ONE PIPE SPECIMEN WITH SIX WELDS FOR TESTING IN 1979.
  - ONE WELDED SPECIMEN FOR RESIDUAL STRESS MEASUREMENTS.
  - BOTH SPECIMEN FROM SAME HEAT OF MATERIAL AS TASK 1.
  - NO GRINDING OR LTS WILL BE PERFORMED.
  - TESTS ON ONE REFERENCE AND ONE INDUCTION-TREATED PIPE WERE INITIATED IN 1978.

**POOR ORIGINAL**

489 044

PROGRAM:

THE GROWTH AND STABILITY OF STRESS CORROSION CRACKS  
IN LARGE-DIAMETER BWR PIPING - RP 1554-1

SPECIFIC OBJECTIVES:

1. DEVELOP A QUANTITATIVE UNDERSTANDING OF THE SAFETY MARGIN ASSOCIATED WITH PIPES CONTAINING CRACKS UNDER STATIC AND DYNAMIC LOADS.
2. DEVELOP A DETAILED QUANTITATIVE UNDERSTANDING OF FACTORS CONTROLLING THE RATE OF IGSCC IN LARGE-DIAMETER 304 STAINLESS STEEL PIPING.
3. DEVELOP AN OVERALL PREDICTIVE MODEL FOR THE GROWTH AND STABILITY OF CRACKS IN LARGE-DIAMETER BWR PIPING.

POOR ORIGINAL

489 045

TASK 2: CRACK GROWTH/ARREST EVALUATION

SUBTASKS:

1. FRACTURE MECHANICS MODELING
2. EVALUATION OF CRACK ARREST DUE TO RESIDUAL STRESSES
3. INVESTIGATION OF CRACK ARREST IN WELD-METAL
4. EVALUATION OF CRACK GROWTH RATES EXPECTED FOR SERVICE CONDITIONS
5. CONFIRMATORY PIPE TESTS

POOR ORIGINAL

# ALLOY 600 STUDIES TEST PROGRAM

## SPECIMEN METALLURGY

ALLOY 600 BASE (WITH ALLOY 82-GTAW AND  
ALLOY 182-(SMAW) AND ALLOY 82 AND 182  
WELD METAL

AW

AW + PWVHT

AW + PWVHT + LTS

AW + LTS

ALLOY 600 BASE METAL

HEAT TREATMENT BEFORE WELDING

PWVHT + W

PWVHT + W + LTS

## TEST CONDITIONS

GENERAL WATER CHEMISTRY:

288 C (550 F), 6 PPM O<sub>2</sub>, 5.5 PH, 1 UMHO/CM  
COND., CL<sup>-</sup> <.1 PPM

CONSTANT LOAD

(2) CREVICED

(2) NON-CREVICED

CONSTANT EXTENSION RATE

D O S\* TEST

(1) MODIFIED

ASTM G28-72

(1) UNMODIFIED

MECHANICAL PROPERTIES

(2)

IN 288 C (550 F) AIR

MECHANICAL PROPERTIES 288 C (550 F) ALSO  
OF AS RECEIVED AND OF HEAT TREATED BUT  
NON-WELDED ALLOY 600 BASE MATERIAL

\*DEGREE OF SENSITIZATION

489 047  
POOR ORIGINAL

IMPROVED CONTROL OF POWDERED RESINS FOR  
REACTOR WATER CLEANUP FILTER DEMINERALIZERS

As a result of several occurrences at BWR operating plants in which powdered resins from the Reactor Water Clean-Up (RWCU) Filter Demineralizers (F/D) have been introduced into the reactor pressure vessel, General Electric has examined the circumstances which led to the resin carry over.

It was determined that to reduce the probability of recurrence BWR owner-operators should undertake corrective action at their earliest possible convenience. The purpose of this Service Information Letter is to define the conditions causing the problem and to present the corrective action recommendations.

DISCUSSION

During certain modes of reactor water cleanup operation, it is possible for the powdered resins to be accidentally injected into the reactor pressure vessel (RPV) forcing startup delays until reactor water chemistry can be re-established within limits. These modes include:

- A. Loss of flow from the Cleanup Recirculation Pumps (CRP) with the bypass line open resulting in a siphon effect which can carry resins into the bypass line where they can later be injected into the RPV.
- B. At most BWR operating plants, low flow through the Filter/Demineralizer (F/D) starts the holding pump and opens the flow control valve further to maintain preset treated water flow. If this occurs with the F/D bypass valve open and water is draining to the hotwell or radwaste, loss of the CRPs will result in emptying the top of the F/D vessel, which, in turn, results in loss of suction at the holding pump. The consequence of these events is the siphoning of water and resin from the F/D into the bypass line where restart of the CRPs will inject resin into the RPV.

- C. Radical flow transients in the RWCU F/D system caused by the loss of CRPs and/or the sudden opening and closing of valves. With a sudden loss of flow to the F/D vessel, there is inadequate time for the holding pumps to get to rated speed and maintain the precoat on the elements.
- D. Loss of power to RWCU F/D System closes all inlet and effluent valves and prevents the holding pump from running unless the latter is on emergency circuit. With restoration of power, even with inlet and outlet valves closed, the holding pump will start recirculating the sludge (insoluble material from filtering action and resin). The sludge is dropped from the elements, due to no-flow condition upon, into, and around the elements and holding pump circuit.
- E. Sudden flow surges when placing a newly precoated F/D vessel on line will tend to cause migration of the resin particles through the filter elements.

#### RECOMMENDED ACTION

General Electric recommends implementation of the following modifications at the earliest convenient outage:

1. Install a "Y" strainer in the normal influent line, up-stream of the F/D vessel and influent valves. The strainer should have 75 micron slots and be installed in the reverse direction. This should prevent gross amounts of resins coming down with siphon water from entering by bypass line. A differential pressure indicator (DPI) would be required to indicate when the strainer screen is clogging due to particulate material from the RPV.

In certain cases, a swing check valve may be used in place of a "Y" strainer. The special conditions necessary for use of a check valve are:


- a) the valve must have resilient seats
- b) a vertical head minimum of 25 feet of water must be above the check valve
- c) the valve must be mounted in a vertical line

2. Modify the Filter/Demineralizer low flow isolation logic to isolate the F/D by closing the air operated influent and flow control valve when flow through the vessel circuit drops below approximately 40 percent of the preset flow value on the first F/D and 25 percent on the second. This modification should prevent the events described in item B in the discussion from occurring.
3. It should be noted that all F/D vessel circuits have a "low flow" annunciator which shares an initiation signal with the holding pump. The set point for all plants should be 75 percent of normal F/D vessel flow. In addition, logic should be added to automatically transfer the cleanup F/D vessel into a backwash mode if the time interval between low flow annunciation and F/D system isolation is less than 15 seconds. It is not necessary to annunciate holding pump operation or non-operation since system isolation will occur before the cake is lost even if the holding pump circuit fails.
4. Install speed controls on the main stream valves to avoid shocking the in-place precoat by limiting the inrush of water into the F/Ds. The time for opening or closing the main stream valves should be approximately 30 seconds. Many BWR plants, especially those where these valves were supplied by General Electric, have this feature.
5. Install power failure logic in the electrical circuitry which will prevent the operation of the hold pump or filter circuitry until the F/D units are backwashed. Without this logic, the hold pump will begin circulating sludge through partially pre-coated filters upon restoration of power which can lead to element plugging as well as a poor filter cake.


It should be noted that due to differences in type and configuration of some BWR equipment, the generic changes recommended above need to be evaluated for specific plant applicability. General Electric will be pleased to quote engineering assistance to ascertain and implement the specific changes applicable to your plant. Please contact your local General Electric service representative for such assistance.

Prepared by: W.L. Lewis/L.A. Gonzalez

Approved by:

  
D.L. Layton, Manager  
Product Service

Issued by:

  
D.L. Allred, Manager  
Utility Support Services

Product Reference: G31 - Reactor Water Cleanup (Filter Demineralizer)



NEDO-23631  
77NED106  
CLASS I  
JUNE 1977

# BWR COOLANT OXYGEN CONTROL

R. L. COWAN  
J. C. ELLIOTT  
O. H. JOHANNESON

GENERAL  ELECTRIC

489 051