## Chicago Bridge & Iron Company

8000 Fairbanks north Houston road plo box 40006 Houston, Texas 77040



telephone 713, 466 7581

April 24, 1979

Office of Inspection & Enforcement U. S. Nuclear Regulatory Commission Washington, D.C. 20555

Attention: Mr. G. W. Reinmuth

RE: NRC BULLETINS 78-12 & 78-12A

## Gentlemen:

In accordance with the above listed Bulletins and requirements from Westinghouse and General Electric, enclosed is one copy of our report.

This report includes information from all completed Reactor Vessels constructed by Chicago Bridge & Iron Co.

Very truly yours,

CHICAGO BRIDGE & IRON CO.

Ralph E. Kelley, Manager

CQA Services

Houston Operations

REK: mks

Enclosure

446 137

## Chicago Bridge & Iron Company

a300 Fallbanks north Houston road: p o box 40063 Houston, Texas 77040



10 Aphoba 713, 466 TR31

The documentation and information required by NRC Bulletins 78-12 and 78-12A, and GE PO # 205-A2764 for

are contained in the attached report.

Welding consumables were re-reviewed against the original requirements in accordance with the above listed documents. No deviations were found.

Based upon our records, I certify, to the best of my knowledge, this report is correct.

Ralph E. Kelley

Manager, CQA Services

Date