

TIC

DE, RA



UNITED STATES
NUCLEAR REGULATORY COMMISSION
REGION II
101 MARIETTA ST., N.W., SUITE 3100
ATLANTA, GEORGIA 30303

JUN 20 1979

In Reply Refer To
RII:FSC
50-424/79-07
50-425/79-07

Georgia Power Company
ATTN: W. E. Ehrensperger
Senior Vice President
Power Supply
P. O. Box 4545
Atlanta, Georgia 30302

Gentlemen:

We have reviewed the clarification for the Vogtle Nuclear Plant that you submitted to the Director of Nuclear Reactor Regulation, May 11 1979, concerning the use of 91-day compressive strength concrete specified in the construction specifications, versus the 28-day compressive strength concrete referenced in the Preliminary Safety Analysis Report for concrete design. In that you have brought the matter to the attention of that office, we have no further concerns with your placement of concrete to these design specifications at this time.

Should you have any questions concerning this letter, we will be glad to discuss them with you.

Sincerely,

Charles E. Murphy, Chief
Reactor Construction and Engineering
Support Branch

cc: K. M. Gillespie
Construction Project Manager
P. O. Box 282
Waynesboro, Georgia 30830

E. D. Groover
QA Site Supervisor
P. O. Box 282
Waynesboro, Georgia 30830

423 3574

7908020 553

Q