



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
REGION III  
799 ROOSEVELT ROAD  
GLEN ELLYN, ILLINOIS 60137

PDR

JUN 27 1979

Docket No. 50-295

Commonwealth Edison Company  
ATTN: Mr. Byron Lee, Jr.  
Vice President  
Post Office Box 767  
Chicago, IL 60690

Gentlemen:

The safeguards inspection report and letter issued following an inspection of your Zion Unit One reactor facility on May 29-31, 1979, was erroneously identified by this office as IE Inspection Report No. 50-295/79-08. The correct report number is No. 50-295/79-10.

We are sorry for any inconvenience this report number error may have caused you.

Sincerely,

*J. A. Hind*  
J. A. Hind, Chief  
Safeguards Branch

Enclosure: Corrected  
Cover Page

cc w/encl:  
Mr. N. Wandke, Plant  
Superintendent  
Central Files  
Reproduction Unit NRC 20b

cc w/ Appendix A, w/o  
IE Inspection Report  
No. 50-295/79-10  
PDR  
Local PDR

401 340

②  
7908070053

U.S. NUCLEAR REGULATORY COMMISSION  
OFFICE OF INSPECTION AND ENFORCEMENT

REGION III

Report No. 50-295/79-10

Docket No. 50-295 License No. DPR-39 Safeguards Group No. IV

Licensee: Commonwealth Edison Company  
Post Office Box 767  
Chicago, IL 60690

Facility Name: Zion Nuclear Power Station - Unit 1

Inspection At: Zion Generating Station, Zion, Illinois

Inspection Conducted: May 29-31, 1979

Inspectors: *J. F. Donohue*  
A. G. Finley *for*

*6/14/79*  
(Date)

*J. P. Patterson*  
J. P. Patterson *for*

*6/14/79*  
(Date)

Approved By: *J. F. Donohue*  
J. A. Hind, Chief *for*  
Safeguards Branch

*6/14/79*  
(Date)

Inspection Summary

Unannounced inspection on May 29-31, 1979 (Report No. 50-295/79-08)

Areas Inspected: Nuclear material control and accountability including facility organization and operation; measurement and controls; inventory and inventory verification; shipping and receiving; storage and internal controls; records and reports; management of material control system. The inspection involved 40 inspector-hours onsite by two NRC inspectors.

Results: Of the seven areas inspected, no apparent items of noncompliance or deviations were identified in five areas, two items of noncompliance (deficiency - not reporting a receipt and shipment by Form NRC-741 on Form NRC-742 - Paragraph 8 and deficiency for not following facility nuclear procedure No. 3 - Paragraph 8).

(Details: Part 2.790(d) Information)