



MAINE YANKEE ATOMIC POWER COMPANY •
ENGINEERING OFFICE

TURNPIKE ROAD (RT. 9)
WESTBORO, MASSACHUSETTS 01581
617-366-9011

WMY 79-55

July 3, 1979

United States Nuclear Regulatory Commission
Region 1
631 Park Avenue
King of Prussia, Pennsylvania 19406

Attention: Mr. Boyce H. Grier, Director

References: (1) License No. DPR-36 (Docket No. 50-309)
(2) NRC, Region 1, letter, dated May 22, 1979
(3) IE Bulletin 79-11, dated May 22, 1979

Gentlemen:

Faulty Overcurrent Trip Devices in Westinghouse DB Circuit Breakers

Reference (3) required Maine Yankee to determine if Westinghouse type DB circuit breakers are installed in safety-related Class 1E circuits or in spares.

Maine Yankee has determined that the subject circuit breakers are not used in safety-related Class 1E circuits.

We plan no further action on IE Bulletin 79-11.

We trust that you find this information satisfactory; however, should you require additional information, please contact us.

Very truly yours,

MAINE YANKEE ATOMIC POWER COMPANY

R. H. Groce
Licensing Engineer

PRJ/jgh

499 329

7908080 313