



HELPING BUILD ARKANSAS

ARKANSAS POWER & LIGHT COMPANY

April 23, 1979

1-059-9

G. L. Madsen, Chief
Reactor Operation and Nuclear Support Branch
United States Nuclear Regulatory Commission
Office of Inspection and Enforcements Region IV
611 Ryan Drive, Suite 1000
Arlington, Texas 76011

SUBJECT: Arkansas Nuclear One - Unit 1
Docket #50-313
License #DPR-51
Inspection Report #50-313/78-17

Gentlemen:

The subject inspection report identified one violation of Environmental Technical Specification 2.4.2.3a. Our letter of November 21, 1978, provided our response to this infraction. This response stated:

Corrective steps which will be taken to avoid further violations:

- A. Health Physics technicians will prepare procedures and techniques for independently evaluating air samples. Air sample counting and evaluation tasks are usually performed by Radiochemistry personnel.
- B. A procedure is being prepared that will instruct Health Physics technicians how to access data files stored in the Radiochemistry computer and complete all calculations necessary to perform a reactor building purge.

We wish to revise this response to state:

Corrective steps which will be taken to avoid further violations:

- A. Additional plant personnel will be trained in the use of procedures for determining waste releases.

501 024

7908080456



G. L. Madsen, Chief
April 23, 1979
ANO-1149 Page 2...
1-059-9

- B. Analysis will be conducted by Radiochemistry personnel or other plant personnel trained under the direction of the Radiochemistry Supervisor prior to any waste release.

Very truly yours,



D. Trimble
Manager, Licensing

DT:pm

File: 0232

cc: Mr. W. D. Johnson
U. S. Nuclear Regulatory Commission
P. O. Box 2090
Russellville, AR 72801

501 025