

SWEPCO TUBE CORPORATION

OUR THIRTIETH YEAR

ONE CLIFTON BOULEVARD • CLIFTON, NEW JERSEY 07015

Swepeco®

June 12, 1979

(201) 778-3000

TWX NO. 710-989-7098

TELEX NO. 133321

Mr. Uldis Potapovs, Chief Vendor
Inspection Branch
U. S. Nuclear Regulatory Commission
Office of Inspection & Enforcement, Region IV
611 Ryan Plaza Drive, Suite 1000
Arlington, Texas 76011

Reference: Docket No. 99900026/79-01 Dated May 15, 1979

Dear Mr. Potapovs:

We acknowledge receipt of above subject report and submit the action that will be taken to adjust the two (2) deviations recorded.

Deviation A

To correct this deviation we shall prepare new Welding Procedures that will encompass the range of essential variables as published in Section IX of the ASME Code.

These new Procedures, once incorporated into the system, shall preclude reoccurrence.

These Procedures shall be written and incorporated within a thirty-day period of this date.

Deviation B

The Technicians that were not examined for visual acuity by a physician, but examined by a qualified technician per SNT-TC-1A as evidenced by our May 5, 1978 records, shall be examined by a physician and so certified as defined in our current Quality Assurance Manual.

All future examinations shall be done by a physician to preclude recurrence.

These arrangements shall be made to complete these examinations within three weeks of this date.

Respectfully,

SWEPCO TUBE CORPORATION

J. A. Seme

Vice President, Engineering

JAS:CT

7908090092

MANUFACTURERS OF *Swepeco* CORROSION RESISTANT PIPE AND TUBING