



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
REGION III  
799 ROCSEVELT ROAD  
GLEN ELLYN, ILLINOIS 60137

PDR

JUL 18 1979

Docket No. 50-483

Union Electric Company  
ATTN: Mr. John K. Bryan  
Vice President - Nuclear  
P. O. Box 149  
St. Louis, MO 63166

Gentlemen:

Thank you for your letter dated June 27, 1979, informing us of the steps you have taken to correct the deviation identified in our letter dated May 30, 1979.

Based on our telecon on July 12, 1979, between W. S. Strothman of your staff and E. R. Schweibinz of this office, your FSAR submittal will reflect the Bechtel Specification No. 10466-C151(Q), Paragraph 7.5.7, which requires (1) use only type 1 or 2 radiographic film, and (2) that fluorescent screens shall not be used. Based on this understanding, your response is acceptable and we will examine your corrective action during a future inspection.

Please inform us if your understanding of this item is different from that stated.

Your cooperation with us is appreciated.

Sincerely,

G. Fiorelli, Chief  
Reactor Construction and  
Engineering Support Branch

cc: W. H. Weber, Manager  
Nuclear Construction

cc w/ tr dtd 6/27/79:  
Central Files  
Reproduction Unit NRC 20b  
PDR  
Local PDR  
NSIC  
TIC  
Regions I & IV  
Ms. K. Drey  
Hon. C. J. Frass, Chairman

621 353

7908130111

Q