

TK



Duquesne Light

435 Sixth Avenue
Pittsburgh, Pennsylvania
15219

(412) 456-6000

July 5, 1979

United States Nuclear Regulatory Commission
Attention: Boyce H. Grier, Director
Region I

631 Park Avenue
King of Prussia, Pennsylvania 19406

Reference: Beaver Valley Power Station, Unit No. 1
Docket No. 50-334
License No. DPR-66
Response to IE Bulletin 79-11

Dear Mr. Grier:

We have reviewed IE Bulletin 79-11 which reports a potential failure of overcurrent trip devices in circuit breakers in engineered safety systems.

Our investigation has determined that Westinghouse type DB-50 and DB-75 breakers with overcurrent trip devices are not used in safety related Class 1E service at the Beaver Valley Power Station.

No corrective action is required at this time.

If you have any questions regarding this response, please contact my office.

Very truly yours,

C. N. Dunn
C. N. Dunn
Vice President, Operations

cc: United States Nuclear Regulatory Commission
Office of Inspection and Enforcement
Division of Reactor Operations Inspection
Washington, D. C. 20555

618294

7908130595