



UNITED STATES
NUCLEAR REGULATORY COMMISSION
REGION I
631 PARK AVENUE
KING OF PRUSSIA, PENNSYLVANIA 19406

CENTRAL FILES

Docket Nos. 50-289
50-320

JUL 2 1979

Metropolitan Edison Company
ATTN: Mr. J. G. Herbein
Vice President
P. O. Box 542
Reading, Pennsylvania 19640

Gentlemen:

The enclosed Bulletin 79-14 is forwarded to you for information. No written response is required at this time. If you desire additional information regarding this matter, please contact this office.

Sincerely,


for Boyce H. Grier
Director

Enclosures:

1. IE Bulletin No. 79-14
2. List of IE Bulletins
Issued in Last 12 Months

cc w/encls:

E. G. Wallace, Licensing Manager
J. J. Barton, Project Manager
L. L. Lawyer, Manager - Generation Operations
G. P. Miller, Manager - Generating Station - Nuclear
J. L. Seelinger, Unit 1 Superintendent
W. E. Potts, Unit 1 Superintendent - Technical Support
J. B. Logan, Unit 2 Superintendent
G. A. Kunder, Unit 2 Superintendent - Technical Support
I. R. Finrock, Jr.
Mr. R. Conrad
G. F. Trowbridge, Esquire
Miss Mary V. Southard, Chairman, Citizens for a Safe Environment

620207

7908150747

BQ

ENCLOSURE 1

UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555

IE Bulletin No. 79-14
Date: July 2, 1979
Page 1 of 3

SEISMIC ANALYSES FOR AS-BUILT SAFETY-RELATED PIPING SYSTEMS

Description of Circumstances:

Recently two issues were identified which can cause seismic analysis of safety-related piping systems to yield nonconservative results. One issue involved algebraic summation of loads in some seismic analyses. This was addressed in show cause orders for Beaver Valley, Fitzpatrick, Maine Yankee and Surry. It was also addressed in IE Bulletin 79-07 which was sent to all power reactor licensees.

The other issue involves the accuracy of the information input for seismic analyses. In this regard, several potentially unconservative factors were discovered and subsequently addressed in IE Bulletin 79-02 (pipe supports) and 79-04 (valve weights). During resolution of these concerns, inspection by IE and by licensees of the as-built configuration of several piping systems revealed a number of nonconformances to design documents which could potentially affect the validity of seismic analyses. Nonconformances are identified in Appendix A to this bulletin. Because apparently significant nonconformances to design documents have occurred in a number of plants, this issue is generic.

The staff has determined, where design specifications and drawings are used to obtain input information for seismic analysis of safety-related piping systems, that it is essential for these documents to reflect as-built configurations. Where subsequent use, damage or modifications affect the condition or configuration of safety-related piping systems as described in documents from which seismic analysis input information was obtained, the licensee must consider the need to re-evaluate the seismic analyses to consider the as-built configuration.

Action to be taken by Licensees and Permit Holders:

All power reactor facility licensees and construction permit holders are requested to verify, unless verified to an equivalent degree within the last 12 months, that the seismic analysis applies to the actual configuration of safety-related piping systems. The safety related piping is Seismic Category I systems as de

DUPLICATE DOCUMENT

Entire document previously entered
into system under:

ANO 7907060295

No. of pages: 9 620208