

NOTICE OF VIOLATION

Garco Testing Laboratories
#41 West Central Avenue
Murray, Utah 84107

Docket No. 30-15226
License No. 43-19020-01

As a result of the inspection conducted on November 21, 1980 and in accordance with the attached Interim Enforcement Policy, 45 FR 66754 (October 7, 1980), the following violations were identified:

1. License Condition 13 specifies that sealed sources containing licensed material shall be tested for leakage and/or contamination at intervals not to exceed six months.

Contrary to this requirement, Troxler Gauge Model 3411B, Serial No. 6609 containing 8.6 millicuries Cesium-137 and 40 millicuries Americium-241 was not leak tested between November 16, 1979 and November 21, 1980.

This is a Severity Level V violation.

2. License Condition 15 requires that the sealed sources received and possessed under the license shall be inventoried and records reflecting the quantities and kinds of byproduct material, location, and date of inventory shall be maintained.

Contrary to this requirement, no such records were available at the time of this inspection.

This is a Severity Level VI violation.

3. 10 CFR 30.51 requires that each person who receives byproduct material pursuant to the specific conditions of a license shall keep records showing the receipt of such material.

Contrary to this requirement, no recent records were available for two Troxler Gauges Model No. 2401, Serial No. 2503 and 1518 containing 50 millicuries of Americium-241 and received in 1979 and 1980 respectively.

This is a Severity Level VI violation.

4. 10 CFR 19.11(a)(b) requires that each licensee shall post current copies of specified regulations and the radioactive material license or a notice specifying where such documents may be found and examined.

Contrary to this requirement, current copies of these documents were not posted at the time of this inspection.

This is a Severity Level VI violation.

8102250 499

5. 10 CFR 19.11(c) requires that Form NRC-3 "Notice to Employees," shall be posted by each licensee when individuals work in or frequent any portion of a restricted area.


Contrary to this requirement, such a form was not posted at the time of this inspection.

This is a Severity Level VI violation.

Pursuant to the provisions of 10 CFR 2.201, Garco Testing Laboratories is hereby required to submit to this office within twenty-five days of the date of this Notice, a written statement or explanation in reply, including: (1) the corrective steps which have been taken and the results achieved; (2) corrective steps which will be taken to avoid further violations; and (3) the date when full compliance will be achieved. Under the authority of Section 182 of the Atomic Energy Act of 1954, as amended, this response shall be submitted under oath or affirmation.

Dated

12/4 80



Glen D. Brown, Chief
Fuel Facility and Material
Safety Branch