

SEP 21 1981



MEMORANDUM FOR: James H. Sniezek, Director
 Division of Resident and Regional
 Reactor Inspection, IE

FROM: Darrell G. Eisenhut, Director
 Division of Licensing, NRR

SUBJECT: PROPOSAL FOR IE REVIEW OF SELECTED NUREG-0737
 ITEMS AT OPERATING REACTORS

There are selected items of NUREG-0737 for which licensees are to have design details available and no submittal of review information to NRR is required. Included are the following:

- II.E.4.1 Dedicated Hydrogen Penetrations
- II.F.1.1 Noble Gas Monitor (plants without deviations)
- II.F.1.2 Iodine/Particulate Sampling (plants without deviations)
- II.F.1.3 Containment High Range Monitor (plants without deviations)
- III.D.3.3.2 Improved Inplant Iodine Instrumentation (plants without deviations)

The guidance provided to the licensee by NRR (i.e., NUREG-0737 and 0578) is adequate for IE verification and no further NRR actions are required. For those plants who have proposed deviations to the requirement, NRR will review each request and advise you of any requested deviations and their resolution.

We request your concurrence in this approach for the five items identified above. We will be happy to meet with you and discuss schedules.

Original signed by
 Darrell G. Eisenhut

Darrell G. Eisenhut, Director
 Division of Licensing

- cc: R. Mattson
 D. Eisenhut
 G. Lainas
 T. Novak
 R. Tedesco
 J. Olshinski
 D. Verrelli
 M. Fairtile
 E. Conner

*SEE PREVIOUS PAGE FOR CONCURRENCE

*P&C-1A
 + IDAR-12*

OFFICE	B. Regua	DL:ORAB	DL:ORAB/BC	DL:AD/SA	DSI:DIR	DL:DIR
SURF	B110070420 B10921	DVerrelli	JOlshinski	GLainas	RMattson	DEisenhut
CF	SUBJ	9/1/81	8/20/81	9/9/81	9/10/81	9/16/81
L	P&C-1A CF					

MEMORANDUM FOR: James H. Sniizek, Director
 Division of Resident and Regional
 Regional Inspection, IE

FROM: Darrell G. Eisenhut, Director
 Division of Licensing, NRR

SUBJECT: PROPOSAL FOR IE REVIEW OF SELECTED NUREG-0737
 ITEMS AT OPERATING REACTORS

There are selected items of NUREG-0737 for which licensees are to have design details available and no submittal of review information to NRR is required. Included are the following:

- II.E.4.1 Dedicated Hydrogen Penetrations
- II.F.1.1 Noble Gas Monitor (plants without deviations)
- II.F.1.2 Iodine/Particulate Sampling (plants without deviations)
- II.F.1.3 Containment High Range Monitor (plants without deviations)
- III.D.3.3.2 Improved Inplant Iodine Instrumentation (plants without deviations)

The guidance provided to the licensee by NRR (i.e., NUREG-0737 and 0578) is adequate for IE verification and no further NRR actions are required. For those plants who have proposed deviations to the requirement, NRR will review each request and advise you of any requested deviations and its resolution. For those items that the licensee does not request deviations, OIE will advise us of its acceptability (or unacceptability).

We request your concurrence in this approach for the five items identified above. We will be happy to meet with you and discuss schedules.

Original signed by
 Darrell G. Eisenhut

Darrell G. Eisenhut, Director
 Division of Licensing

- cc: R. Mattson M. Fairfile
 D. Eisenhut E. Conner
 G. Laines B. Requa
 T. Novak
 R. Tedesco
 J. Olshinski
 D. Verrelli

*SEE PREVIOUS PAGE FOR CONCURRENCE

OFFICE	DL:ORAB	DL:ORAB/BC	DL:AD/SA	DS:DIR	DL:DIR
SURNAME	DVerrelli:sh	JOlshinski*	GLaines	RMattson	DEisenhut
DATE	9/1/81	8/20/81	9/9/81	9/16/81	9/15/81

MEMORANDUM FOR: James H. Sniezek, Director
Division of Resident and Regional
Regional Inspection, IE

FROM: Darrell G. Eisenhut, Director
Division of Licensing, NRR

SUBJECT: PROPOSAL FOR IE REVIEW OF SELECTED NUREG-0737
ITEMS AT OPERATING REACTORS

There are selected items of NUREG-0737 for which licensees are to have design details available and no submittal of review information to NRR is required. Included are the following:

II.E.4.1	Dedicated Hydrogen Penetrations
II.F.1.1	Noble Gas Monitor (plants without deviations)
II.F.1.2	Iodine/Particulate Sampling (plants without deviations)
II.F.1.3	Containment High Range Monitor (plants without deviations)
III.D.3.3.2	Improved Inplant Iodine Instrumentation (plants without deviations)

We believe the guidance provided to the licensee by NRR (i.e., NUREG-0737 and 0578) is adequate for IE verification and no further NRR actions are required.

For those plants who have proposed deviations to the requirement, NRR will review each request. We will advise you of any requested deviations and the resolution of the issue.

We request that you advise us by memorandum of the results of the OIE verification relative to the acceptability (or unacceptability) of these licensee actions.

We request your concurrence in this approach for the 5 items identified above. We will be happy to meet with you and discuss schedules.

Darrell G. Eisenhut, Director
Division of Licensing

cc: R. Mattson J. Olshinski
D. Eisenhut D. Verrelli
G. Lainas M. Fairfile
T. Novak E. Conner
R. Tedesco B. Regua

*SEE PREVIOUS PAGE FOR CONCURRENCE

OFFICE	DL:ORAB/BC	DL:AD/SA	DSI:DIR	DL:DIR
SURNAME	JOlshinski*	GLainas*	RMattson	DEisenhut
DATE	8/20/81	8/24/81	8/ /81	8/ /81

MEMORANDUM FOR: James H. Sniezek, Director
 Division of Resident and Regional
 Reactor Inspection, IE

FROM: Darrell G. Eisenhut, Director
 Division of Licensing, NRR

SUBJECT: PROPOSAL FOR IE REVIEW OF SELECTED NUREG-0737
 ITEMS AT OPERATING REACTORS

There are selected items of NUREG-0737 for which licensees are to have design details available and no submittal of review information to NRR is required. Included are the following:

- II.E.4.1 Dedicated Hydrogen Penetrations
- II.F.1.1 Noble Gas Monitor (plants without deviations)
- II.F.1.2 Iodine/Particulate Sampling (plants without deviations)
- II.F.1.3 Containment High Range Monitor (plants without deviations)
- III.D.3.3.2 Improved Inplant Iodine Instrumentation (plants without deviations)

We propose that IE accept review responsibility for these items. Assistance to IE from NRR Technical Review Branches will be made available, as required on a case-by-case basis. We would advise you of any licensee requested deviation to our position and the resolution of any such request.

We believe the guidance provided to the licensee by NRR (i.e., NUREG-0737 and 0578) is adequate for IE review.

In view of the continued interest by the Commission on status of implementation of Action Plan items we believe an SER should be issued on each of these items which documents the acceptability of licensee's completed or planned actions. This is particularly important for those accident monitoring modifications scheduled for installation by January 1, 1982.

We will be happy to meet with you and discuss schedules.

Darrell G. Eisenhut, Director
 Division of Licensing, NRR

cc: R. Mattson
 D. Eisenhut
 G. Lainas
 J. Olshinski
 D. Verrelli
 M. Fairtile
 E. Conner
 B. Regua

*SEE PREVIOUS WHITE FOR CONCURRENCES

OFFICE	DL:ORAB *	DL:ORAB *	DL:AD/SA	DSI:DIR	DL:DIR
SURNAME	DVerrelli:sh	JOlshinski	G. Lainas	RMattson	DEisenhut
DATE	8/20/81	8/20/81	8/24/81	8/ /81	8/ /81

MEMORANDUM FOR: James H. Sniezek, Director
 Division of Resident & Regional
 Reactor Inspection, OI&E

FROM: Darrell G. Eisenhut, Director
 Division of Licensing, NRR

SUBJECT: PROPOSAL FOR OIE REVIEW OF SELECTED NUREG-0737
 ITEMS AT OPERATING REACTORS

There are selected items of NUREG-0737 for which licensees are to have design details available and no submittal of review information to NRR is required. Included are the following:

- II.E.4.1 Dedicated Hydrogen Penetrations
- II.F.1.1 Noble Gas Monitor (plants without deviations)
- II.F.1.2 Iodine/Particulate Sampling (plants without deviations)
- II.F.1.3 Containment High Range Monitor (plants without deviations)
- III.D.3.3.2 Improved Inplant Iodine Instrumentation (plants without deviations)

We propose that OIE accept review responsibility for these items. Assistance to OIE from NRR Technical Review Branches will be made available, as required on a case-by-case basis. We would advise you of any licensee requested deviation to our position and the resolution of any such request.

We believe the guidance provided to the licensee by NRR (i.e., NUREG-0737 and 0578) is adequate for OIE review.

In view of the continued interest by the Commission on status of implementation of Action Plan items we believe a SER should be issued on each of these items which documents the acceptability of licensee's completed or planned actions. This is particularly important for those accident monitoring modifications scheduled for installation by January 1, 1982.

Our schedule for completion of these reviews is 10/81.

Darrell G. Eisenhut
 Division of Licensing

cc: R. Mattson
 D. Eisenhut
 G. Laines

OFFICE	J. Olshinski	DL:ORAB/SL	DL:ORAB/BC	DL:AD/SA	DST:DIR	DL:DIR
SURNAME	D. Verrelli	DVerrelli:sh	JOlshinski	GLaines	RMattson	DEisenhut
DATE	E. Conner	8/2/81	8/7/81	8/ /81	8/ /81	8/ /81
	B. Requa					