

LICENSEE EVENT REPORT

EXHIBIT A

CONTROL BLOCK: \_\_\_\_\_ (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | A | R | A | N | 0 | 2 | 0 | 0 | - | 0 | 0 | 0 | 0 | - | 0 | 0 | 3 | 4 | 1 | 1 | 1 | 1 | 4 | \_\_\_\_\_ (5)  
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40

CON'T  
01 | L | 0 | 5 | 0 | 0 | 0 | 3 | 6 | 8 | 7 | 0 | 5 | 2 | 7 | 7 | 9 | 0 | 6 | 2 | 0 | 7 | 9 | \_\_\_\_\_ (1)  
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)  
02 | During Main Steam Safety Valve testing, Mode 3 operation, the "A"  
03 | Steam Generator pressure indicator, 2PI-1041-4, on the Channel D FPS  
04 | failed high. The low pressure and high Steam Generator differential  
05 | pressure on Channel D were by-passed. The remaining indicators were  
06 | operational. There have been no similar occurrences.  
07 | This occurrence is reportable per T.S. 6.9.1.9 (b).  
08 | \_\_\_\_\_  
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40

09 | I | E | E | I | I | Z | \_\_\_\_\_ (11) (12) (13) (14) (15) (16)  
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40

17 | 7 | 9 | \_\_\_\_\_ (18) (19) (20) (21) (22) (23) (24) (25) (26) (27) (28) (29) (30) (31) (32) (33) (34) (35) (36) (37) (38) (39) (40)  
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)  
10 | Investigation revealed that the electronic portion of the transmitter  
11 | would fail intermittantly. The failure is believed to be caused by a  
12 | heat breakdown of some component. The two electronic cards were replaced  
13 | and will be returned to the manufacturer for analysis. PPS "D" was  
14 | declared operable meeting requirements of Action Statement T.S. Table 3.3-3, #9.  
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40

15 | B | 0 | 0 | 0 | Pwr Escalation | A | NA | \_\_\_\_\_ (28) (29) (30) (31) (32)  
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40

16 | Z | Z | NA | NA | \_\_\_\_\_ (33) (34) (35) (36)  
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40

17 | 0 | 0 | 0 | Z | NA | \_\_\_\_\_ (37) (38) (39)  
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40

18 | 0 | 0 | 0 | NA | \_\_\_\_\_ (40) (41) (42)  
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40

19 | Z | NA | \_\_\_\_\_ (43) (44) (45)  
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40

20 | N | NA | \_\_\_\_\_ (46) (47) (48) (49) (50) (51) (52) (53) (54) (55) (56) (57) (58) (59) (60)  
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40

NAME OF PREPARER: Chris N. Shively  
PHONE: 501/968-2519

7907050107

235 345