



Portland General Electric Company

TERA

TERA

Charles Goodwin, Jr. Assistant Vice President

Docket No. 50-344

April 20, 1979

Mr. R. H. Engelken, Director  
Nuclear Regulatory Commission  
Region V  
Suite 202, Walnut Creek Plaza  
1990 N. California Blvd.  
Walnut Creek, CA 94596



Dear Sir:

Nuclear Regulatory Commission IE Bulletin 79-03 identified certain longitudinal weld defects in ASME SA-312 Type 304 stainless steel piping manufactured by Youngstown Welding and Engineering Company. We have reviewed our initial design piping contract and our subsequent piping procurement documents and found that no ASME SA-312 Type 304 or other pipe manufactured by Youngstown Welding and Engineering Company is presently in use or planned for use in safety-related systems at Trojan. If you have any questions, please contact me.

Sincerely,

C. Goodwin, Jr.  
Assistant Vice President  
Thermal Plant Operation and  
Maintenance

CG/SML/4sb4A26

c: Director  
State of Oregon  
Department of Energy

7907050407

281 108