

JUL 9 1979

DISTRIBUTION
Central Files
NRC PDR
PSB Reading

MEMORANDUM FOR: L. Engle, Project Manager, Light Water Reactors, #1, DPM
FROM: G. Lainas, Chief, Plant Systems Branch, DOR
SUBJECT: TMI-1 RESTART ACTIONS

We have been requested to provide you with any recommended actions we believe necessary for TMI-1 restart. Considering the limited time we have been given to respond to this request, we have only one comment in the area of the containment systems. The containment isolation capability is one of the bulletin items. However, we recommend that the containment purge issue (i.e., justification for containment purging during normal operation) be resolved prior to operation. The licensee has responded to our generic letter and his response should be evaluated and resolved prior to operation.

G. Lainas, Chief
Plant Systems Branch
Division of Operating Reactors

cc: B. Grimes
J. Stolz
E. Adensam
D. Tondi
R. Ferguson

7908150742

OFFICE →	SL-PSB: DCR	C-PSB: DOR			
SURNAME →	EAdensam	GLainas:dn			
DATE →	7/7/79	7/ /79			