

UNITED STATES NUCLEAR REGULATORY COMMISSIONDOCKET NO. 50-219JERSEY CENTRAL POWER & LIGHT COMPANYNOTICE OF ISSUANCE OF AMENDMENT TO PROVISIONAL
OPERATING LICENSE

The U. S. Nuclear Regulatory Commission (the Commission) has issued Amendment No. 39 to Provisional Operating License No. DPR-16, issued to Jersey Central Power & Light Company (the licensee), which revised the Technical Specifications for operation of the Oyster Creek Nuclear Generating Station (the facility) located in Ocean County, New Jersey. The amendment is effective as of its date of issuance.

The amendment: 1) adds a limiting safety system setting for the automatic initiation of the Isolation Condenser, on a reactor low-low water level signal (Section 2.3), 2) revises Table 3.1.1 to reflect the change in 1) above, 3) adds the Assembly Average Power Void Relationship for all fuel types in the reactor (Section 3.10.c), 4) removes Figure 3.10-2 and the reference to Figure 3.10-2 from Section 3.10.A, and 5) removes the word interim from Figure 3.10-9, which was inadvertently included in the title of this Figure during the issuance of License Amendment No. 35, dated May 30, 1979.

The application for amendment complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations. The Commission has made appropriate findings as required by the Act and the Commission's rules and regulations in 10 CFR Chapter I, which are set forth in the license amendment. Prior public notice of this amendment was not required since the amendment does not involve a significant hazards consideration.

695301
7908160 18% P


- 2 -

The Commission has determined that the issuance of this amendment will not result in any significant environmental impact and that pursuant to 10 CFR §51.5(d)(4) an environmental impact statement or negative declaration and environmental impact appraisal need not be prepared in connection with issuance of this amendment.

For further details with respect to this action, see (1) the application for amendment dated May 23, 1979, and the licensee's submittal dated May 19, 1979, (2) Amendment No. 39 to License No. DPR-16, (3) the Commission's related Safety Evaluation, (4) Amendment Nos. 35 and 36 dated May 30, 1979 and the related Safety Evaluations, and (5) the Commission's letter and Safety Evaluation Report dated May 30, 1979. All of these are available for public inspection at the Commission's Public Document Room, 1717 H Street, N. W., Washington, D. C., and at the Ocean County Library, Brick Township Branch, 401 Chambers Bridge Road, Brick Town, New Jersey 08723. A copy of items (2), (3), (4), and (5) may be obtained upon request addressed to the U. S. Nuclear Regulatory Commission, Washington, D. C. 20555, Attention: Director, Division of Operating Reactors.

Dated at Bethesda, Maryland, this 23rd day of July, 1979.

FOR THE NUCLEAR REGULATORY COMMISSION



Dennis L. Ziemann, Chief
Operating Reactors Branch #2
Division of Operating Reactors

695302