



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

FLORIDA POWER CORPORATION
CITY OF ALACHUA
CITY OF BUSHNELL
CITY OF GAINESVILLE
CITY OF KISSIMMEE
CITY OF LEESBURG
CITY OF NEW SMYRNA BEACH AND UTILITIES COMMISSION, CITY OF NEW SMYRNA BEACH
CITY OF OCALA
ORLANDO UTILITIES COMMISSION AND CITY OF ORLANDO
SEBRING UTILITIES COMMISSION
SEMINOLE ELECTRIC COOPERATIVE, INC.
CITY OF TALLAHASSEE

DOCKET NO. 50-302

CRYSTAL RIVER UNIT 3 NUCLEAR GENERATING PLANT

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 22
License No. DPR-72

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Florida Power Corporation, et al (the licensees) dated July 13, 1979, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

756 243
7908170170


2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. DPR-72 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 22, are hereby incorporated in the license. Florida Power Corporation shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of the date of its issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



Robert W. Reid, Chief
Operating Reactors Branch #4
Division of Operating Reactors

Attachment:
Changes to the Technical
Specifications

Date of Issuance: July 23, 1979

ATTACHMENT TO LICENSE AMENDMENT NO. 22

FACILITY OPERATING LICENSE NO. DPR-72

DOCKET NO. 50-302

Replace the following pages of Appendix "A" Technical Specifications with the enclosed page. The revised page is identified by Amendment number and contain vertical lines indicating the area of change. The corresponding overleaf page is also provided to maintain document completeness.

3/4 5-5

756 245

EMERGENCY CORE COOLING SYSTEMS

SURVEILLANCE REQUIREMENTS (Continued)

2. Verifying the correct position of each mechanical position stop for each of the stop check valves listed in Specification 4.5.2.c.
3. Verifying that the flow switches or the throttle valves listed in Specification 4.5.2.d operate properly.
4. A visual inspection of the containment emergency sump which verifies that the subsystem suction inlets are not restricted by debris and that the sump components (trash racks, screens, etc.) show no evidence of structural distress or corrosion.
5. Verifying a total leak rate \leq 6 gallons per hour for the LPI system at:
 - a) Normal operating pressure or a hydrostatic test pressure of $>$ 150 psig for those parts of the system downstream of the pump suction isolation valve, and
 - b) \geq 55 psig for the piping from the containment emergency sump isolation valve to the pump suction isolation valve.
- f. At least once per 18 months, during shutdown, by
 1. Verifying that each automatic valve in the flow path actuates to its correct position on a high pressure or low pressure safety injection test signal, as appropriate.
 2. Verifying that each HPI and LPI pump test starts automatically upon receipt of a high pressure or low pressure safety injection test signal, as appropriate.
- g. Following completion of HPI or LPI system modifications that could have altered system flow characteristics, by performance of a flow balance test during shutdown to confirm the following injection flow rates into the Reactor Coolant System:

HPI System - Single Pump

Single pump flow rate \geq 500 gpm
at 600 psig

While injecting through 4 Injection Legs,
the flow rate for all combinations
of 3 Injection Legs \geq 350 gpm at 600
psig

LPI System - Single Pump

1. Injection Leg A - 2800 to 3100 gpm
2. Injection Leg B - 2800 to 3100 gpm

CRYSTAL RIVER - UNIT 3

3/4 5-5

Amendment No. 22

- ¶ Flow balance tests performed prior to complete installation of modifications are valid if performed with the system change that could alter flow characteristics in effect.

756 240

POOR ORIGINAL

EMERGENCY CORE COOLING SYSTEMS

ECCS SUBSYSTEMS - $T_{avg} < 280^{\circ}\text{F}$

LIMITING CONDITION FOR OPERATION

3.5.3 As a minimum, one ECCS subsystem comprised of the following shall be OPERABLE:

- a. One OPERABLE high pressure injection (HPI) pump,
- b. One OPERABLE low pressure injection (LPI) pump,
- c. One OPERABLE decay heat cooler, and
- d. An OPERABLE flow path capable of taking suction from the borated water storage tank (BWST) and transferring suction to the containment emergency sump.

APPLICABILITY: MODE 4.

ACTION:

- a. With no ECCS subsystem OPERABLE because of the inoperability of either the HPI pump or the flow path from the borated water storage tank, restore at least one ECCS subsystem to OPERABLE status within one hour or be in COLD SHUTDOWN within the next 20 hours.
- b. With no ECCS subsystem OPERABLE because of the inoperability of either the decay heat cooler or LPI pump, restore at least one ECCS subsystem to OPERABLE status or maintain the Reactor Coolant System T_{avg} less than 280°F by use of alternate heat removal methods.
- c. In the event the ECCS is actuated and injects water into the reactor coolant system, a Special Report shall be prepared and submitted to the Commission pursuant to Specification 6.9.2 within 90 days describing the circumstances of the actuation and the total accumulated actuation cycles to date.

SURVEILLANCE REQUIREMENTS

4.5.3 The ECCS subsystems shall be demonstrated OPERABLE per the applicable Surveillance Requirements of 4.5.2.

756 247