



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

GEORGIA POWER COMPANY
OGLETHORPE ELECTRIC MEMBERSHIP CORPORATION
MUNICIPAL ELECTRIC ASSOCIATION OF GEORGIA
CITY OF DALTON, GEORGIA

DOCKET NO. 50-366

EDWIN I. HATCH NUCLEAR PLANT UNIT NO. 2

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 10
License No. NPF-5


1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Georgia Power Company, et al. (the licensee) dated July 23, 1979, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. NPF-5 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 10, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of the date of its issuance.

FOR THE NUCLEAR REGULATORY COMMISSION


Thomas A. Ippolito, Chief
Operating Reactors Branch #3
Division of Operating Reactors

Attachment:
Changes to the Technical
Specifications

Date of Issuance: July 26, 1979

ATTACHMENT TO LICENSE AMENDMENT NO. 10

FACILITY OPERATING LICENSE NO. NPF-5

DOCKET NO. 50-366

Replace the following pages of the Appendix "A" Technical Specifications with the enclosed pages. The revised pages are identified by Amendment number and contain vertical lines indicating the area of change. Overleaf pages are provided for your convenience.

Remove

3/4 6-9
3/4 6/10

Insert

3/4 6-9
3/4 6-10

CONTAINMENT SYSTEMS

PRIMARY CONTAINMENT INTERNAL PRESSURE

LIMITING CONDITION FOR OPERATION

3.6.1.6 Primary containment internal pressure shall not exceed 0.75 psig.* |

APPLICABILITY: CONDITIONS 1, 2 and 3.

ACTION:

With the primary containment internal pressure in excess of the specified limit, restore the internal pressure to within the limit within 1 hour or be in at least HOT SHUTDOWN within the next 12 hours and in COLD SHUTDOWN within the following 24 hours.

SURVEILLANCE REQUIREMENTS

4.6.1.6 The primary containment internal pressure shall be determined to be less than or equal to 0.75 psig at least once per 12 hours.

*Except when performing the test required by Specification 4.6.4.1.b or the Special Startup Test authorized by Amendment No. 2.

698 293

CONTAINMENT SYSTEMS

DRYWELL AVERAGE AIR TEMPERATURE

LIMITING CONDITION FOR OPERATION

3.6.1.7 Drywell average air temperature shall not exceed 135°F*.

APPLICABILITY: CONDITIONS 1, 2 and 3.

ACTION:

With the drywell average air temperature > 135°F*, reduce the average air temperature to within the limit within 8 hours or be in at least HOT SHUTDOWN within the next 12 hours and in COLD SHUTDOWN within the following 24 hours.

SURVEILLANCE REQUIREMENTS

4.6.1.7 The drywell average air temperature shall be the volumetric average of the temperatures at the following drywell elevations and shall be determined to be within the limit at least once per 24 hours:

<u>Elevation</u>	<u>Azimuth</u>
a. 128-130 feet	115° or 255° or 3 5' or 320°
b. 162 feet	90° or 270°
c. 175 feet	90° or 270°
d. 187 feet	90° or 270°

* From July 26, 1979 until the end of the first refueling outage, a limit of 145°F applies.

698 294