

736



Duquesne Light

435 Sixth Avenue
Pittsburgh, Pennsylvania
15219

(412) 471-4300

July 20, 1979

United States Nuclear Regulatory Commission
Region I
631 Park Avenue
King of Prussia, PA 19406

ATTENTION: MR. BOYCE H. GRIER, DIRECTOR

SUBJECT: Beaver Valley Power Station - Unit No. 2
Docket No. 50-412
IE Bulletin 79-11
Westinghouse DB-50 and DB-75 Circuit Breakers

Gentlemen:

We have reviewed IE Bulletin 79-11 which was submitted with your letter dated May 22, 1979 and identified potential problems with time delay dashpots supplied in Westinghouse type DB-50 and DB-75 circuit breakers.

Westinghouse type DB-50 and DB-75 circuit breakers will not be used in Beaver Valley Power Station Unit No. 2.

DUQUESNE LIGHT COMPANY

By E. J. Woolever
E. J. Woolever
Vice President

cc: Dr. V. Stello (15)
Mr. W. G. McDonald

771350

7908200 009

Q