



UNITED STATES
NUCLEAR REGULATORY COMMISSION
REGION II
101 MARIETTA ST., N.W., SUITE 3100
ATLANTA, GEORGIA 30303

AUG 7 1979


In Reply Refer To:
RII:JPO
50-364

Alabama Power Company
Attn: F. [unclear], Jr.
Executive Vice President
Post Office Box 2641
Birmingham, Alabama 35291

Gentlemen:

The enclosed Bulletin 79-18 is forwarded to you for information. No written response is required. If you desire additional information regarding this matter, please contact this office.

Sincerely,


for James P. O'Reilly
Director

Enclosures:

1. IE Bulletin No. 79-18
2. Listing of IE Bulletins
Issued in Last Six Months

845 302

7908220617

Alabama Power Company

cc w/encl:

A. R. Barton
Executive Vice President
Post Office Box 2641
Birmingham, Alabama 35291

J. T. Young
Vice President-Production
Post Office Box 2641
Birmingham, Alabama 35291

C. Biddinger, Jr.
Manager-Corporate Quality Assurance
Post Office Box 2641
Birmingham, Alabama 35291

H. O. Thrash
Manager-Nuclear Generation
Post Office Box 2641
Birmingham, Alabama 35291

H. G. Hairston, III
Plant Manager
Drawer 470
Ashford, Alabama 36312

R. E. Hollands, Jr.
QA Supervisor
Post Office Box U
Ashford, Alabama 36312

845 303

UNITED STATES
NUCLEAR REGULATORY COMMISSION
OFFICE OF INSPECTION AND ENFORCEMENT
WASHINGTON, D.C. 20555

August 7, 1979

IE Bulletin No. 79-18

AUDIBILITY PROBLEMS ENCOUNTERED ON EVACUATION OF PERSONNEL FROM HIGH-NOISE
AREAS

Description of Circumstances:

In January 1979, a number of licensee personnel were engaged in routine activities in the auxiliary building at the Florida Power Corporation, Crystal River Unit 3 nuclear plant. While these individuals were working in the auxiliary building, in a high-noise (fan) area, an unplanned release of radioactive noble gases was detected by building monitors within the auxiliary building at concentrations which caused the licensee to initiate the facility emergency plan auxiliary building evacuation procedure. The facility Emergency Officer (Shift Supervisor) assessed the monitor readings and initiated an auxiliary building evacuation. The evacuation announcement, made over the licensee's PA system, was not heard by the personnel working in the high-noise area. Licensee personnel did evacuate the auxiliary building upon observing that other personnel had left, and after calling the control room to inquire if an evacuation had been initiated. During these occurrences, licensee personnel were not exposed to quantities of radionuclides above regulatory guidance. However, the potential existed for inadvertent unnecessary exposure of individuals to radioactive materials.

Subsequent to the NRC followup inspection of this occurrence, Florida Power Corporation initiated an assessment of this situation and performed an engineering evaluation and identified several plant areas where the annunciator system needed audibility improvement. The licensee has installed a new auxiliary building evacuation tone signal and may add visual alarm indicators in areas of very high-noise.

Action to be Taken by the Licensees:

For all power reactor facilities with an operating license:

1. Determine whether current alarm systems and evacuation announcement systems are clearly audible or visible throughout all plant areas with emphasis on high-noise areas. Determination in high noise areas must be made with the maximum anticipated

DUPLICATE DOCUMENT

845 304

Entire document previously entered
into system under:

ANO

7908030403

No. of pages:

5