

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION

1 In the Matter of:

2 IE TMI INVESTIGATION INTERVIEW

3 of Met Ed Training Staff

4 Richard Zechman
5 Training Supervisor

6 Nelson Brown
7 Nuclear and Technical Training

8 Denny Boltz
9 Nuclear and Technical Training

10 Marshall Beers
11 Group Supervisor
12 Nuclear and Technical Training

Trailer #203
NRC Investigation Site
TMI Nuclear Power Plant
Middletown, Pennsylvania

13 May 8, 1979
14 (Date of Interview)

15 July 2, 1979
16 (Date Transcript Typed)

17 177 and 178
18 (Tape Number(s))

19
20
21 NRC PERSONNEL:

22 Bob Marsh
23 Don Kirkpatrick
24
25

7908280674

681 044

1 MARSH: The date is May 8, 1979, time is 5:17 p.m. We are located at Three
2 Mile Island in Trailer 203, and I am Bob Marsh. I am an investigator with
3 the US Nuclear Regulatory Commission assigned to Region III, Chicago,
4 Illinois. The purpose of today's meeting is to conduct an interview of
5 representatives from the Met Ed Training Staff, and at this time I would
6 like each of the individuals in the room going from my left around the
7 table to identify themselves, spell their last name, and indicate their
8 position so we can start.

9
10 ZECHMAN: My name is Richard Zechman and the Training Supervisor of the Met
11 Ed Company.

12
13 BROWN: My name is Nelson Brown, I am administrator of Nuclear and Technical
14 Training.

15
16 BOLTZ: My name is Denny Boltz, Administrator of Nuclear and Technical
17 Training.

18
19 KIRKPATRICK: I am Don Kirkpatrick, I am a nuclear engineer with USNRC, IE
20 Headquarters.

21
22 BEERS: I am Marshall Beers, Group Supervisor of Nuclear and Technical
23 Training.
24
25

1 MARSH: Fine, thank you, before we start Mr. Boltz, may I get you to sit up
2 on the end of the table on this side, and we will turn that end mike this
3 direction if we may, and that may give us a little better pickup. I think
4 that will give us a little better pickup on the tape. Okay, Don, I think
5 you've got a few words you want to say regarding the scope. Before we do
6 that I just want to put one other thing on the record. Prior to starting
7 the tape we had a few words regarding this two page memo, which I have
8 provided each individual in the room. Pause for a second for the airplane.
9 This two page memo lays down the purpose for this investigation, a little
10 bit about its scope and the authority under which it's being conducted. At
11 the conclusion of this two page memo are three questions which I would like
12 each individual to respond to. I'll read the questions and then if you
13 would, give me your last name and your response to the questions so we also
14 have it on the tape. Question No. 1 reads, "Do you understand the above,
15 making reference to the two page memo?"

16
17 ZECHMAN: Yes.

18
19 BROWN: Yes.

20
21 BOLTZ: Yes.

22
23 BEERS: Yes.
24
25

1 MARSH: The second question reads, "Do we have your permission to tape this
2 interview?"

3
4 ZECHMAN: Yes.

5
6 BROWN: Yes.

7
8 BOLTZ: Yes.

9
10 BEERS: Yes.

11
12 MARSH: And the third question reads, "Do you want a copy of the tape?"

13
14 ZECHMAN: Yes.

15
16 BROWN: No.

17
18 BOLTZ: No.

19
20 BEERS: No.

21
22 MARSH: Fine, at the conclusion of this interview I will then duplicate a
23 copy of the tape, and you can have it today before you leave. There is a
24 fourth question, which is not called out specifically at the end of that
25 two page letter, but is covered in the body of it. This addresses your

681 047

1 rights to have, if you so choose, a representative from the company or your
2 union present right now. Could I get a response of your desires on that.

3
4 ZECHMAN: No.

5
6 BROWN: No.

7
8 BOLTZ: No.

9
10 BEERS: No.

11
12 MARSH: Okay, thank you. One other point on that, if at any time during
13 the course of this interview, you feel that you do want to have someone
14 present, do not hesitate to raise your hand and make the statement, we'll
15 take a break and we'll get someone here. Likewise, if you want to take a
16 break, you get tired or that, just call out and we'll break the tape, and
17 give you a few minutes for a break. Don Kirkpatrick, at this point I am
18 going to turn it over to you for your statement. And I think I will termi-
19 nate this air conditioner and see if we cut down on this background noise.

20
21 KIRKPATRICK: We have already discussed the overall training program with
22 you gentlemen and since there is a great deal of documentation that we have
23 ready access to that gives this training program in detail, I see no point
24 in taping it here at this time. Instead, what this session is intended to
25 do is to answer specific questions regarding the training that is relative

1 to the incidents that occurred during the events on March 28. In addition
2 to that, I have some questions regarding the emergency response training
3 that I will address after this. The first question regards auxiliary
4 feedwater operation. Does the emergency training for loss of feedwater
5 address the verification of auxiliary feedwater flows?

6
7 BROWN: Are we supposed to answer now, or are we suppose to wait 'til you
8 have gone through your scope, or are done with the scope?

9
10 KIRKPATRICK: I am done, so go ahead.

11
12 BROWN: Yea. There is the procedural guidance for the verification of
13 emergency feedwater. It is covered, and says that on the loss of feedwater,
14 normal feedwater, that the emergency feedwater pumps will start. That is,
15 one steam-driven emergency feedwater pump, and two motor-driven emergency
16 feedwater pumps, and the emergency control valves, nomenclature EF standing
17 for Emergency Feedwater, 11A and B, will automatically control the steam
18 generator level. In the loss of both main feedwater pumps, they will
19 control at 30 inches. This is addressed in the emergency procedure.
20 Additionally this is documented, we document it by training on that in
21 emergency procedure review, plus we teach it in-house, we talk about operat-
22 ing characteristics, and it is reviewed at the simulator, when we go over
23 loss of feedwater.
24
25

1 BOLTZ: It is also covered in our in-house ICS course as well, ICS meaning
2 Integrated Control System.

3
4 KIRKPATRICK: What made the auxiliary feedwater flow indication exist in
5 the control room.

6
7 BOLTZ: There is no flow indication for emergency feedwater in the control
8 room. The procedures on loss of feedwater, which is what these fellows
9 were going through, ask you to verify the pumps are operating correctly.
10 What the operator is supposed to look at is the RPMs of the turbine-driven
11 feed pump, and the discharge structure. There is no flow indication there.
12 He has to wait until he gets down to 30 inches on the steam generator
13 levels, to see that the levels are held up by the initiation of emergency
14 feedwater flow. So, in fact, until they hit 30 inches steaming down follow-
15 ing a trip, there will be no emergency feedwater flow. Yea, the pumps will
16 be on reset.

17
18 KIRKPATRICK: Are the operators trained to look for steam generator level
19 rise or indication?

20
21 BOLTZ: They are trained to look at the steam valve. Okay, the level
22 decrease in the steam generators, which appears following the trip. They
23 are trained to verify that it does level out 30 inches on a startup range
24 level entrance.
25

1 KIRKPATRICK: I see.

2
3 BEERS: On a normal reactor or turbine trip, it would take about three
4 minutes for the steam generators to steam down to the 30 inch level. I
5 believe in this incident here the time to steam down to 30 inch was approxi-
6 mately one third that time, as near as we can determine from heresay when
7 we talked to other people.

8
9 KIRKPATRICK: The next question pertains to the electromatic release valve
10 operation. As you know, we believe the relief valve came open during the
11 event and stayed open for a long time afterwards. Are the operators trained
12 to verify closure of the electromatic release valve following events which
13 can be expected to result in its operation.

14
15 BROWN: Yes, they are, and with this loss of main feedwater and then not
16 having auxiliary emergency feedwater immediately there, the pressure would
17 have stayed up for some time period, and it would have--they wouldn't have
18 looked at it right away. And once it, the pressure, would decrease below
19 the point at which this electromatic relief valve was suppose to reclose,
20 which is 2205, then everything they really had to look at that's concrete
21 on that night and really concrete, is the indication on the console, which
22 is only an indication of the demand signal to the actuator, not the actual
23 valve position. And that's what they would have to look at for that. For
24 additional information they would have to look at to verify it would be
25 closed would be discharge line temperature. If they waited for, to try and

1 see it on the alarm printer, the alarm printer is relatively slow, and
2 following a reactor trip or turbine trip, the computer tends to get backed
3 up and alarms that would happen in the first five minutes tend not to get
4 printed out for 20 or 30 as a rule of thumb, sometimes longer, sometime
5 less. And they could request that information, but that takes time and the
6 first couple minutes of an accident you really don't have time to go play
7 with the computer and request information. At this rate, the operator can
8 look at the RC drain tank level pressure and temperature but unfortunately
9 in Unit 2 that is not easily accessible. It's on a back panel out of sight
10 of the normal controls.

11
12 KIRKPATRICK: You mention the fact that the operator can look at the tempera-
13 ture for electromatic relief valve operation. I understand that one of the
14 reasons for the reactor coolant drain tank or one of the purposes of the
15 reactor coolant drain tank is to handle leakage from the electromatic
16 relief valve during normal operations. Now, if the electromatic relief
17 valve were leaking, would the temperatures that you would expect to get be
18 similar to what you might expect following the relief valve opening.

19
20 BOLTZ: I would say, yes, that's true. From my understanding, the electro-
21 matic relief valve was leaking at the time, prior to the incident, because
22 the fellows had to makeup somewhere over a thousand gallons each shift to
23 hold the makeup tank level within the operating band, so that at the start
24 of the incident here, they would have had higher than what you would call
25 normal relief valve discharge temperatures.

681 052

1 BEERS: Under these conditions, it is difficult to determine what is a high
2 temperature on the downstream side of the electromatic relief. Even if the
3 code reliefs were leaking, it would be possible that you would get some
4 transition of feed back up the pipe that the electromatic relief valve
5 discharges into, and make that pipe also appear hot.

6
7 KIRKPATRICK: Okay, thank you. You also mentioned the reactor coolant
8 drain tank pressurize. Does the operator training include actions that
9 have to be taken if there is a pressure increase in the reactor coolant
10 drain tank.

11
12 BROWN: Under normal conditions, yes. Additional things go into the RC
13 drain tank, the relief valve discharge, valve packing lead offs go into
14 there, and for an example, and these valve packing technically could also
15 cause level and pressure in this tank to increase and with those conditions
16 it's relatively slow and the operator does have time to respond, which
17 could be turning on additional coolers for that tank, turning on sooner,
18 could be lowering levels slightly, still keeping the sparging line covered,
19 and putting in cold demineralized water to help bring the pressure and
20 temperature back down, but those are relatively long time operation.

21
22 BOLTZ: They do have a response to alarm procedure for drain tank pressure,
23 high alarm, which is received in the control room as well as high and low
24 level.
25

1 BEERS: You might indicate where that alarm is, so

2
3 BOLTZ: Again, it is out of sight from the console. It is back where the
4 level and pressure indicators are for the drain tank.

5
6 KIRKPATRICK: If the operator did observe abnormal indications of pressure
7 and level in the drain tank, would he be able to distinguish what source it
8 came from, based on his training.

9
10 BOLTZ: Based on his training he would be able to, but not necessarily
11 instantaneously. It's...you've got so many sources of water at high tempera-
12 ture that can come in to this tank, that it could take some time to actually
13 get down to the actual source by process of elimination.

14
15 KIRKPATRICK: Thank you. During the incident, the reactor coolant pressure
16 decreased rapidly to the saturation level and apparently stayed there for a
17 good while. Does operator training address the significance of the satura-
18 tion pressure?

19
20 BOLTZ: I would say, yes, it does in the basic thermodynamics that we teach
21 the AOs, and what we pick up in our CRO training program, under heat transfer
22 characteristics.

23
24 KIRKPATRICK: Should the operator...assuming he had knowledge that satura-
25 tion pressure existed, would that mean to him that the possibility of
steaming voiding in the primary system other than the pressurizer.

1 BOLTZ: Yes. I am sure that the way it is put out by the training depart-
2 ment, that it would have meant that. A good example of the way this is
3 covered, we have a variable low pressure trip for the reactor, based on the
4 actual value of the coolant outlet temperature from the vessel. As the
5 outlet temperature increases, the low pressure trip, set point is automa-
6 tically increased, and it is put out to everybody the reasons behind all
7 the reactor trips including this one here, and they can all tell you it's
8 DNBR consideration, a minimum value of 1.3.

9
10 MARSH: DNBR?

11
12 BOLTZ: Departure from Nucleate Boiling Ratio, DNBR.

13
14 KIRKPATRICK: Would you expect, based on operator's training in emergency
15 procedures, that they would indeed check for this condition, assuming that
16 the pressure was lower than they expected.

17
18 BROWN: With the conditions that happened from hearsay that I can put
19 together, I would say not immediately. Primarily, the electromatic was
20 open. They knew it was open because the pressure was up, and then they
21 didn't have any feedwater in there so the whole system got very hot as
22 well. When they did establish the emergency feedwater, the emergency
23 feedwater comes in at something less than 90 degrees or thereabouts, 90 to
24 100 degrees, which is very cold compared to the reactor coolant system,
25 which with a lot of heat removal capability, which is going to cause the

1 system to shrink and depressurize. Additionally, because of the rapid
2 depressurization where they had the steam generators very hot, because they
3 didn't have that feedwater, emergency feedwater, the actuation of the high
4 pressure injection, the safeguards actuation system, also puts cold water
5 into the system. So coming from the boiling water storage tank, that is
6 again about 90 degrees, a lot of heat removal, so those two methods of heat
7 removal plus the pressurizer spray valve sticking open, that's where your
8 electromatic relief valve sticking open would cause that pressure to go
9 down rather far and stay down for a little while 'til they could recover
10 from that. So I think that would help--a little bit of Monday morning
11 quarterback, I guess--but that would help to explain why you wouldn't take
12 action immediately, because you did have a number of sources in there that
13 were causing a large amount of heat removal.

14
15 BOLTZ: I would like to add one point to that. In the incident that occurred
16 here on March 28 the temperatures and pressures that we're talking about
17 that would concurrent with each other, this is the first time in my knowledge
18 that a B&W plant has had a reactor trip and had elevated core outlet tempera-
19 tures like we've seen through the complete loss of cooling water on the
20 secondary side. So, if you're saying, would he have verified for a steam
21 bubble in the core with this pressure, normally he would not because normally
22 he would not be experiencing these cooling temperatures that he saw. He
23 would not have to worry about a steam bubble.
24
25

1 KIRKPATRICK: Would you expect to find a set of steam tables in the control
2 room.

3
4 BOLTZ: We have no requirement to have steam tables in the control room,
5 and I haven't gotten upstairs to verify whether there are some there or not
6 since we talked about this previously. Myself, as a Unit 1 shift foreman
7 previously, we had tables in the shift foreman's desk, but not readily
8 available to an operator at the console, and there was no requirement to
9 have them there.

10
11 KIRKPATRICK: I believe he has no instrument to tell him that he's...

12
13 BOLTZ: Below saturation pressure?

14
15 KIRKPATRICK: Right.

16
17 BOLTZ: That's true.

18
19 BROWN: As far as relationship of hot leg, or core exit temperatures and
20 saturation temperature, the only place that it is addressed where they
21 could have somewhat access to it, limited access, is in the station blackout
22 procedure when the discussion goes into natural circulation coolant, but
23 the situations at hand, they were not in a station blackout, they didn't
24 lose all the power so they wouldn't have been keyed to look in there, and
25 there was enough other things going on that personally I don't feel they

1 would have thought about looking in there to see, you know, where they were
2 in relationship to those temperatures.

3
4 KIRKPATRICK: What are the operators trained to do in case of low reactor
5 pressure, lower than normal reactor pressures?

6
7 BOLTZ: What they are trained to do, and you'll find procedures, what I am
8 referring to, is pressurizer system failure, 2202-1.5 where they cover
9 cases of a leaking electromatic relief valve, one which is stuck open,
10 pressurizer spray valve which is stuck open, and they are taught that ways
11 of bringing pressure back, it would be like isolating letdown, throwing the
12 pressurizer heaters to manual to get them to full output early rather than
13 waiting for the pressure to decrease to the automatic setpoint, and possibly
14 increasing pressurizer level.

15
16 BEERS: All right, in the normal reactor trip procedure, they give various
17 actions of turning on an extra make-up pump, opening a high pressure injec-
18 tion valve to try and bring the level up and the secondary part of that
19 would bring the pressure back up.

20
21 KIRKPATRICK: All right. Now, if you had the high pressurizer level, what
22 would his procedure require him to do.

23
24 BOLTZ: We have administrative requirements and tech spec requirements on
25 maximum pressurizer level. Technical specifications say that pressurizer

1 levels shall not go above 385 inches, okay, while the reactor is critical.
2 Obviously we weren't critical in this incident. We had just shut down, but
3 this is a loss of coolant consideration for the peak containment pressure
4 following a LOCA, for the maximum RCS inventory that would flash to steam.
5 So, we had that limit there. In addition, the plant operating procedures,
6 we have the B&W limits precautions, a statement that says, "Thou shall not
7 go solid at any time in the pressurizer, except for hydrostatic testing."
8 And the consideration is over pressurization of the reactor coolant system,
9 and the possibility of exceeding the safety limit of 2750 pounds in the
10 coolant system by going solid and going against the discharge in the make-
11 up pumps.

12
13 KIRKPATRICK: What did that discharge do?

14
15 BOLTZ: It depends on the flow out of the pump. Deadhead on the pumps is
16 going to be somewhere around 2900 pounds.

17
18 KIRKPATRICK: Well, now, if the operator had any indication of high pressur-
19 izer level and at the same time he had an indication of low pressurizer
20 pressure, based on his training and experience, what would you expect that
21 he...which action would he take?

22
23 BOLTZ: Based on the training and the materials, and the operating philoso-
24 phies, that is presented to Met Ed, to the training department by B&W, he
25 would have reacted to the high pressurizer level, again trying to avoid

1 going solid and overpressurization of the system, the action not going
2 against low pressure. Like I say, they were shut down. Normally when you
3 are shutdown, you don't have to worry about DNBR considerations or anything
4 like that. The core is shut down ahead of time, so normal procedures, if
5 you want to call a trip normal, he would respond directly to the high
6 pressurizer level, like I say, a normally coolant temperature or lower.

7
8 KIRKPATRICK: All right. The initial pressurizer level rise appears to be
9 caused by relief valve venting and lowering the pressurizer pressure below
10 the saturation pressure in the core. Now it seems that flashing in the
11 core may have raised the pressure from the main part of the primary system
12 above the pressurizer pressure, thereby forcing water up into the pressurizer
13 from the partially voided system. Has the possibility of this ever occurred?
14 Of this set of conditions that I described, ever occurring and brought to
15 the attention of the operators?

16
17 BOLTZ: Never.

18
19 BROWN: The only thing that is ever discussed and it was discussed in the
20 reactor trip procedure, is that following a reactor trip if you do not
21 maintain your pressurizer level, you can get a pressurizer steam bubble
22 into the hot leg which is one of the main reasons why they told them,
23 "Start one make-up pump, start the second make-up pump,"--well, you already
24 have one running--"start the second make-up pump," which is one of your
25 first actions, and when you start you end up having three make-up pumps

1 running following a reactor trip to maintain pressurizer level, so that you
2 don't get that pressurizer steam bubble down into the hot leg. That's so
3 in case voiding occurs in that leg, it will be swept out by the pump.
4

5 KIRKPATRICK: That's right?

6
7 BROWN: I am not sure I understand that question.
8

9 BEERS: You want to maintain the pressurizer level, some level in the
10 pressurizer so that this can never occur--to get voids in the hot legs.
11

12 KIRKPATRICK: You say that the procedure...
13

14 BEERS: Not a voids, but the steam bubble getting into the hot legs. The
15 reason it can happen, is because you are going from your normal average
16 temperature of 582 down to an average temperature of 555 following a reactor
17 trip and the amount of shrink in the system, you have to start additional
18 make-up pump and get more water in there to compensate for that shrink
19 because of the change in density. So that's what we key them to--it is
20 very important to get another make-up pump on early to keep the pressurizer
21 level, so that that doesn't happen.
22

23 KIRKPATRICK: The question I ask, I misunderstood your answer, I was referring
24 to the primary coolant pump.
25

1 BOLTZ: The big consideration on the minimum pressurizer level, and the
2 actions given in the reactor trip emergency procedure, is that the reactor
3 is shut down, and you have to have a means of positive identification of
4 coolant system water inventory to make sure the core is covered. It never
5 addresses the steam bubble formation in that core. When you are shut down,
6 it assumes you have cooling. The core is shut down, there is heat generated,
7 but you've got positive identification that the core is covered if you have
8 pressurizer level indication.

9
10 KIRKPATRICK: But in general the possibility of voiding in the primary
11 system, has that been addressed in TMI or B&W training?

12
13 BEERS: Void coefficients were addressed to some degree in Unit 1, but it
14 was never much of a consideration. It was never a consideration under
15 these conditions.

16
17 BOLTZ: The only procedure that I know of on either unit that addresses
18 boiling in the hot legs, the core exit, is the, for Unit 2, station blackout
19 with loss of both diesel generators, where you're cooling the plant down by
20 natural circulation, no cooling pumps running, and your doing it with the
21 steam-driven emergency feed pump. In this procedure, they give a table
22 which states saturation temperature for a given reactor coolant system
23 pressure and a maximum T_{hot} , they allow you to control in the cooling
24 system, and I quote "To prevent hot leg boiling," and primary shrinkage
25 assuming an initial T_{out} of 582. It has two parts in this thing. It says

1 you can go down so far with no make-up pumps running and maintain your
2 minimum pressurizer level inventory, ensuring that you know the core is
3 covered, and it also says - this is your saturation temperature for this
4 given pressure, okay? Don't take T_{hot} any higher than within 30 degrees
5 below this T-set. It is the only procedure I know of that addresses hot
6 leg boiling. Again it is for a cooldown, on a steam-driven pump, during
7 blackout conditions, and no

8
9 MARSH: Can you reference the document you are citing from?

10
11 BOLTZ: Yea, the procedure number is 2202-2.5, Revision 6, dated 9/22/78;
12 the table is on page 6.

13
14 KIRKPATRICK: Thank you. The B&W analysis of loss of feedwater transient,
15 Davis-Besey, indicates that this first voiding would occur in the primary
16 system in the case of the loss of offsite power transient. Has this possi-
17 bility ever been discussed with the operators?

18
19 BROWN: No. We do review all of the licensee event reports that come from
20 the computer printout from the NRC. I forget the division it is coming
21 from. And I have a copy in front of me of the December 9, 1977 LER output
22 on PWR events that were processed by this publication of communications for
23 the NRC during November for power reactors. And this particular information
24 is on page 39. This computer sheet was handed out to the operators to
25 review. It was not picked out. I personally review these to go over them

1 in training when it is my turn to go over then. And the information that
2 was in here was not enough to say that was something important to go over.
3 There was not any information published by the NRC in the current events or
4 operating history information, which comes out with the detailed information,
5 nor was there anything prefaced on this by B&W, prior to March 28. The
6 information that has three columns in it or four columns, it has a cause
7 code, cause subcode, facility component, component subcode, system discoverer
8 or manufacturer, that's one column, the next column is docket number/LER
9 number, which is licensee event report/ control number. Then the next
10 column is event date, report date, report type, and the last section is
11 reactor status, event description, cause description, with percent power.
12 All right, this particular event where Davis-Besey had boiling in their
13 core as well, which last week we got the information from Davis-Besey,
14 by phone call. They sent us a copy of their licensee event report, which
15 is 50 pages long. It has in here under the first section: cause code,
16 other non-applicable, Davis-Besey 1, implementation and controls, other
17 instrumentation system required for safety, operational vent, Consolidated
18 Controls Corporation, then under the docket it gives the Davis-Besey docket
19 number, the LER number and the event report date was 9/24/77, report date
20 was 10/7/77, and it was a two-week report. The reactor status event descrip-
21 tion says routine shutdown operations, they were initially at 9 percent
22 power. Half trip of steam and feedwater rupture control system caused rise
23 in reactor coolant system temperature and pressure. Caused pressurizer
24 power relief valve to open, and valve failed to close causing reduction in
25 RCS pressure, LCOs, limiting conditions for operation, were exceeded for 5

681 064

1 tech specs, and they give the numbers of them. Now, they are under standard
2 tech specs as is Unit 2, and personally I didn't take the time to look up
3 all those references. If there was something that was a little more impor-
4 tant, I figured it would be referenced. And then the cause description at
5 the bottom it says - after condition from SFRCs--I am not sure what that
6 definition stands for--safety features, reactor coolant system I guess, I
7 am not sure--channel 2 which caused valve, and they give a feedwater valve
8 number FWSP7A, to quote "Cause of this half trip has not been positively
9 determined although extensive investigation has revealed loose connections
10 at terminal boards (possible cause)". The information there was not signi-
11 ficant--why do I want to go over with an operator that they had an LER on a
12 loose terminal board that caused a half actuation, although the 50 page
13 report on the second page of the summary, then says, and I quote, "The
14 depressurization of the primary system resulted in steam formation in the
15 primary system, but the evaluation has shown there was no appreciable
16 boiling in the core." And that is the first time in any report that I have
17 ever seen where B&W, or any place else, other than a boiling water reactor,
18 discussed boiling in the core.

19
20 KIRKPATRICK: I thank you. Are you normally provided with this type of
21 information by B&W?

22
23 ZECHMAN: Normally we are. Normally if information of that...if that
24 information was very important, normally we receive two places: 1) through
25 communications of the engineering departments between B&W and Met Ed; and

1 2) immediately it appears on the simulator trainer during recall or some-
2 thing of this sort; and 3) if it is important, we also find it on operator
3 licensing exams. If its a major problem, it becomes a favorite exam question,
4 and casually an operator will be passed on his oral. And we have not seen
5 any, I don't think any questions that anybody related to us indicated any
6 discussions of this sort either from B&W, NRC or NRC licensing exam.

7
8 BROWN: Also, if it is something that is important, that could be generic
9 in all of the B&W plants, the B&W has a user's meeting and they also have a
10 user's memo system where if something important comes out between meetings
11 that they identify to all the operating plants, "Hey, this is something you
12 ought to look at." And there was nothing in there either, to our knowledge.
13 Nothing came out of that that got down to the training department to train
14 the operators.

15
16 BOLTZ: In addition all the plants have tech specs. I know this for a
17 fact, all the plants do, which requires immediate notification of the NRC
18 on any item which is found not to be reviewed by the safety analysis, any
19 transient the plant has gone through that is not being considered in the
20 safety analysis or any problem which may look to be a generic problem in
21 all similar facilities. And like I say and like Skip says, this thing at
22 Davis-Besey was never treated that way, even though it is turning out to be
23 that one.
24
25

681 066

1 KIRKPATRICK: Do you think it would be helpful if NRC promptly disseminated
2 this information to other licensees?

3
4 BOLTZ: Yes I do, but I am not sure even the NRC understood the gravity of
5 what happened at Davis-Besey, because it never came to us in NRC examinations
6 or any kind of communications with NRC.

7
8 BROWN: The communications division at NRC, I don't know how large it is,
9 like I said, this is a computer sheet that I have read off earlier that was
10 on page 39. Some of these reports, they go in to the components and causes,
11 plus they also go into things that are classified as operator error, which
12 could be a maintenance man or janitor or a licensed operator. Sometimes it
13 says, just plain operator error, and they don't--or personnel error--and
14 they don't really identify whether it was an operator or maintenance man or
15 what. But we get these reports monthly in a computerized form, and they
16 run somewhere in the order of close to 60 pages every month computerized
17 with three events per page, that's how many were processed due to communi-
18 cation. Now for that to get put out in even more detail, they would have
19 to see...they would pick off just this one here with this loose terminal
20 board that I quoted before, and use additional summary statements that
21 would require somebody to fully review every licensee event report, for in-
22 communication, to see here if it is a generic item or if it is of major
23 importance item. And that to me, when they are processing that many reports
24 every year, and you run them to standard tech specs with Unit 2 as far as
25 the number of things would have to be reported, under standard tech specs,

481 067

1 I called a couple of plants that were under standard tech specs before, and
2 they were running about a 100 to 110, give or take a few, licensee event
3 reports per year and there are 70 reactors and some reactors run 30 some
4 run 110, some might go 150 events per year. That's quite a lot of number
5 of events, and this computer printout gives you the prompt notification,
6 which is the two week written followup, it gives the 30 day written followup,
7 plus any revisions that may come in which may be six months, nine months,
8 or even longer until a revision or a followup report is generated to give
9 all the specific details. It is optimistic to say, yea, the NRC or somebody
10 ought to jump on it, but that volume of information, and this one I have
11 quoted before, this LER from Davis-Besey, which was 50 pages in length. A
12 hundred of those a month times 50 pages, the guy's going to go crazy reading
13 that.

14
15 MARSH: Do you feel some type of prioritizing would be in order for that.
16 Some type of a code or more definitive code or more information in the code
17 as to the importance of the event, the LER.

18
19 BROWN: The identification numbers do prioritize it--whether, where it was
20 on, whether it is a safety system or not, but some of the accidents on the
21 safety system that are reported are like this, the one I quoted where there
22 was a loose terminal board is what started the whole thing off. That is
23 not in itself, isn't anything to be overly excited about. That happens at
24 different times everywhere, a little electrical connector decides to work
25 itself loose.

681 068

1 KIRKPATRICK: ...do you feel that maybe that prioritization that they have
2 now should be refined even further.

3
4 BROWN: The volume is what really indicates that the initial cause doesn't
5 look like much, but the final results of what really would dictate in the
6 summary. And that may not be available for six months until all the inves-
7 tigation, analyses, and everything are done. One of the things that, I
8 forget which one it is right now, one of the standard tech specs says that
9 if certain parameters are exceeded, they've got to go through a whole re-
10 analysis of 5 or 6 different events, to be verified that everything is
11 still okay with that in mind, and 'til those things are done it can take
12 quite a while.

13
14 BEERS: Perhaps there needs to be some method of going back and looking at
15 some of these reports--the final report. You have to have an initial
16 report and a final report on these events. Perhaps on this Davis-Besey
17 incident, when the initial report was put in, maybe they didn't realize the
18 gravity of it at that time, and then it never was picked up again on the
19 final report. I don't know whether there was any method in the communica-
20 tions division of NRC to pick up this type of thing.

21
22 BROWN: The coding systems for identifying an LER is in itself defined in a
23 Reg Guide, and for example this one that I read off there its identification
24 number was 77-016/01T-0. That meant it was 1977, it was the 16th report,
25 it was a 01--means it was a prompt report--defined under the conditions of

1 a required prompt report, if my memory serves me correct. There is ten
2 items there, the T signifies that it was 10 over 14 day written report and
3 the zero means that that's the revision that it was. That's an awful lot
4 of numbers to remember when you are trying to sort through these and say,
5 now gee, where did this come from and what was it? This coding system
6 after the 77-016 which is the year and the event number, to break down the
7 code it goes anywhere from zero 1 through 99 that uses P, T, L, W and X and
8 then you can have any number of revisions on the bottom of it. It gets to
9 be quite lengthy as you are trying to break it down, and it still doesn't
10 really, it goes into a lot more for licensee event reports on environmental
11 incident and for overexposures and that type of thing.

12
13 KIRKPATRICK: I would like to get on with a different subject now. I noted
14 during the incident that the operators were very quick to bypass the ECCS
15 after it was initiated, even though they may not have found it necessary to
16 reduce flow until sometime later. Are the operators trained to do this?

17
18 MARSH: Before you begin to answer I am going to break for a second and
19 reverse this tape. Time being 6:02 and I am reading 710 on the meter.

20
21 MARSH: The time is still 6:03 and we have resumed. Don, you just read the
22 question, still on your mind to go ahead and answer it.

23
24 BOLTZ: Yes. The reason the operators, they are in fact trained to bypass
25 SFAS actuation following depressurization of the coolant system to do a

1 number of things. Unit 2 has automatic opening of the sodium hydroxide
2 tank outlet valves into the high pressure injection system which injects
3 caustic into reactor coolant system. It's happened in the past and the
4 only way to get these valves to reclose following opening up, which follows
5 the actuation of the safety features actuation system, SFAS, is to bypass
6 the actuation to allow closure by the operator. And he would be doing this
7 even though he would not need to, at the time, throttle back on high pressure
8 injection flow. I might add that if the pressurizer level is high following
9 SFAS actuation, the procedures tell him to maintain 220 inches in the
10 pressurizer. If it is higher than that, he's going to have to bypass the
11 actuation to throttle the high pressure injection valves.

12
13 BEERS: We feel this is a design problem in that this same hydroxide is
14 injected into the reactor coolant system at this time it is really the
15 design, it is really for LOCA considerations and not necessarily at the
16 time of a reactor coolant, or a reactor trip.

17
18 KIRKPATRICK: Another question along this same line, can you tell me what
19 the pump, make-up pump limitations, flow limitations are.

20
21 BOLTZ: Yes, the make-up flow limitations on TMI 1 and TMI 2, that's 550
22 gallons per minute per pump and we have high pressure injection flow alarms
23 to each of the four high pressure injection legs. Individually they come
24 on at 275 gallons a minute increasing.
25

1 KIRKPATRICK: As the pressure decreases significantly below the low pressure
2 trip setpoint that initiates _____, what would happen to the flow.

3
4 BOLTZ: Coolant system pressure decreases following initiation of high
5 pressure injection. If you start out with, what, say, 250 gallons a minute
6 through each of the four high pressure injection valves, as the coolant
7 system pressure decreases the high pressure injection flow will increase,
8 and it is required operator actions by the emergency procedures to bypass
9 the actuation signal and throttle down on the high pressure injection flows
10 to prevent run out of the make-up pumps.

11
12 KIRKPATRICK: Okay, thank you. One of the things that happened during the
13 event was apparently--the core was, as the core was voiding, a nuclear
14 instrumentation showed an increase. Does the training program include the
15 behavior of nuclear instrumentation during the density changes in the
16 core,...changes of density of the coolant in the core.

17
18 BOLTZ: Yes, the training that the operators get does address this. There
19 are several areas where it is stressed not only for nuclear instrumentation
20 purposes but for reactivity changes in the core. What we are addressing is
21 leakage neutrons from the core. It has never been specifically addressed
22 that if you get a steam bubble in the core you would see an increase in
23 nuclear instrumentation. We have never addressed a steam bubble in the
24 core. But, yes, they would be aware of the effects on nuc instrumentation.
25

1 ZECHMAN: We hit two areas with respect to those detectors in this light.
2 One is the density changes of water in the event of neutron leakage which
3 the detector see, and two, the movement of control rods in the areas of the
4 detectors and their effects on the instrumentation.

5
6 BOLTZ: I might add that one of the things which is commonly done by a
7 control room operator on the console is, when we are doing a heat balance
8 check on the out-of-core detectors and of course I am talking power range
9 detectors, if they are out of specification, meaning they are out away from
10 the heat balance by more than 1.0 percent full power, one of the things
11 that we can do is to slightly adjust the reactor coolant system T^F higher
12 or lower to get the indicated reactor power from the out-of-core detectors
13 back within 1 percent of the heat valves and this done very calmly. I am
14 not saying we adjust T^F by two or three degrees or anything like that but
15 many times even a half degree T^F change will bring the instrumentation back
16 within specifications and the fellows know this, and they know that what
17 they're doing is affecting the core density and the leakage neutrons that
18 the out-of-core detectors are seeing.

19
20 KIRKPATRICK: Are changes in the pump behavior which are caused by reduced
21 water quality addressed during training.

22
23 BOLTZ: Yes, you must be talking cavitation of pumps.
24
25

1 KIRKPATRICK: Right.

2
3 BOLTZ: MPSH, cavitation, things like that, pump run out. Yes, basic
4 fundamentals under fluid flow and things, are covered all the way down
5 starting in the AOC program that the fellows are initiated in. Auxiliary
6 Operators, its the lowest, what do you want to call it, rank of auxiliary
7 operator in the plant.

8
9 KIRKPATRICK: And as the operator observed some of the alarms that were
10 occurring during this event such as increased pump speed and increased
11 vibration, what would his training require him to do.

12
13 BOLTZ: We have procedures which cover abnormal operation on reactor coolant
14 pumps and motors. Do I have those procedures here? I should. Reactor
15 coolant pump operation procedure 2103-1.4, and reactor coolant pump and
16 motor malfunctions, I don't have, let's see, the procedure, here it is,
17 2203-1.4 address abnormal conditions, which require securing a reactor
18 coolant pump and they include high vibration, high amperage, low RC flow,
19 those conditions under the manual action required, they say reduce power,
20 trip reactor and secure the affected RCP, so under high vibration conditions,
21 which we're sure that they had, they did have decreasing reactor coolant
22 system flow indicatio, which I have seen through some conversations with
23 operators that were there, and I know they had low motor current. I did
24 mean high motor current rate originally. So here's one procedure specifically
25 which says you must trip the reactor coolant pump. This was covered in

1 operator training, both in CRO training and requal training for the licensed
2 operators.

3
4 MARSH: Regarding both this procedure and the one you cited from earlier
5 and the others that you referenced, is this correct that these are the
6 current versions of those particular procedures and the ones that were in
7 effect on March 28?

8
9 BOLTZ: The 2203-1.4 procedure, abnormal procedure, reactor coolant pump
10 and motor emergencies, is--that I'm holding here--is revision 3 dated
11 5/4/78. The pages that were changed on this revision on this revision are
12 pages 2, 3, and 3.1, the conditions requiring tripping the coolant pump
13 under the low amps, the high vibration and the low coolant system flow are
14 on page number 8.

15
16 MARSH: So that indeed then is the most current version and it does reflect
17 information that was in effect on March 28, those portions that you cited.

18
19 BOLTZ: Yes, that's true, and page 8 here is revision 0 dated 5/17/77.

20
21 ZECHMAN: And you are using a control...you got a control copy in front of
22 you?

23
24 BOLTZ: This is a control copy for the training department.
25

1 KIRKPATRICK: Does the training emphasize or include discussion of any of
2 the hazards that the operator might, because of the primary system, if he
3 did not trip the pump in case of high vibration.

4
5 BOLTZ: If you did not trip a pump due to high vibration. Yes, the operator
6 knows and it is addressed during CRO(?) training programs that he could run
7 into seal failure problems of the pump itself. Cavitation could cause
8 dropping the impeller, and the steam formation right there, and one of the
9 big things that we pushed in our training program is the idea of a seal
10 failure. You want to try to avoid it under all circumstances, because it
11 puts the unit into a loss of coolant situation. I might add from my own
12 personal viewpoints, is--that paper said, you know, you can give your own
13 recommendations--that if the coolant pumps had been left on line instead of
14 being secured like they were, if they would have cavitated those pumps very
15 much longer, they would have gotten seal failure, which would have put them
16 into a loss of coolant situation which is unisolable. And I feel at this
17 time we would be recirculating the Reactor Building sump inventory through
18 the low pressure injection lines and the dose rates in the Auxiliary Building
19 would be tremendous, and any leakage out of those pumps right now is going
20 to give one heck of a gas release, so we would have offsite teams tracking
21 a plume yet today.

22
23 KIRKPATRICK: One of the things that occurred during the event was that the
24 outlet temperatures went offscale and comparison with the pressure at the
25 time indicates that these were in a superheat range. Did the operator
training ever address significance of such a thing and the fact that, ah...

681 076

1 BROWN: We discussed the regions of heat transfer, as to whether it's
2 conduction, nucleate boiling, film boiling, bulk boiling, or superheat. As
3 far as the temperatures were--really referred to the pressure--yes, and no.
4 We deal our discussions primarily with the steam generators. We're talking
5 about those different mechanisms of heat transfer and getting the good
6 quality of steam out of the steam generator, and don't really address it in
7 the reactor coolant system because--Well, the only thing we talked about is
8 that the reactor is operating in the nucleate boiling region, and the fact
9 the nucleate boiling region can be broken down into two parts: the subcooled
10 and the saturated, and that the regular operators in the subcooled nucleate
11 boiling region, where in the nucleate boiling region small bubbles are
12 formed, small voids are formed, but they move into the coolant and collapse
13 quickly and in the subcooled nucleate boiling region those bubbles of heat
14 transfer are at a minimum, even though you are in a good region of heat
15 transfer. But as far as talking about those temperatures that be T set,
16 those range of those instruments that they would be looking at on the
17 console only go up to 620 degrees, and I don't know exactly what the pressure
18 was at the time that you were referencing it, 1300 degrees. Yeah, you are
19 definitely over set T. But, there's a few numbers that are in their mind,
20 like for example, they know that for a pressure of 1010 that the set T is
21 around 545.

22 KIRKPATRICK: That's because that's the steam generator.
23
24
25

1 BROWN: And that's to do with the steam generator and we talked about that
2 for a reactor trip, and the steam bypass valves are to maintain that steam
3 header pressure at 1010, so that we have a cooling mechanism to go to
4 maintain the steam generator 545, while the reactor coolant system will lag
5 a little bit and be around 555, which will limit the amount of shrink
6 following a reactor trip. And that is gone over quite extensively. Whether
7 they can carry it over or not during that transient situation, I don't
8 know. I'm sure the--personally I would sit there and say, "Oh, gee, look
9 at that temperature, that's T set." You know, there's 14,000 alarms going
10 off and you're trying to figure out where to go, I'm not sure if I could
11 put that together myself. Maybe I could, and I'm cuttin' myself down, but
12 that's something I'm not sure I would go with, but yes, heat transfer,
13 superheat and certain T set's are gone over, even in the pressurizer opera-
14 tion. They have to record every shift of the pressurizer temperature, and
15 they know that for 2155 T set is 650 or thereabouts, close to it, and
16 that's the indication that they are looking for to show that they have
17 saturated conditions in the pressurizer.

18
19 BOLTZ: One thing I would like to add to that is during the CRO training
20 and in fact during the requalification training, when an RPS force is given
21 we do address the effects of departure from nucleate boiling on cladding
22 temperatures. There is a graph that we put out that show's what happens
23 when the core does depart from nucleate boiling, going back and forth to
24 the film boiling region and the film collapsing and cycling the temperatures
25 of the cladding up and down. But, it is never discussed, that I know of,

1 in terms of reactor coolant system pressure and an actual steam bubble
2 being formed in the core, uncovering the core. Just the effects on heat
3 transfer and the effects on elevated cladding temperatures, is all that has
4 been addressed.

5
6 BROWN: The only time that any B&W lecture or anything else we ever talked
7 about goes into the safety features emergency core cooling system, is on
8 the maximum hypothetical accident, the worse LOCA, is that the assumptions
9 are that the only system that works is your low pressure injection system,
10 and if the core does get uncovered then the recovering is no problem.

11
12 BOLTZ: That's right. We also have right in our tech specs, the final
13 acceptance criteria of 2200 degrees it is right now, for peak cladding
14 temperature following a loss of coolant accident.

15
16 BROWN: The analysis was done to show that it was safe at 2300, but the
17 final acceptance criteria for the emergency core coolant system limited
18 that to 2200.

19
20 BOLTZ: But again, I do want to stress that the final acceptance criteria
21 as it was presented to us by the B&W people and as we present it to the
22 operators is stressed on cladding temperature and its effects on heat
23 transfer and cladding damage, not on coolant system response. We are
24 talking accident conditions when we talk final acceptance criteria, and we
25 are talking loss of coolant, which dictates coolant system pressurizer

1 level really being low and possibly out of sight because there is a hole in
2 the coolant system.

3
4 KIRKPATRICK: PA11 right, thank you. That's all the questions I have
5 regarding the primary system behavior. Do you have any more comments that
6 you would like to give at this time before I get into the emergency plan
7 questions?

8
9 BROWN: There's something I would like to have in here. And that is that
10 the whole event that started this thing was due to the loss of main feedwater.
11 And what caused this whole thing, I feel it could have been avoided with
12 some good designing. The main feedwater pumps did trip on low section
13 pressure as designed. They were cleaning out some--trying to clean up the
14 condensate polishing demineralizers--and a line clogged which got water
15 back into an air line which caused the outlet valves on the condensate
16 polishers to go closed. Therefore, there was significant reduction in the
17 water suction to the main feedwater pumps, causing them to trip. There is
18 a bypass valve on these condensate polishers, but it's manual and that
19 doesn't do anybody a damn bit of good. And that to me is--that started the
20 whole thing, and we were talking about some of the locations of, where is
21 the indication at? Where's the control at? In the control room, is the
22 availability for the operator to see it? There's a lot of design things
23 there that, as far as I know, were identified on problem reports to the
24 contractor, Burns and Roe, the engineer contractor and startup testing,
25 which I believe was done by UE&C, United Engineers and Constructioners and

1 to GPU. This was by the operators. Some of the things were taken care of;
2 other things weren't.

3
4 KIRKPATRICK: I discussed this area with you before. You listed a series
5 of differences between Unit 1 and Unit 2 that you believe would have led
6 to... had they existed on Unit 2, as they do on Unit 1, may have mitigated
7 this problem.

8
9 BROWN: One of the lists

10
11 KIRKPATRICK: Make notes

12
13 BROWN: I'll try, I don't know if I can remember all or not. One of the
14 things is the electromatic relief valve. In Unit 2, there is a status
15 light on the console that was added after they had lost a power supply one
16 time; and the only thing that this light does in Unit 2 is give you an
17 indication of what kind of command signal is being sent to the solenoid
18 valve for this electromatic relief valve. In Unit 1, it's a limit switch
19 on the valve that will tell you whether that valve is open or closed.
20 Additionally, in Unit 1 all the operator has to do is, standing there at
21 the console, controlling the primary system, is turn around and he has
22 indication of RC drain tank pressure and temperature, and he can see whether
23 the heat exchanger is on trying to get the temperature back down. In Unit
24 2 he can't do that. Those are two things right there that I can think of,
25 plus this bypass valve, which I just mentioned.

1 BEERS: Right. Why don't you go ahead and explain how the bypass valve
2 works in Unit 1?

3
4 BROWN: Well, in Unit 1 if you get a high differential pressure across the
5 polishers in Unit 1, which is called Powdex in Unit 1, this bypass valve
6 goes open so that you can pump straight from the hot well to the condensate
7 pump, to the condensate booster pump, right to the feedwater pumps, without
8 cleaning up the water. They sacrifice water quality, as far as chemistry
9 is concerned, to ensure that you do have water in the main feed pumps, and
10 in Unit 1, the main feed pumps don't trip because they have that bypass
11 around their polishers.

12
13 BOLTZ: I might add that Unit 1 has the same feedwater pumps that Unit 2
14 does. Unit 1 does not have low pressure trips on those feed pumps.

15
16 KIRKPATRICK: You mentioned the existence of the block valves on Unit 2.
17 Feedwater block valves. Auxiliary feedwater block valves.

18
19 BOLTZ: In Unit 1, it comes off the discharge of the pump, it goes through
20 the control valves, which are called EFV30A and B, straight into the steam
21 generator through the Aux Feed nozzles. In Unit 2, it comes out off the
22 discharge of the pump and it goes through the control valves which are
23 EFV11A and B, and then it goes into a header motor operated where this one
24 valve was closed, this EFV12A and B. They were closed, and then through
25 two normally closed valves and their numbers are EFV32A and B, and 33A and

1 B, and they are a bypass around this block valve that in event this 12
2 valve doesn't work they can go through those. And in Unit 1, they don't
3 have that, so there is no problem about worrying if it is locked open, or
4 if it was tested properly, or if the limit switches were okay. It's just a
5 straight shot off the control valve and you either have it or you don't.

6
7 KIRKPATRICK: Do you know why the procedure for surveillance testing requires
8 closing those 12 valves, _____ valves, if they are not needed on Unit 1.

9
10 BOLTZ: You mean on Unit 2.

11
12 KIRKPATRICK: Yeah. The Unit 2 procedure requires closure of these valves.
13 Since they don't exist on Unit 1 presumably they are not needed there.

14
15 BOLTZ: I don't know why they do. In fact, not all of the surveillance
16 procedures that we have on the Unit 2 emergency feedwater system, which
17 ends up with the emergency feedwater pumps running on recirculation--not
18 all the surveillance procedures require those valves to be closed, only
19 one. It happens to be the one that was performed a few days before the
20 incident.

21
22 BEERS: There are two possibilities of why they must be closed on Unit 2
23 and not on Unit 1. The first possibility is that Unit 2 is on standard
24 tech spec and requires many more operability checks, all of these emergency
25 feed systems, than is required by Unit 1. Secondly, perhaps the flow

1 control valves, the EMV11A and B in Unit 2 leaked through, and to preclude
2 water being injected into the generator, the block valve was in in line
3 with the control valves.

4
5 BOLTZ: The way Unit 1 gets around that is they close the discharge valve
6 on the emergency feed pumps, which is downstream of the discharge check
7 valve and Unit 2 has the same set up. In fact, motor operated discharge
8 valves, Unit 1's are manual which have to be closed locally by the operator,
9 but the low flow recirculation valve for pump protection is before the pump
10 discharge check valve, just as in Unit 1. So they could have operated the
11 same way.

12
13 BROWN: There is one other difference between Unit 1 and Unit 2, is that
14 some of the discussion with the operators, they were having a lot of problems
15 with their make-up pumps, getting them on and letting them stay on, and the
16 interlocks require a four second time delay for the Unit 2 make-up pumps to
17 start, 'cause when you hit the the control switch you have to hold it until
18 it goes through its logic to get the oil pumps on before we'll say okay
19 pumps start. In Unit 1, it doesn't have that time delay. You hit the
20 control switch, the oil pumps are already on, and it goes right away.
21 That's one other difference between Unit 1 and Unit 2 on those.

22
23 BOLTZ: One other thing we mentioned the other day is for unit differences,
24 and it becomes quite important in the March 28 incident, and that is the
25 design feature in Unit 1 on the way we empty the RB sump. We have two

1 containment isolation valves that we have to open, it's gravity flow into
2 the Auxiliary Building sump in Unit 1. There's a low level interlock,
3 which automatically closes one of the valves to maintain a water seal, so
4 that there is no gas release from the containment to the Auxiliary Building
5 should the line go dry with the sump. There are no automatic sump pumps or
6 valves or anything like this, like Unit 2 has. And maybe if they would
7 have had the same thing, all this water in the Unit 2 Auxiliary Building
8 just wouldn't be there today.

9
10 KIRKPATRICK: All right.

11
12 BOLTZ: I might add one thing, is these two containment isolation valves on
13 the Unit 1 RB sump, and I am sure this is true of all the Units, only close
14 on a four pound safety feature actuation, not a low RC pressure deal.

15
16 KIRKPATRICK: Okay. I'll go to the emergency plan questions. Do you have
17 an established training program for individuals who are assigned duties and
18 responsibilities by the TMI emergency plan.

19
20 ZECHMAN: Yes, sir. We have a procedure titled "Station Health Physics
21 Procedure" 1670.9, Volume 1, "Emergency Plans and Procedures, Emergency
22 Training and Emergency Exercise," which I have available for you here
23 today.
24
25

1 KIRKPATRICK: All right, this does briefly describe the nature of the
2 training, briefs of the...well for the various categories of personnel who
3 would be involved in an emergency, is that right.

4
5 ZECHMAN: Yes sir, it does.

6
7 KIRKPATRICK: All right, thank you. Does the training outline...let's see
8 does this training program...is this training program, excuse me, outlined
9 in the form of schedules and lesson plans?

10
11 ZECHMAN: The training program outlines--the procedure, I should say,
12 outlines the training required for each of the assignments to the onsite
13 emergency personnel. It identifies in the procedure that lesson plans
14 will be available for each program. In other words, the lesson plans are
15 not included in the procedure but the procedure states what shall be taught.

16
17 KIRKPATRICK: All right.

18
19 MARSH: Have these lesson plans been developed?

20
21 ZECHMAN: Yes, sir.

22
23 MARSH: And they are available.
24
25

681 086

1 ZECHMAN: And they are available.

2
3 KIRKPATRICK: Is it training, classroom, or hands-on in nature, or both?

4
5 ZECHMAN: It is a combination of both because along with the training we
6 followup with a drill, the actual drill participation by the participants.

7
8 KIRKPATRICK: All right. During--you're at the end of the training sessions,
9 are there tests or other checks of individual's proficiency.

10
11 ZECHMAN: In certain areas there is, yes sir. Depends on the job assigned,
12 for example, we don't for training offsite fire companies or civil defense
13 people as part of this program, we don't give them tests.

14
15 KIRKPATRICK: But for, let's see, well, for personnel in these categories
16 like emergency directors, accident assessment personnel, radiological
17 monitoring teams, fire brigade team, onsite fire brigade team, repair party
18 team, first aid rescue team, operations personnel and division support
19 personnel. Would they have the proficiency tests?

20
21 BROWN: Some of them would.

22
23 BEERS: Part of them do, and part of them don't.

1 BROWN: All right. The accident assessment group that would be doing the
2 calculations, yes, they are instructed, they go over all the offsite doses
3 and calculations have to be gone into that, and there is a quiz that goes
4 along with that. The operations personnel must pass a test on certain
5 emergency procedures that are outlined in this 1670.9. There is a hands on
6 type of training for the fire brigade, everybody has to go then physically
7 wrap the hose in their hand and put a fire out or an extinguisher or both,
8 and the first aid training is a Red Cross or multimedia course and, yes,
9 there is a quiz with that. Some of the training there is, some there
10 isn't.

11
12 KIRKPATRICK: All right.

13
14 _____: I might point out that like the procedures states, unless the
15 plans are outlined, will be revised by the instructor for each program, and
16 will include periodic examinations or assignments.

17
18 KIRKPATRICK: All right.

19
20 MARSH: You mentioned contingency planning with offsite local fire depart-
21 ments, this type of thing. Who bears the responsibility for that, under
22 whose ...which one of you would be in charge of that or would bear reponsi-
23 bility for that portion, or do all of you get involved?
24
25

1 BROWN: Yes, the training is conducted and it normally falls under the
2 realm of radiation protection supervisor, Dick Dubiel, and supervisor of
3 maintenance, Dan Shovlin, and safety supervisor--which I believe in charge
4 of that now, is Earl Gee. And they work together with getting these people
5 in here. Earl Gee, for example, he works a lot with the fire companies to
6 get them in, either him or Jim Wheelan, from Met Ed Safety Department.
7 We'll work with the fire companies so that they know which gate to come in,
8 where the special hookups--that's for anything different from what's on
9 their truck--is located and as far as who was in charge this past year, I
10 don't know.

11 _____: The procedure can be very specific. For example a training program
12 facility _____ is the responsibility of the supervisor of Radiation Protec-
13 tion and Chemistry. The training program for the Bureau of Radiological
14 Health is the Supervisor, Radiation Protection, or his designee. The
15 training program for the State Police is the Supervisor of Radiation Protec-
16 tion and Chemistry. The training program for the local fire companies is
17 the TMI representative and his designee, as Mr. Brown just explained.
18

19
20 MARSH: Do you people monitor the performance of these people to see that
21 this training _____ had been carried out?

22 _____: We receive final documentation.
23
24
25

1 KIRKPATRICK: Okay, has this been exercised. Have they been doing this
2 lately?

3
4 _____: Yes, sir.

5
6 KIRKPATRICK: Do the offsite people participate in any of your drills?
7 Have they responded or has this been exercised, so that, uh,...

8
9 BOLTZ: The way it works is we set up a training program and invited the
10 local companies to respond.

11
12 KIRKPATRICK: Have they responded? .

13
14 BOLTZ: Some have, some have not. To be specific, I would have to go back
15 to the records and tell you exactly who has this year and who has not. I
16 don't have it with me.

17
18 BROWN: Some of the...most of them I think had. I am not sure if we have
19 an attendance by name of who from these offsite organizations participated.
20 And every year in the radiation emergency drill, they are notified to
21 activate their own subsection of the plan and follow it through with the
22 emergency plan. And this is sort of a little thing afterwards: about a
23 week and a half after this March 28 incident here, I heard a big thing on
24 the news from the, I think it was Lancaster County Civil Defense, that
25 says, "We now have an emergency plan." What in the hell were they doing
since 1974 when we were running these drills?

1 KIRKPATRICK: One of the questions that I have down here is, "Briefly
2 describe the emergency drill program."

3
4 _____: Sir, that is spelled out in detail in the procedure 1670.9 that
5 I am turning over to you today.

6
7 KIRKPATRICK: All right, thank you. As of 3/28 has the 1978 training
8 iteration for emergency planning been completed?

9
10 _____: The training was provided for each of the organizations that are
11 mentioned in the training procedure. There are a few who send, for example,
12 the repair party. The repair party, two graduate people(?) have been
13 trained with the responsibility to go to their people in their departments,
14 and train them. In certain areas, that has not been completed as of this
15 date. Operations training has been completed.

16
17 KIRKPATRICK: All right, thank you. If a drill identifies any area or an
18 area requiring followup, in other words improvement, how is the area high-
19 lighted, evaluated or corrected?

20
21 _____: All right, as a result of the drill critique, individual action
22 items are listed on Enclosure 4 of this procedure. With action to be
23 taken, then has the be...the action has to be resolved with resolution
24 attached and signature and date signed.
25

681 091

1 KIRKPATRICK: Okay, and to your knowledge, on March 28, were there any
2 outstanding items that had been identified during previous drills that have
3 not been resolved.

4
5 _____: During previous drills or the last drill?

6
7 KIRKPATRICK: Well

8
9 _____: During the last drill, there are still outstanding items that
10 have not been resolved.

11
12 KIRKPATRICK: All right. Would you be able to describe them right now or

13
14 _____: No sir, they are available.

15
16 KIRKPATRICK: All right, but outstanding items from drills previous to that
17 have been completed, is that right?

18
19 _____: Again, I would have to look at, into all those items and tell you,
20 you know. I do not have them with me to identify that, and it has been
21 over a year since that time so it is available to you at any time.

22
23 KIRKPATRICK: All right, thank you. That's all the questions that I have.
24
25

1 MARSH: I've got one or two more. With the offsite contingency training,
2 that's a broad title for it, I assume the hospitals are also included?

3
4 _____: Yes sir. We have run a yearly emergency drill with the hospital.

5
6 MARSH: In some instances, your employees here, within different categories
7 work on a swing shift type of basis, with them rotating shift to shift to
8 shift, with a set period at the end of that rotation assigned for training.
9 Do you people monitor the use of that time? In other words, if I've got a
10 week at the end that's supposed to be training, you are just dealing with
11 supervisors to be sure that ultimately the training is accomplished, am I
12 understanding you right?

13
14 BROWN: This is right. For licensed operators and people in operations the
15 auxiliary A, B and C operators, on some of their weeks, which is called a
16 training week, there is some classroom training. Other than that, there is
17 some system training, which they can do on their own under the direction of
18 the Foreman, who says, "Okay, you go trace this system out and go answer
19 these questions." The licensed operators do attend the requalification
20 program. The maintenance people such as electrical, mechanical, instrument,
21 radchem techs, people that are on shift work of that nature, we at this
22 time do not do any training for them. If there is any training they can
23 sit in on, it's fire fighting, first aid. All right, they come to that,
24 but we don't provide a weekly training schedule for those people.
25

1 BEERS: We do provide some training for these type of people that you
2 addressing, but what Mr. Marsh is asking, do we track to ensure that they
3 are trained. Am I correct?
4

5 MARSH: The specific one I am looking at that, although time is set aside,
6 what prevents this time from being used by the supervisor as just another
7 work week. And although it may be labeled as training, it is not dedicated
8 the same. I am looking for a hand as to whether we can measure that or
9 not.
10

11 _____: We can. Let me be a little specific. Our department represented
12 here today has the responsibility for the training, and operations training,
13 general employee training, radiation emergency drill training. The line
14 departments, line management, is responsible for their training programs,
15 maintenance responsible for their training programs, radiation protection,
16 that department is responsible for their training programs, and so forth.
17 So we are getting in another area that we are not responsible for.
18

19 MARSH: Right, but at the end of that training they then respond to you?
20

21 _____: That's right.
22

23 MARSH: Do you have track records on that?
24
25

1 _____: Yes sir, at the end of that training they supply to us the final
2 documentation of their training that took place within their area.

3
4 MARSH: That answers my question. Okay, one other area I would like to put
5 on this tape, and this is from a layman's point of view recognizing that
6 the tape may be listened to by other investigative teams with limited
7 technical knowledge. If I were a newly hired potential licensed operator,
8 if I understand you right earlier, I would start as a Aux operator C and I
9 start undergoing my training. Could you briefly describe what my course of
10 training would be? How would I progress to the point where I became a
11 licensed operator? Kind of put the whole training program of an operator
12 into perspective, recognizing that it's detailed in the documents, but just
13 for the sake of expediency here I would like you to repeat what's in it.

14
15 ZECHMAN: Zechman - Okay, I can describe that program. The training program
16 for CRO today begins really at the Aux operator level. I'll give you a
17 feel for this. We have three classifications of Auxiliary operators,
18 Auxiliary C, above him is Auxiliary B, above him is Auxiliary A operator.
19 In order to get to be a control room operator, you have to be at the Auxiliary
20 A level, and be the most senior qualified individual to bid in for CRO
21 position when it is available. Now, to give you the kind of training that
22 one goes through just to get to the A level: an Aux C, a person who meets
23 the job specifications for an Auxiliary C operator will be identified as an
24 Auxiliary C operator and come in to a one year training program, the begin-
25 ning of which is approximately six to eight weeks of classroom training, 8

1 hours a day, 5 days a week on secondary systems. This is followed by a
2 comprehensive written exam. Now, I point out that weekly exams are given
3 during the progression of that program, a comprehension exam at the end of
4 classroom portion. This individual, then, for the remaining part of one
5 year is to be assigned to a shift under the direction of a shift foreman
6 and other auxiliary operators on shift, and proceeds on-the-job training
7 with those people. At the end of one year, he is then given an oral and
8 final written examination on everything he has had for that period of one
9 year. Successfully passing that program, he then automatically, what we
10 call the mode, automatic motor progressions, moves up to the auxiliary B
11 level. Should he fail two exams for the Aux C program, in other words he
12 failed the original one, and then we give him a re-exam with the union
13 present. If he fails that he returns to the job he previously held. If we
14 had hired him from the street, he would be out of a job. If he came in
15 from a utility group or with any other group within the company, he would
16 go back to that position. Now assuming he successfully finishes the Auxiliary
17 C training program of one year and qualifies as I said he moves up automa-
18 tically to the Auxiliary B level--again, he goes into a classroom training
19 program six to eight weeks, and now is indoctrinated on the primary systems.
20 Same criteria applies, he takes weekly exams and on final written exam at
21 the end of the classroom portion, then is assigned again to a shift under
22 the direction of a shift foreman and an auxiliary operator crew, and goes
23 onto an on-the-job training situation. Again, at the end of one year he is
24 then given an oral and written examination on everything he has had to
25 date, and it's comprehensive. It includes both secondary and primary. And

1 I might point out that the oral exam is given by his shift supervisor to
2 assure that, the operation department, that they are satisfied with this
3 gentleman they have positioned. Now once he completes that training program,
4 he is automatically promoted to Auxiliary A operator position, as a fully
5 qualified Auxiliary A operator. Now, as I said, if a control room operator
6 position does open up, the Auxiliary A operators are allowed to bid through
7 the union process for that position. After interviews, the most senior
8 qualified Auxiliary A operator would get that bid. He immediately then
9 goes into a nine month, what we call Category 4, control room operator
10 training program. Perhaps, Marsh, this is your area, you would like to
11 describe that program.

12
13 MARSH: Well, Brown, you did so well on the last interview that I'll let
14 you do it again.

15
16 KIRKPATRICK: Brown, before you start I am going to interrupt you just a
17 second, and put a new tape on if I may. Okay, the time is 6:47 meter
18 reading 1377. I am going to terminate this tape.

19
20 MARSH: We are continuing now with the second cassette in a discussion with
21 Ed training personnel, and, Mr. Brown you were about to continue with
22 the training procedures of the newly hired individuals destined to become
23 an operator, who'd be going through.
24
25

1 BROWN: Okay. The training program for a control room operator, hereafter
2 referred to as CRO, is nine months in duration. He is going to be on
3 probation for this job for 90 days. So the program describes evolutions
4 for the shift foreman to look at. How well does he handle himself in the
5 control room? Remembering that the control room is a room without any
6 windows, you don't know what time of day or what the weather is outside,
7 completely confined, and it takes a special kind of a person to work in
8 there. So they want to look to see how they react in there, how well they
9 learn the basics of the layout of the console, and how they've worked with
10 other people on their shift. The program itself has a listing of all the
11 procedures in there; the administrative procedures, going over such things
12 as document control, switching and tagging, radiation protection plan, and
13 emergency. All the emergency and abnormal procedures are listed in there,
14 and the normal operating procedures are listed. The program starts out
15 with a review of the secondary plant with systems like circ water, river
16 water, and some of the closed cooling systems, much like they had when they
17 were an auxiliary C operator. The difference being, now that they're going
18 to be looking at the specific interlocks of that system, the functions of
19 that system again in more detail, and the places where that component may
20 be controlled from--whether it is out on the plant or in the control room
21 and what indications they have in the control room for that system. And
22 the first portion also goes into the administrative procedures. During the
23 whole course, during the 9 months, they have to get signed off on this
24 procedure list. They have to talk with the--they either have to perform
25 it, simulate it, or describe the events in that procedure to the satisfac-

1 tion of their shift foreman, the shift supervisor, or another senior reactor
2 operator--if they understand what's in that procedure. Now the program for
3 the 9 months is broken down into six segments and they cover it in--we call
4 it half of the cycle. After they go through half of this cycle, to the
5 sixth segment, they get a written test on that information. The whole
6 program is cumulative in nature. What they were responsible for on day 1
7 they are responsible for the end of the 9 month program. At the end of the
8 first complete cycle, they then have to take another written examination
9 and a comprehensive walkthrough, which will last somewhere between 4 and 8
10 hours on the material that they had studied. They then continue going
11 through the cycles into the primary systems, chemical addition, safeguards
12 actuation, reactor theory, control rod drive, intergrated control system,
13 reactor coolant pumps, reactor coolant system construction components in
14 there. And each time they're taking a written, two writtens and an oral
15 examination, a walkthrough, on every one of these cycles and, again, its
16 cumulative. So by the time they get to the end of their 9 month program
17 they will have taken a minimum of 12 written examinations, and have 6 oral
18 examinations. In addition, they also get a class depending on their experi-
19 ence and availability of those people, whether its one on one, or whether
20 its one with five or six, one instructor to five or six people, they will
21 have a class on the integrated control system, where we go into everything
22 except the size of the resistors and stuff. They're very detailed, very
23 exact, and a one week course on reactor theory as well. They also have to,
24 for satisfactory completion or preparing for a license, have to go to the
25 simulator and they have to pass a startup certification. So, once they

1 finish the 9 month program with the training department, taking the 12
2 written and 6 oral examinations, in order to get the opportunity to get
3 examined by the NRC, they also have to take a mock written exam following
4 in the guidelines of the NRC exam, of the seven categories, and they have
5 to get an additional oral examination by a senior reactor operator other
6 than someone in the training department. So they will have 2 to 3 different
7 people or more giving them examinations so that they can benefit from
8 having the same question asked by different people in different ways. It's
9 quite extensive. We also go into the non-nuclear instrumentation and the
10 nuclear instrumentation in great detail.

11
12 ZECHMAN: We might point out that I have turned over, this is Dick Zechman
13 speaking, turn over to Donald Kirkpatrick a complete package of the category
14 4 training program. And you might also point out that when they do receive
15 the right to, for us to allow them to go for an NRC exam, the NRC then
16 administers both a written exam, which lasts anywhere from 6 to 8 hours,
17 followed by an oral exam, which lasts anywhere from 4 to 6 hours before
18 they certify them as an SRO or CRO, ...

19
20 BROWN: There is one thing I'd like to bring out, this is Brown again, is
21 that during the oral examinations, the emergency procedures, they have to
22 simulate them in a timely fashion corresponding to whatever emergency
23 procedure it is, at the console by saying "I'm gonna look at this switch,"
24 and pointing to it, "I'm going to look at this gauge," and pointing to it,
25 and goes through step by step, and be interrupted, and say, and answer the
question "Why?," during the examination.

1 KIRKPATRICK: This is Kirkpatrick, I have a package that was given to me by
2 Mr. Zechman and it will be available as part of the investigation team
3 documentations.

4
5 BROWN: One other thing I would like to address since we've described this
6 program in detail and that is the fact that, as I understand it, the personnel
7 who were actually on shift the day of the incident had had previous extensive
8 experience and training, including, I believe in each individual's case,
9 they've completed the naval nuclear power program. And because of this,
10 they did not receive all the training you've described here. Could we
11 briefly, since we have addressed this area, can you describe the training
12 these four individuals had?

13
14 ZECHMAN: The individuals went through with the NRC titles a code licensing
15 training program and it is described, the program is described in the FSAR
16 for Unit 2, Chapter 13, training programs for supervisory CRO's and SRO
17 personnel and I'm turning it over to you at this time.

18
19 KIRKPATRICK: Thank you.

20
21 ZECHMAN: I might point out that that document I turned to you is only a
22 portion, that covers the major training programs of the in-depth and the
23 number of minor training programs by minor I will even include something
24 like first aid, although that only has a small number of hours associated
25 with it. The training that each person has received is available from us

1 and also is summarized on a computer printout and the number of hours for
2 each training program for each individual. And that is available to you at
3 any time.

4
5 KIRKPATRICK: All right. I'm still gathering that kind of documentation
6 and I believe that--well, we will include for those specific individuals,
7 we'll include this, these records as part of the investigation team records.

8
9 MARSH: Well, I appreciate very much your time in coming in to speak to us
10 and since we've been asking you questions, before we terminate, I would
11 like to offer each of you an opportunity, this is Marsh speaking, to put
12 into the record, as I discussed while I was changing tapes, your thoughts
13 on the incident and what we're benefitting from it. Any comments or recom-
14 mendations will be solicited, if anyone has anything. I know we've discussed
15 and commented during the course of the investigation, this has been going
16 on as things have been coming up we covered stuff on a tape, but I didn't
17 want to cut you short and terminate before we give you an opportunity if
18 there is anything you want to bring up or discuss. Okay, if we're in
19 shape, then I'm gonna terminate the tape at 6:58 reading approximately 105
20 on the meter, the second cassette. Once again, say thank you for your
21 time. I recognize that you are busy people also, I appreciate your time in
22 coming in. I cut the tape then at 6:59.

23
24
25

681 102