

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION

1 In the Matter of:

2 IE TMI INVESTIGATION INTERVIEW

3 of

4 John Flint
5 Physics Test Coordinator, Unit 2

6
7
8
9 Trailer #203
10 NRC Investigation Site
11 TMI Nuclear Power Plant
12 Middletown, Pennsylvania

13 April 20, 1979

14 (Date of Interview)

15 July 5, 1979

16 (Date Transcript Typed)

17 275

18 (Tape Number(s))

19
20
21
22
23
24
25
7908290308

21 NRC PERSONNEL:

22 Ed O'Connor

23 009 346

1
2
3
4
5
6
O'CONNOR: This is an interview with John Flint of B&W being interviewed by Ed O'Connor. The date is April 20, 1979. The time is approximately 15:50. John, would you briefly state when you came on site, what your role is at TMI, and pretty much what you saw as you entered the control room the morning of the 28th of March.

7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
FLINT: My function onsite was to be physics test coordinator the Unit 2 startup. Previous to this I had been working on writing the Unit 2 startup report. At approximately 08:30 on the 28th of March, I arrived at the north gate to the Island only to be stopped due to security personnel restricting anyone from coming on the Island. During approximately the next 20 minutes to a half hour I attempted to have one of the security personnel contact the control room, and find out if my services were required. This is based on fact that I am familiar with the core physics of the Unit. At approximately 0900 permission was received for me to go on the Island. I immediately drove to Unit 2, entered through the Unit 2 search trailer and went directly to the control room. Upon entering the control room, I noticed the normal alarms were lit. There was printing out, is normal after a turbine reactor trip. I also noticed that the emergency team or the radiation type of emergency was in attendance in the control room. In talks with the control room personnel, primarily, Bill Zewe, the shift supervisor, Ed Frederrick, control room operator, and Lee Rogers, B&W site representative, quickly established that conditions were abnormal for this type of

009 347

1 transient. In talking with these personnel and looking at the console
2 indication in the computer print-out noted that the hot leg temperature
3 for the primary system were in excess of 620 degrees, that the cold leg
4 temperatures significantly varied from this, they were quite a little
5 bit cooler. The pressure was low in the reactor coolant system. All
6 the control rod were on the bottom. The indication for the source and
7 intermediate range appeared to be normal for a shutdown condition. I
8 did, however noticed the two blips on the recorders for the source of
9 intermediate range. Ed Frederick informed me that they had thought at
10 the time that they were going critical and that they had added boron.
11 At this time I informed him that in all probabilities that was the not
12 case that there had been a change in the leakage... Flux path from the
13 reactor core to the detectors and it was not in fact a case of the
14 reactor going critical again. Looking at the recorder that prints out
15 the OTSG and reactor coolant temperatures on wide range 0 to 800 degrees,
16 there were several temperatures that were reading from 770 to 800
17 degrees in the hot leg of the reactor coolant system. Since these
18 thermocouples are not normally calibrated in that range, knew the
19 temperature were high, but did not totally believe the indication.
20 Ivan Porter the Met Ed I&C engineer showed me a set up where he was
21 reading approximately 243 ohms, which converts to approximately 725°F
22 on RTD that he set up specially opposite side of the control room. The
23 talks with various personnel in the control room, Gary Miller, and the
24 rest of the operations personnel informed me of the sequence of events
25 that had led up to this position. At that time in talk with Ed Fredericks,

1 we were convinced that night that we in fact had a solid steam bubble
2 in both loops of the hot legs. At this time I attempted to initiate
3 the filling of steam generators to induce natural circulation or at
4 least remove enough heat that would collapse the bubble sufficiently to
5 run the reactor coolant pumps.
6

7 O'CONNOR: John, let me ask you a question at this point. You said
8 that some time after you got there which was 9:00 you started to sense
9 natural circulation. From that can I infer that the control room staff
10 up to that time was not trying to establish natural circulation?
11

12 FLINT: There was some doubt at that time as to whether they were
13 trying to establish natural circulation or not. They were filling the
14 generation to some extent, but it wasn't clear that they were going to
15 try to establish natural circulation.
16

17 O'CONNOR: That was not their goal?
18

19 FLINT: I didn't infer that at the time. I talked to several different
20 people and I can't remember exactly who said what now. Some of them
21 said they merely filling the generators to obtain a level in them and
22 remove some heat. Others said they were doing -- try to induce, natural
23 circulation, and some said that they were doing it in order to just
24
25

009 349

1 cool enough to try to run a full pump. I think most people this time
2 did not believe that there was in fact super heated steam bubble in the
3 hot legs.

4
5 O'CONNOR: And this is some time after 9:00.

6
7 FLINT: Sometime between 9:00 between approximately 9:00 and 9:30.

8
9 O'CONNOR: What was the control room staff trying to do at that time
10 to re-establish some flow in the reactor coolant system.

11
12 FLINT: The operators reported to me that they had attempted to run
13 the reactor coolant pumps, had seen a low current indication on the
14 pump, had not observed any flow indication of any significant degree,
15 and therefore had concluded that they were totally steam valve, or that
16 the pumps were just sitting there and cavitating and not operating
17 corectly.

18
19 O'CONNOR: Were they trying to increase plant pressure to prevent
20 function cavity.

21
22 FLINT: Shortly after a period of time, there was an attempt to pressurize
23 the system and to collapse the bubble that way. I explained to them at
24 the time that if the temperature we were seeing were anywhere near true
25 we could not in fact collapse the bubble. It would be in excess of

1 allowable pressures even if we gave the code safetys. The code safetys
2 would lift before we could reach this pressure and the system itself
3 was not designed for this pressure. The
4

5 O'CONNOR: That was because the steam bubble was super heated?
6

7 FLINT: That is correct.
8

9 O'CONNOR: So in summary you are saying that the temperature of the
10 steam bubble was so hot that its saturation pressure was greater than
11 set points for the code safetys and even if they charged the system up
12 the code safetys would have lifted before they could have suppressed
13 the bubble.
14

15 FLINT: That is correct, a rough approximation would be say in excess of
16 3 thousand lbs. And a code safety is set for less than 2400 lbs - 2500
17 right in that range. So there would be no way that we could have done
18 it. About that time for approximately an hour and a half they were
19 dumping out of the atmospheric dump on the A generator. We then received
20 a call that stated the Governor requested that that valve be closed
21 immediately the request was in the form that made it a demand. Gary
22 Miller complied and was at that time was preparing to go talk with the
23 Governor.
24
25

009 351

1 O'CONNOR: Do you recall why you were lifting the atmospheric dumps?
2

3 FLINT: We were using atmospheric dumps to try to steam the A generator
4 remove enough heat that we could use it as a heat sink and collapse the
5 bubble that way. Induce natural circulation.
6

7 O'CONNOR: The vacuum in the condenser was not available at that time?
8

9 FLINT: No. We had lost the auxiliary boiler and they were attempting
10 to regain it I believe they gained one boiler porportioned time lost it
11 and was quite some time before we got both boilers back.
12

13 O'CONNOR: What did you use as a the heat sink once the plant staff
14 stopped dumping steam through the atmospheric dumps at the request of
15 the Governor?
16

17 FLINT: Some of the heat removal was dumping through the electromatic
18 relief valve into the building, some of it was taken away with the
19 filling of the generators. About this time the level in the B generator
20 was also increased. They did dump some down into the condenser on the
21 bypass valves but that was not, you know in that portion of time it is
22 a little difficult to remember exactly which sequence. That was their
23 only method of heat removal at that time. Finally, verified that in
24 fact that we could not collapse the bubble. The pressure was then
25 reduced again. At that point in time it was tried to start the reduce

1 the pressure to the point where we could get down on the core flood
2 tank. There was some concern that the core was not in fact covered. I
3 felt that it was since the leakage flux as seen by the source range
4 channels appeared to be in a normal range for a shutdown condition
5 considering the length of time we had been shut down. However as a
6 precaution, the pressure was reduced the core flood tanks then slowly
7 came into the system and since we did not see a significant pressure
8 change or rapid dropping of the core flood tank levels where they feed
9 directly into the downcommer annulus or the reactor vessel itself, from
10 that we presumed that in fact the core was covered and that we were
11 essentially feeding in an either bypassing the core or just merely
12 coming out of the core coming back through the legs and dumping out the
13 pressurizer for cooling water. We were not getting anything up through
14 the loops themselves. We did have a high pressure indication in the
15 reactor building somewhere along this length of time. We had the alarm
16 for containment isolation about this time there was a double thud at
17 the time was not thought to be from the building. At least, I personally
18 did not think it was from the containment building. I thought that it
19 was the ventilation damper cycling it. It was very close to that
20 sound. And since we had been in and out of respirators due to levels
21 in the building, I just thought somebody had cycled the ventilation
22 dampers again and related it to that. The reactor building spray pumps
23 came on a normal actuation sequence for high pressure in the building.
24 They were bypassed and later shut down. During this portion of time we
25 finally managed to get the A leg temperature decreased to where we

1 could see the hot leg temperature on scale we the operator then elected
2 to try to go over to another leg and collapse the B side and in doing so
3 he lost the gain we had made on the A side. The A side hot leg again
4 went off scale. Somewhere along in here we finally did see some changes
5 of decrease where the hot leg was coming down. The cold leg tempera-
6 tures were going up indicating that we were getting some type of heat
7 transfer across there. Later in the afternoon we were requested to
8 once again try to collapse the bubbles by increasing the pressure.
9 Once again we tried to explain that we had tried that that morning gone
10 to approximately 2,000 lbs and it had not work. That the temperatures
11 at this time were still not significantly different from those earlier
12 in the day but we could not persuade them that this could be done.
13 Being unable to convince offsite personnel that the pressure increase
14 would not collapse the bubble, we went ahead and increased pressure of
15 approximately 2300 lbs charging with the makeup pumps. We gradually
16 throttled back on one pump until we achieved this and held it for a
17 considerable period of time. This did not collapse the bubble. However,
18 by this time due to early indications of the whole leg temperature
19 increasing and the hot leg temperature coming down the A loop, we felt
20 that we had enough water around the pump at this time that we could run
21 one of the A loop pumps. The A loop pumps were chosen for two reasons.
22 One we had a better chance of establishing circulation there since that
23 generator was not bogged up and No. 2 the pressurizer spray line comes
24 off there which would give us mixing in the loop and help to bring the
25 temperature down a little more rapidly plus allow us to get better

1 boron samples if we had to take them out of the pressurizer system. We
2 bumped the reactor coolant pump 1A after trying to start the 2A and it
3 did not start. We went to 1A ran it for approximately 10 seconds this
4 was long enough to indicate to us that the current appeared to be in
5 the normal range and that flow was in fact verified to be in the loop.
6 We then shut the pump off, let it sit for approximately 15 minutes.
7 The 15 minutes was based on the fact that during normal startup due to
8 surge currents you do not want to start and stop the pump anymore
9 frequently than this.

10
11 O'CONNOR: Excuse me John, why was the pump stopped after just a few
12 seconds of running?

13
14 FLINT: We were not certain that what would happen was we would pull the
15 steam bubble down into the pump and cause severe cavitation or possibly
16 with a rapid pressure change and of mass density change fail the seals
17 in the pump. We therefore just wanted to verify the moving water get
18 some mixing once again turn that water over collapse the bubble a
19 little further and then run the pump once we were verified that we felt
20 we could do without any significant problems.

21
22 O'CONNOR: If you didn't have the, I withdraw that question.
23
24
25

009 355

1 FLINT: Since the pump had appeared to be normal. The pump was restarted
2 and we saw the expected pressure decrease and flow rate that we expected.
3 The pump current was normal at approximately 600 amps. The pressure
4 decreased was due to the collapsing of the steam bubble and we saw the
5 A loop temperatures on the hot leg come down and the cold leg temperatures
6 going up indicating we did have flow and mixing across there. The
7 smooth trace on the flow plus the pump current indicated we did not
8 have any serious steam bubble problems in fact we were pumping primarily
9 water if not entirely all water. That period of time the pump was left
10 running to mix the system up. In this period of time we started drawing
11 a vacuum on the condenser and were preparing to get the aux boilers
12 back on line so we could start feeding back into the condenser normal
13 method for cooldown. After a period of time we, fairly late in the
14 evening by now, established the bubble in the pressurizer, we had
15 brought the temperatures in the B loop down on scale and we were getting
16 some small amount of circulation through the B side as well. One
17 point that I did forget to mention earlier was that shortly after I
18 came in we also started calling up on the computer the incore thermocouples
19 attempting to establish what had happened in the core. Many of them
20 were indicated question marks which indicated they were greater than
21 their 700 degree range only one or two seemed to indicate there were in
22 fact bad. These temperatures were monitored for the rest of the day
23 during this portion of time to follow what was happening with the core.
24
25

009 356

1
2 O'CONNOR: John, does B&W, were you functioning as a B&W employee during
3 this event, or were you just there providing advice.

4 FLINT: I was providing primarily there providing advice not as a B&W
5 because I was still on master service's to GPU and felt that I was
6 filling the role of advice and consultation to the customer from that
7 standpoint. I was however interacting with Lee Rogers providing him
8 with a physics parameters and...

9
10 O'CONNOR: Where was Lee?

11
12 FLINT: Lee was in the control room during all this portion of the time
13 frequently he would be in the meetings with George Kunder, Gary Miller,
14 Mike Ross, Bill Zewe and the rest of them establishing what they were
15 going to do next what the conditions were. Well I was primarily working
16 with the operators themselves monitoring parameters and helping them
17 try to assess what the actual situation in the core in the primary
18 system was.

19
20 O'CONNOR: I see. Was B&W in Lynchburg communicating with Lee Rogers?
21
22
23
24
25

009 357

1
2
3
4
5
6
FLINT: There was an open line to B&W Lynchburg on a continuous basis as well as an open line for the Nuclear Regulatory Commission to communicate with their personnel and open lines direct over to the observation center and to other personnel on the outside for advice from the GPU and Met Ed facilities.

7
8
9
O'CONNOR: Were you in a position to observe how the emergency plan was being carried out?

10
11
12
13
14
15
16
17
18
FLINT: During the portion of time that I was there it seemed to be extremely well organized, personnel knew what they were required to do, there was excellent communication between Unit 1 control room personnel which was set up as an emergency control center, the Unit 2 Control Room, the offsite personnel and I would say that all aux operators, NRC personnel, HP that were associated with this, were almost as if this was a drill rather than the real thing since they were functioning extremely smoothly during this course of time.

19
20
21
O'CONNOR: How would you describe the atmosphere in the control room during the period of time that you were there?

22
23
24
25
FLINT: I would say that the personnel were extremely calm and well organized. Late in the afternoon it had a tendency to get a little noisy in there when the immediate problems were over we have a large

1 number of personnel in the control room by this time we had a large
2 number of NRC personnel, we had at least a shift and a half of personnel
3 plus additional personnel from Unit 1 and so forth. It got a little
4 noisy from that standpoint but it was still very well controlled and
5 well organized.

6
7 O'CONNOR: People were not running around not knowing what to do. Or
8 panicing?

9
10 FLINT: No, no panic, especially since frequently announcements were
11 made over the page system to let all personnel know what was going on.
12 Unnecessary personnel were released either to their homes or were
13 mobilized over at the observation center for assistance if necessary.
14 The only personnel that remained onsite were those that were absolutely
15 required and since they were well informed of what was occurring and
16 since most people were in either one of the two control rooms, there
17 was no problem of people appearing not to know what they were doing.

18
19 O'CONNOR: Are there any other observations that you would like to get
20 into the record?

21
22 FLINT: No. I do not believe I have any other observations or remarks
23 concerning the incident.

24
25 889 359

1 O'CONNOR: Well, thank you very much John. Appreciate it.
2
3
4
5
6

7 009 360
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25