

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION

1 In the Matter of:

2 IE TMI INVESTIGATION INTERVIEW

3 of

4 Michael J. Ross
5 Supervisor, Station Operations - Nuclear

6
7
8
9 Trailer #203
10 NRC Investigation Site
11 TMI Nuclear Power Plant
12 Middletown, Pennsylvania

13 April 25, 1979
14 (Date of Interview)

15 July 2, 1979
16 (Date Transcript Typed)

17 81 and 82
18 (Tape Number(s))

19
20
21 NRC PERSONNEL:

22 Dorwin R. Hunter, Inspection Specialist

23 Donald C. Kirkpatrick, Nuclear Engineer

24 Owen C. Shackleton, Investigator

25 892 300

7908290610

1 SHACKLETON: This is an interview of Mr. Michael J. Ross. The time is
2 3:48 p.m., April 25, 1979. Present in the room to conduct this interview
3 from the U.S. Nuclear Regulatory Commission, is Mr. Dorwin R. Hunter.
4 Mr. Hunter is an Inspection Specialist, Performance Appraisal Branch,
5 Inspection & Enforcement, Reactor Construction Inspection. Also present
6 is Mr. Donald C. Kirkpatrick. Mr. Kirkpatrick is a Nuclear Engineer
7 with Inspection and Enforcement, Headquarters, Bethesda, MD. I am
8 Owen C. Shackleton, I am investigator assigned to Region V and will act
9 as moderator during the course of this interview. Prior to the interview,
10 I presented to Mr. Ross a two-page advisement document from the U.S.
11 Nuclear Regulatory Commission which set forth the purpose and scope of
12 this investigation, identifying the authority of the U.S. Nuclear
13 Regulatory Commission to conduct such an investigation, and setting
14 forth those rights that Mr. Ross has to refuse to be interviewed.
15 Mr. Ross answered three questions on the second page of this document.
16 He answered all of them affirmatively. At this time I am going to read
17 these questions and request Mr. Ross to respond. Mr. Ross did you
18 understand all the information contained in the advisement document?

19
20 ROSS: Yes, I did.

21
22 SHACKLETON: Do we have your permission to tape this interview?
23
24
25

892 301

1
2 ROSS: Yes, you do.

3
4 SHACKLETON: Would you like a copy of the tape?

5
6 ROSS: Yes, I would.

7
8 SHACKLETON: All right sir, that will be provided, and on behalf of the
9 Commission I extend our appreciation for your being here to furnish us
10 information regarding the incident at Three Mile Island. For reference
11 and for understanding for those persons who will be utilizing the
12 information you provide, please, if you would, briefly set forth your
13 experience that brought you to the nuclear industry.

14
15 ROSS: I spent approximately 8 years in the United States Navy, basically
16 as an enlisted man. My speciality was electronics and reactor control.
17 Included in that was one term in a tour of duty with Naval Reactors
18 Branch and the Schenectady Naval Reactors Fuel Office in Schenectady,
19 New York. Since then I came to Metropolitan Edison in 1968, served as
20 a Staff Instructor at Saxton Nuclear Experimental Corporation in Penn-
21 sylvania for approximately 2 years, being assigned to Metropolitan
22 Edison as a Shift Foreman in 1970 and coming to Three Mile Island at
23 that time. Since 1970, I've been active in startup of both Unit 1 and
24 Unit 2. I've held positions of Shift Foreman, Shift Supervisor, and in
25 1978, Shift Supervisor of Operation in Unit 1.

892 302

1
2 SHACKLETON: Thank you very much. And now gentlemen, I'll turn the
3 questioning over to Mr. Hunter.

4
5 HUNTER: Thank you. Mike, we'd like to pick you up the morning of the
6 incident and allow you to tell us when you came to the plant and your
7 immediate activities that you were involved in at that time.

8
9 ROSS: My first contact really started at 4:35 in the morning when I
10 received a call from my Unit 1 Shift Foreman saying that Unit 1 had
11 suffered a trip and he had lost heated steam to Unit 2. At that point
12 there was no indication that any thing was serious. His biggest problem
13 was he did not have clean feedwater to feed the Unit 1 steam generators.
14 We talked some 15 minutes, approximately, about what he should do, and
15 not having any cause for alarm at that point, I got up took a shower,
16 had breakfast, came to work, with no hurry in mind, arriving at the
17 site, I think, somewhere around 5:30 in the morning--that's rough. On
18 arriving at site, still not thinking there was any thing to be concerned
19 about, I went to Unit 1 control room, which is my normal station,
20 reviewed with the Shift Foreman what he was doing and where we were
21 going with the Unit 1 plant. At that time, Unit 1 was approximately
22 525 degrees fully pressurized. In preparation, we were looking at
23 possible deboration criticality on Unit 1 sometime that day after a
24 refueling outage. Sometime, and it had to be between 6:00 and 6:30, I
25 received a call from one of the Shift Supervisors, at this time I might

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

add that both Shift Supervisors were in Unit 2 at this time. He told me that, and that's one of the reasons that I started to come in, because both guys were down there and they were busy.

HUNTER: Maybe, excuse me. The two Shift Supervisors that were in Unit 2...

ROSS: Bill Zewe was assigned to Unit 2 and Ken Bryan was assigned to Unit 1, and I guess after the trip Kenny went on down to Unit 2, near as we can tell. The Foreman that contacted me was Dale Pilzitz from Unit 1. Sometime I received a call from Bill Zewe saying he really had a big problem and would I please come on down and give him a hand. I'm not sure of that time--it tough, it's dark somewhere between 6:00 and 6:30 in the morning. I then--and his words wasn't very ...he just said he had something he didn't understand real clearly, would I come. So I did, I still had no reason to rush down at this point. I arrived at Unit 2, and I'm still not sure of the time. When I got there, both Shift Supervisors were there, Joe Logan was there-- he's the Superintendent--George Kunder, a couple staff engineers were already assembled at Unit 2. At that point, I tried to ascertain what we really had. About the time I came into the Control Room, or shortly thereafter, all reactor cooling pumps were tripped. When we looked over, to my recollection, we did have high-pressure injection. It started--right after I got there we saw something on the source range monitors, and at that

1 time I told Bill if he wasn't injecting he ought to be also emergency
2 borating. We saw a spike of some kind on that recorder. It bothered
3 me real bad. When I look down, high-pressure injection was already
4 established. Whether they reinitiated, I don't know, I never asked.
5 When I looked down we had flow and we had boric acid going in.
6

7 HUNTER: Dale, when you came into the Unit 2 control area, were you in
8 direct contact then with Bill Zewe?
9

10 ROSS: Yes, I came to the console and Bill said, "Look around, I got
11 some problems here. I'm going to need some help shortly." I started to
12 look around.
13

14 HUNTER: Any particular thing that you look at, at that time?
15

16 ROSS: I look at primary plant pressure. It was somewhere around, near
17 as I could tell, 1100 lbs, in that area--not high, it was low. I
18 thought high pressure injection was initiated and no reactor coolant
19 pumps, the pressurizer level was really high--whether it was pegged I
20 couldn't tell from where I was standing, but it was really high. And
21 that was what was bothering Bill at the time. He had something he
22 didn't fully and totally understand. Shortly, it must have been within
23 minutes, we saw something on the source ranges on the recorder. It's a
24 big recorder that sits up on a console. We saw movement on it and it
25

1 bothered us, so I told Bill I thought he ought to be emergency borating
2 and he ought to be on high pressure injection. That he did immediately.
3 I'm not sure that high pressure injection at this time was or was not
4 on. Like I said, when I did look down, it was in fact on.
5

6 HUNTER: And that time the pumps was already off, as I understand it.
7

8 ROSS: Yeah, the pumps was off.
9

10 KIRKPATRICK: There's no high radiation alarms at this time, yet...is
11 that right?
12

13 ROSS: Nothing that would have caught my eye. I look over, he had a
14 couple of alerts, but nothing that would have said, "Hey we've got a
15 problem." Okay, I did look over, and there was nothing--there was a
16 couple in over there, but I think they were like let-down coolers and
17 stuff like that, which are pretty much normal alarms.
18

19 HUNTER: Was there any thing else that caught you eye. Anything else
20 that caught you besides the pumps being off, the pressure was low...
21

22 ROSS: The source range indication really bothered. It really bothered
23 me a lot.
24
25

892 306

1
2 HUNTER: Do you recall looking at the steam generators at that time?

3
4 ROSS: No, they are on the other side of the console from where I was
5 standing. I did not look at that particular time.

6
7 HUNTER: Okay, go ahead, at the point where you saw the source range
8 and the emergency borating...

9
10 ROSS: The emergency borate had injected. After that I told Bill we
11 ought to try to get a reactor coolant pump on, and we tried and we
12 didn't get anything. I'm not sure of the time--it's one of the problems
13 I have, being four weeks after.

14 HUNTER: Don't worry about the time, I'm more interested in the events.
15 Emergency borate, in your words, would be through what flowpaths?

16
17 ROSS: Basically, through the makeup path. There is, . . . you start
18 the boric acid injection pumps, it comes into the makeup system and is
19 injected with makeup pumps into the system.

20
21 HUNTER: Will that also include a manual pass, or could it possibly
22 include a manual injection...?

23
24 892 307
25

1 ROSS: It could. At that time we were using just what was available.
2 All he had to do, the emergency path was lined up to start to pumps,
3 and that's what they did.
4

5 HUNTER: Okay. All right.
6

7 ROSS: Shortly thereafter, realizing we had a problem with cooling, we
8 tried to start a reactor coolant pump, and we started the coolant pump.
9 First they told me. . . I was kind of standing back trying to absorb
10 some of this stuff and I had just walked in. Shortly after they started,
11 they said the pump didn't start. When I looked we could see the red
12 light on the breaker and knew the breaker was shut. At that point they
13 ascertained, the length of time was quite long, I'm sure, the pump only
14 had a 100 amps. At that point we knew we probably had a dry well or
15 something. The pump was tripped and we commenced to increase pressure
16 and let the coolant flow out through the electromatic relief.
17

18 HUNTER: At the time the pump started, in relation to that time, were
19 there any radiation alarms that came on?
20

21 ROSS: It was either right at that time or shortly thereafter. It's in
22 the same time frame that everything--
23
24
25

892 308

1
2 HUNTER: Everything came on? Was there something that came on first,
3 to you knowledge?

4
5 ROSS: It just started lighting up over there, and then the Superintendent
6 stepped up, and at that point we realized that we probably had at least
7 a slight emergency on our hands, and we declared that right away. That
8 was declared by Kunder and Zewe, a site emergency. The time was, well,
9 I know what the time was--around 7:00 in the morning by this time. But
10 I wouldn't have remembered that.

11 HUNTER: This is a good breaking point. from this event, because we'll
12 know where to come back to it, okay. I'd like to go back a minute and
13 pick your brain a little bit. When you came in and looked at the plant
14 status, did you look at the power operated relief valve, the RV-2
15 valve, and the status of the reactor coolant drain tank?

16
17 ROSS: Well, the reactor coolant drain tank, unfortunately in this
18 Unit, is around back. It's not indicated in the control room. I did
19 look at the electromatic relief and all indications of it were in fact
20 shut. They have a light with a brilliant light that tells you when this
21 thing is open. It indicated shut.

22
23 892 309
24
25

1
2
3
4
5
6
HUNTER: The light deenergized means the circuit was deenergized through
the valve. It should have been closed. What about--let me go back and
clarify something. You said the reactor coolant drain tank was not in
the control room. It's not in the control room but it's behind the
panel.

7
8
ROSS: Behind the panel. No, I did not look at the status of that.

9
10
11
HUNTER: You did not go behind there. Ok. What about on the computer--did
you make a pass at the computer at that time?

12
13
14
15
16
17
ROSS: One of the Shift Supervisors at that time was trying to ascertain
the position of RC-RV2--it was Ken Bryan. At that time he reported
back to us that it was 200 and something degrees on his thermocouple,
which is a fairly low reading. And about that time we went in and
isolated it.

18
19
20
21
HUNTER: If you had experience in Unit 2 or Unit 1 of the powered
operated relief valve leaking, safety valve leakage, what would you
have expected that temperature to be if it was really leaking?

22
23
24
25
ROSS: If it was really leaking I would have expected something much
higher than 200°, although I know that thermocouples are strapped on a
plate. It is not a weld type.

892 310

1 HUNTER: Could you recall an example of what temperatures you have seen
2 when a valve is leaking significantly?
3

4 ROSS: We've seen temperatures in Unit 1 on an electromatic relief when
5 we had a valve leakage problem of 280^o, 290^o, 300^o.
6

7 HUNTER: During your review of Unit 2 operations, it appears that the
8 electromatic or safety valve was in fact leaking prior to the event,
9 because looking at the computer alarms, looking at the temperatures,
10 the tank was--the operaors indicate that the tanks were hot. They
11 indicated that they were having to pump a few thousand gallons a shift
12 out of the reactor drain tank, above and beyond what would normally
13 apparently be pumped by reactor coolant pump seals. Were you aware of
14 that this morning when you were there?
15

16 ROSS: No, I wouldn't have any reason to be aware of that. My normal
17 station is in Unit 1.
18

19 HUNTER: I understand that, I'm trying to...
20

21 ROSS: I knew that they had a relief valve leaking problem. We were
22 aware of that on both units, but nothing that I would have called
23 gross. I knew they had a leakage problem.
24
25

892 311

1
2 HUNTER: Were you under the assumption that morning that they were not
3 aware that the power operated relief valve was open, or going down?

4
5 ROSS: Yes. I'm under the assumption that they felt it was closed,
6 because sometime in that time gap we went ahead and isolated it, and
7 the reactor coolant pressure started to drop. So we felt that the
8 electromatic had in fact been passing.

9
10 HUNTER: But before that, had it really entered their mind that it was
11 open?

12
13 ROSS: I think that they looked at the indications they had, including
14 computer, and ascertained that it was shut and just went on to something
15 else.

16
17 HUNTER: Okay, the temperatures were low, indicating low, which might
18 indicate that it might be weakened and not drawing?

19
20 ROSS: Yes, I would say, yes exactly.

21
22 HUNTER: The reactor coolant drain tank, temperature and pressure and
23 level are indicated on a control panel behind, around from the operator--
24
25

892 312

1
2 ROSS: Panel 8A, right.

3
4 HUNTER: Which is around the corner. The operator, except for the
5 computer, do you know if he had any indication on that, on the reactor
6 coolant drain tank, reactor coolant system, reactor coolant drain tank
7 system in front of him?

8
9 ROSS: No, he has nothing except the computer.

10
11 HUNTER: OK. In your tour--again, I realize that you just walked in.
12 You were doing a tour and realizing that, I don't know what details,
13 you look at "HIPSI"--if you mentioned high pressure injection. You
14 mentioned that you did in fact look--can you recall when--I'm not
15 worried about the time--when you came in, can you recall the high pressure
16 injection light on? Did you look at it in that amount of detail?

17
18 ROSS: I looked down to see that we had flow from the high pressure,
19 and where you look is on the back panel. I looked over the panel light
20 to see what--

21
22 HUNTER: What did you see?

23
24 ROSS: I saw a flow indication, up in the 200 range in each leg. You
25 know, it was up, normal indication.

892 313

1
2 HUNTER: Four legs?

3
4 ROSS: It looked to me like it was all 4 legs.

5
6 HUNTER: At that time?

7
8 ROSS: Yeah...like I said, I don't if it was after they reinitiated or
9 not. I'm not sure at this time.

10
11 HUNTER: OK, that's fine. The site emergency then was declared. After
12 you started the pump, the alarms went off, and the site emergency was
13 declared. What activity did you become involved in then?

14
15 ROSS: Well, then we just decided to increased the makeup flow, but we
16 didn't increase the pressure in the system. We let it essentially flow
17 through RC-RV2. The electromatic is our cooling mode if we have no
18 hole in the system. We put it in there and tried to get some flow
19 through the system. We started that. Shortly thereabouts, within
20 minutes, Gary Miller came into the control room and took charge of the
21 control room. Gary is our Site Manager and that time he appointed me
22 as his Liaison for Operations as Senior Operations guy there. He's
23 formed management staff that was going to report to him for the emergency.
24
25

892 314

1
2 HUNTER: What did this staff include?

3
4 ROSS: The Operations guy, which was me, and I was to give direction or
5 counsel to the shift supervisors; a B&W guy by the name of Lee Rogers,
6 and where he showed up, I'm not sure, but he's pretty quick; maintenance
7 was going to be taken care of by Dan Shovlin, who's a Maintenance
8 Superintendent; and Dick Dubiel was placed in charge of HP type areas;
9 and Jim Seelinger was in placed in charge of the Emergency Controls
10 Center and offsite activities, trying to give us some control and to
11 divide duties a little. Basically, I would remember it that way.

12 HUNTER: You were receiving then, your instructions from Gary Miller.

13
14 ROSS: Yes sir.

15
16 HUNTER: And you then were. . . and who was orking specifically for
17 you soon after that?

18
19 ROSS: Shift supervisors. I was giving instruction in operational type
20 modes at that time.

21
22 HUNTER: And that would include Bill Zewe and Ken Bryan, both?

23
24 892 315
25

1 ROSS: Someplace in there, we sent Ken Bryan back to Unit 1 and his
2 relief, someplace in there, also came in-another Shift Supervisor,
3 Brian Mehler. So we kept Mehler in 2 and sent Ken Bryan back to 1 to
4 make sure we had some operational type senior people in both Units,
5 because basically we ended up with everybody down there. And with a
6 radiation emergency going on, they were going to need somebody up
7 there.

8
9 HUNTER: What did you get specifically involved in at that time?

10
11 ROSS: At that time Gary had specified and talked about what our goals
12 ought to be at this time, knowing that we did have a problem. The
13 seriousness, I don't think we fully realized. Our guidelines at that
14 time was to try to limit offsite doses, try to keep the core covered
15 and cool, as best we could, and to limit damage to Met Ed people and
16 equipment. That was kind of our charter at that time. We talked about
17 the plant status and we decided we'd continue to inject to increase the
18 pressure as much as we could to keep high pressure injection going.

19
20 HUNTER: Would you expand on that some? Looking at high pressure
21 injection, from that time the pump has been secured, the alarms are on,
22 you discovered your main stream high pressure injection--what be the
23 flow at that time?

24 892 316
25

1
2 ROSS: I would say the flow would still have been 225 per leg. At that
3 time--I'm not sure what we gave the operator, we gave the operator a
4 pressure drain to maintain with the electromatic block--electromatic
5 relief valve, and I believe we gave them somewhere around 18-1900
6 pounds to maintain the system at 2000 pounds, in that area. They were
7 letting the pressure build up like this.

8 HUNTER: Okay, and that was with one or two high pressure injection
9 pumps running and--

10
11 ROSS: Two high pressure injection pumps.

12
13 HUNTER: Would they be throttling the high pressure injection at that
14 time?

15
16 ROSS: They'd be throttled to maintain leg flows-225, but that should
17 have already been set. I don't believe we throttled anything else at
18 that time.

19
20 HUNTER: Okay, with this particular amount of time, this time then, you
21 were actually maintaining in the range of 900 for four legs at 225
22 gallons a leg, and controlling opening the main door, opening motor
23 operating valve on the RV-2 valve pressure, the pressure relief? Okay,
24 how long did this go on?

25
892 317

1 ROSS: It seemed like a long time...an awful long time.
2

3 HUNTER: Yes, try to key to the next activity, like "we maintained this
4 until this time," and we'll try to key it back into this place time
5 frame.
6

7 ROSS: Somewhere in there, we lost the auxiliary boilers and I had to
8 break vacuum in Unit 2, and that was in the morning. I not real sure of
9 the time, but it was well before noon.
10

11 HUNTER: OK, that's most important, is the activity. Don't worry about
12 the time.
13

14 ROSS: We lost vacuum, we broke vacuum.
15

16 HUNTER: What did this do to you, this force Unit 2?
17

18 ROSS: We weren't really much steaming out of that generator, even
19 though we'd brought the levels up. It didn't appear to us that we were
20 getting any heat exchange from that at all, anyway, not much of it.
21
22

23 892 318
24
25

1
2
3
4
5
HUNTER: At this time, basically you're sitting with the safety, the high pressure injection system discharging out to the power operated relief valve, isolation valve, as necessary to maintain the pressure. What did you see on the Th, the temperature, Tc's.

6
7
8
ROSS: They were awful high on Th, indication that, yeah, we did in fact have vapor up in the legs. They were offscale.

9
10
HUNTER: Did you recall any thermocouple readings at that time?

11
12
13
ROSS: Not till later. We had asked for thermocouple readings, and they had come back questionable, question marks off the computer.

14
15
16
HUNTER: That means, what would the normal temperature on the computer be?

17
18
19
20
21
ROSS: Well, normal temperatures would be hard. . . In this particular Unit, we're talking about 1200^o or less. That question mark means it was out of the scan range, is what it means, or it had in fact a fault of some kind.

22
23
24
25
HUNTER: The hot legs were extremely high, what about the cold legs?

892 319

1
2 ROSS: I'm not real real sure. It looked to me like they were down low
3 someplace, indicating there was stagnant flow someplace.

4 HUNTER: And at this time, you had seal water injection to the pumps?
5

6 ROSS: Yes...still on.
7

8 HUNTER: Seal continuously...were you at the control panel in the
9 control room area when they had their first building isolation signals?
10

11 ROSS: I was close. I think that was somewhere in the morning again,
12 quite early. I was back trying to map out our next plan is what I was
13 doing. But, yeah I was there when they got an isolation signal. It was
14 maybe 9 or 10 o'clock in the morning, I don't know.
15

16 HUNTER: Did you see any changes occur when the building isolated, that
17 you recall, any significant changes in the ...?
18

19 ROSS: The only significant thing was that the operator reported that
20 the building spray pump started. It started sometime in that area.
21

22 HUNTER: Sometime in the morning?
23
24
25

892 320

1 ROSS: Yeah.

2
3 HUNTER: The pressure to start the building spray pump is what?

4
5 ROSS: 30 pounds.

6
7 HUNTER: OK, so that one's 20--

8
9 ROSS: Two different pressure switches.

10
11 HUNTER: OK. Going back earlier in the morning, okay, there appears to
12 be a building isolation when the pressure drifted up to 4 lbs. Do you
13 have any recollection of that particular time?

14
15 ROSS: It may have, and like I said things were I remember at
16 least once, possibly twice that we did get the isolation signal.

17
18 HUNTER: Okay. And your going through this high pressure injection,
19 maintaining pressure, what will be the next--all of your boilers lost,
20 or what would be the next key event--

21
22 ROSS: Broke vacuum.

23
24
25
892 321

1 HUNTER: Broke vacuum.

2
3 ROSS: Then we were ordered to shut our atmospheric dump to the atmosphere
4 on the one generator that wasn't isolated. And it was a concern we
5 were dumping activity and we were relatively sure we weren't. And we
6 did that somewhere around noon.

7
8 HUNTER: That was to isolate the actual steam relief pump on the A
9 generator, or the one that wasn't isolated.

10
11 ROSS: Right. And at that point we reestablished and started pulling
12 vacuum again somewhere, right around in that same area. It's a little
13 confusing to us exactly when it was.

14
15 HUNTER: That will be reestablishing the auxiliary steam from Unit 1--

16
17 ROSS: Right.

18
19 HUNTER: Or the auxiliary boiler and then getting the vacuum back.

20
21 ROSS: Trying to look for any kind of heat sink we could get, even
22 though we were having trouble getting a circulation path, any heat sink
23 would have better than that.

24
25 892 322

1 HUNTER: OK. The next key event that you recall?
2

3 ROSS: Well, Miller got orders to the Governor's office sometime in
4 that area, and he had to leave. So we just kept on with what we were
5 doing.
6

7 HUNTER: Who took his place then?
8

9 ROSS: Basically, he turned things over to Joe Logan, the Superintendent
10 for Unit 2, and he was gone, I don't know, an hour an a half or so, and
11 he came back. And we had been asking for recommendations from B&W at
12 that point. At that point, the next key one I remember was making a
13 decision, which was a hard decision, for all of us to blowdown and try
14 to go on 1) core-flood injection and 2) possibly decay heat removal.
15

16 HUNTER: And you said that recommendation came from ...
17

18 ROSS: It was a joint recommendation that B&W concurred in. It was all
19 people involved.
20

21 HUNTER: I just want to know where it came from so that we know who to
22 talk to, okay? So, we're going through--
23
24
25

892 323

1 ROSS: It came out of the think group there, the five of us that were
2 involved so co-equals, and that's what we did.
3

4 HUNTER: Lee Rodgers was involved in the think tank and he was directly--
5

6 ROSS: It was Gary, me, and at that point we tried to make a run, if
7 you will, down as the core flood got on.
8

9 HUNTER: Okay, so we're at the point now where the high pressure injection
10 is still going, the motor operated valve is being cycled by the operator
11 to maintain pressure, and you are considering going down to the core
12 flood tanks.
13

14 SHACKLETON: Gentlemen, we'll cut right here. The time is now 17 minutes
15 after 4:00 PM, April 25, 1979. We will resume our interview when we
16 turn the tape.
17

18 SHACKLETON: This is a continuation of an interview for Mr. Michael J.
19 Ross. The time is now 4:18 p.m. April 25, 1979. Please continue.
20

21 HUNTER: We left talking about preparing to depressurize and go to the
22 core flood tanks. Mike, would you continue that?
23

24 892 324
25

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

ROSS: And that we did, we came down ... one of our fears was that we weren't getting flow through the core, you can't tell from out there. We were hoping that all that high pressure injection was in fact going up through the core. Thoughts were that we can come down, get the four flood tanks to go in, verify the core was in fact covered, and keep high pressure injection going pushing water through the core. We did come in the Unit, and as near as I can tell, pressure only went as low as about 200 some pounds. Core flood tanks went in at some volume, probably a foot, foot and a half, not much. There was no inrush, tremendous inrush into the core, and hopefully that indicated there was some water in there anyway. At that time we decided we'd continue high pressure injection, hoping we'd get some natural circulation and break whatever steam void we did. Then I think what we started doing was alternating legs on high pressure injection at that time, trying to get one side to recirc a little more, the other flow back on one side. So we definitely had a--

HUNTER: Okay. Let's go back. What did you depressurized to go down to the core flood tanks, did you reduce the high pressure injection or did you just ...?

ROSS: To my knowledge, high pressure injection was not reduced until we actually got down there and we were trying to swap flow between legs to get the natural circ to break.

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

HUNTER: In the core flood tanks, basically, it appears you probably just flooded the core flood tanks on the system and you then blocked up with whatever pressure the core flood tanks were, would maintained. Then you indicate that you varied the flows to the four loops. Would you go into that all in more detail, how you do that.

ROSS: That one is a little hazy. We were back in the think tank, and one of the things that was recommended was that we try break, get some natural circulation of some kind going, maybe increase the flow in one leg and cut the flow back in one leg. Hopefully that would do something for us, which we tried. I'm--not being in the control room at the time, we were back in the think tank--I'm not sure how much they varied at that time, what there range was in varying.

HUNTER: What was the intent? Was the intent to increase the flow in one leg and decrease it in on the other.

ROSS: Yeah.

HUNTER: Was there any talk about maintaining the same flow, the same total flow to the core?

892 326

1 ROSS: Talk was to keep high pressure injection on in a reasonable high
2 amount of flow. We didn't tell them that couldn't move more than ten
3 gallons or anything, but the idea was to stay in the same area.
4

5 HUNTER: Okay. Let me make sure I understand. The intent was to try
6 to, by varying the flow to the legs, to possibly establish some natural
7 circulation?
8

9 ROSS: Grasping the straw in the middle, but looking to do something.
10

11 HUNTER: Okay, no problem. Then, go ahead and continue. Do you recall,
12 not when, but maybe how long you were actually in this evolution?
13

14 ROSS: We talked about coming back out of it quite rapidly, but then we
15 started to see some temperature changes in the legs and indication
16 maybe we were going to get some flow. So we stayed there and continued
17 this for a little while, and we eventually did start to bring Tcs and
18 Ths closer together. We started to see Tc's come up and Th's come down.
19 By then we had a recorder hooked up on the Th and it was a higher range
20 than our instruments. They were telling us, yeah, they were seeing Ths
21 come down.
22

23 HUNTER: Okay, and can you recall what temperatures they were talking
24 about?
25

892 327

1 ROSS: Yeah, they were talking 700° and then we coming back on scale.

2
3 HUNTER: OK, and Tc's at that time, were they still low?

4
5 ROSS: Yeah, they were low.

6
7 HUNTER: And then they would be coming back from where, do you recall?

8
9 ROSS: 100 and some degrees...or 90 to 100. I don't know. Low.

10
11 HUNTER: I'm having a little trouble with...I'm not to sure I understand
12 where the 100° water came from, except that unless--with high pressure
13 injection going, where does it inject?

14
15 ROSS: It comes in a discharge to the reactor coolant pumps.

16
17 HUNTER: Into a vertical line, or...?

18
19 ROSS: Yeah, it comes into the line, right at the discharge to the
20 pump, it comes into the side of the line.

21
22 HUNTER: Okay, in the side.

23
24 892 328

25

1
2 ROSS: And the thermocouples are in that.

3
4 HUNTER: What will be the water flow? What would you approximate the
5 water flow at that time, coming into A loop, to pump discharge, would
6 it go both ways? Would it go through the ...

7 ROSS: I would like to think it would go through the core.

8
9 HUNTER: Did you recall in the think tank, the discussion as far as
10 what the flow paths were?

11
12 ROSS: We kept thinking, we were hoping that we weren't short cycling
13 the core and back this way. But our thoughts were being, possibly were
14 so cold we were getting a lot of injection into the core.

15
16 HUNTER: Okay, do you recall the steam generator levels at that time,
17 or the pressures? Did you discuss those?

18
19 ROSS: Yeah. Seems to me they were like a 100 lbs generator pressure.

20
21 HUNTER: All right, you had flood up for natural circulation before you
22 took the pumps off ...?

23
24 892 329
25

1 ROSS: That's correct. We brought the levels up for natural circulation.

2
3 HUNTER: And they were sitting there at that level, I suppose.

4
5 ROSS: 130, something like that.

6
7 HUNTER: Again, at low pressure, apparently.

8
9 ROSS: Yeah, real low pressure.

10
11 HUNTER: The next significant event that you can recall, that you were
12 involved in?

13
14 ROSS: Like I said, we started to see the Tc's, and the next event was
15 later that night. Once we had seen that we had talked about trying to
16 get a reactor coolant pump. By then our Manager had called over and
17 said, "you guys ought to go back solid," which we started to do-Jack
18 (Herbein) called, and we were starting to go back solid, total injection,
19 two makeup pumps, to take her back solid. At this time we started
20 looking we saw all indications that the loop was in fact filling, both
21 by the amount of water and the pressure kind of hung up and water flow
22 kept on going with the RC2V tube isolated. This told us we were in fact
23 filling all the loops. At that time we talked to B&W and talked about
24 getting a reactor coolant pump started, and we discussed which pump we
25

1 would start, after knowing all the history on all the pumps, what pumps
2 had been run by then and by that time I think about all of them had
3 been run dry, by the way. So we talked a great length about which pump
4 would start and at that point we decided which pump we would do. We
5 then bumped the pump. When I say "bumped", we ran it just long enough
6 to see the reactor coolant pressure change and get flow indication.
7 And the reactor coolant pressure changed radically. At the time we
8 bumped it, we were probably 18-1900 lbs and pressure dropped down to
9 about 1100 lbs. We had about a 6-700 lbs drop, like right now. That
10 was somewhere around 7:00, you might say.

11
12 HUNTER: Okay, let's go back a little earlier, during the afternoon. I
13 think you said it was decided to go off the core flood tanks. You
14 weren't getting down to decay heat removal. You weren't able to get
15 down that far.

16
17 ROSS: We weren't able to get down.

18
19 HUNTER: And it was decided to go back up in pressure. Where did this
20 come from? I take it--

21
22 892 331
23
24
25

1
2 ROSS: We had talked about it in the tank some, and also about that
3 time, Jack Herbein called over and said he wanted the plant taken
4 solid.

5 HUNTER: Okay.

6
7 ROSS: So that's were we headed.

8
9 HUNTER: So, you would then continue high pressure injection on two
10 pumps, leaving the motor operated valve on RCV closed on the relief
11 valve and continue up. Do you recall any significant changes during the
12 time you were pressurizing?

13
14 ROSS: As far as Tc and Th continued to diverge for us at that time,
15 and coming closer, indicating we were getting some flow.

16
17 HUNTER: They were converging at that time.

18
19 ROSS: The other significant event was that, without the pressure going
20 up, we got up to like 16-1700 lbs, and pressure kind of held, indicating
21 to us we were flowing into the loops. It didn't just take straight up.

22
23 HUNTER: What would that indicate, that you're not solid?
24
25

1 ROSS: Yeah, that's what that would indicate.
2

3 HUNTER: And that you had a bubble?
4

5 ROSS: Someplace, yeah for sure. At least that was my analysis. We
6 didn't talk about it, but I kept thinking, "geez, we've been pumping
7 air a long time but pressure is not going up anymore. We must be filling
8 loops." At that time we talked about how much extra water...
9

10 HUNTER: That was the context you talked about though, that you must be
11 just filling the loops?
12

13 ROSS: Yeah.
14

15 HUNTER: And continuing to pressurize and then ... it seems like a long
16 time to me. You're going out towards 7:00, I think, the pump was started,
17 later in the evening.
18

19 ROSS: Around 7:30 I think.
20

21 HUNTER: So you bumped the pump.
22
23
24
25

892 333

1 ROSS: We bumped it once. We did see flow. We did see loop temperatures
2 change and we did see a rapid decrease in pressure when we did that.
3 B&W recommended that we wait 15 minutes at that time to protect our
4 pump 'cause they felt that was going to be our cooling mode at this
5 time. And we increased pressure quite high, we must have went 2200 lbs
6 or 2300 lbs, maybe, in order to accomodate this pressure decrease, with
7 our goal being, once we started to pump the second time, to leave it
8 running.

9
10 HUNTER: Then you starting to save time and what happened?

11
12 ROSS: Then it went, it ran, pressure dropped down quite rapidly and
13 didn't stabilize and we left the pump running. And it looked to me like
14 when the pump was started we had a loop temperature somewhere in the
15 area of 300-320°, in that area. That would at least tell me that we
16 did cool the core. As a layman, anyway.

17
18 HUNTER: Okay. And then, at that time the pump was on, did you start
19 to. . . did you maintain pressure or go back to normal pressure?

20
21 ROSS: What we did then, not thinking we had any further problems, what
22 we did was kept the pressurizer heaters on, brought the temperature up,
23 and we drained the pressurizer hoping to shift. . . . I guess we were
24 kind of solid in the pressurizer--indications were solid anyway--to
25

1 shift the bubble to the pressurizer if there was a bubble anyplace
2 else. We continued to heat the pressurizer and get it hotter and drain
3 down a little bit on the pressurizer with the reactor coolant pump on.
4 Later that evening we did see indication of the level coming down and
5 pressure kind of stabilizing. I think that pressure was somewhere
6 around 14-1500 lbs.
7

8 HUNTER: With the heaters on, you were heating--the power operated
9 relief valve closed, the pumps on, the system is basically solid except
10 if there was a bubble somewhere. At least you were steaming, you were
11 going through a steam generator at that time. Then you were able to
12 steam...
13

14 ROSS: By that time we had vacuum also, again.
15

16 HUNTER: Were you cooling do through the ... what was you cool down
17 path?
18

19 ROSS: Dumping back to the condenser through the turbine bypass valves.
20

21 HUNTER: Pumping the water then back ...
22
23
24
25

892 335

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

ROSS: Back, and we did go into a cool down mode shortly thereafter, cooling the plant down. From what I remember, about 330°, we brought it down to, late that evening, very late we were like 250-260 in that area. That was about 2:00 in the morning, by then.

HUNTER: Looking at the pressurizer, since that probably was the only thing that was going on at that time, seems that things were fairly well straightened out by that time. I hope you were probably involved in that particular evolution, and you, in fact, had the pressurizer heaters on.

ROSS: Yes.

HUNTER: What would the pressurizer temperature be doing?

ROSS: Coming up.

HUNTER: If you were sitting at 1450 or 1350 lbs, you had a goal to come up to the saturation temperature, I presume. And then start draining?

ROSS: Yeah.

892 336

1 HUNTER: And get the bubble into the pressurizer?
2

3 ROSS: Get the bubble in the pressurizer and try to get to what we
4 would call a normal cooldown mode. We'd have the pump on, we'd have
5 the bubble supposedly in the pressurizer, we would be steaming the
6 generator, except one generator bottled, we would go into a normal
7 cooldown mode at that time. And basically, that's for we did that.
8

9 HUNTER: So, you ended up that evening, sometime that evening, with a
10 bubble sitting at constant pressure, one reactor coolant pump on,
11 normal charging makeup, reactor coolant pump seals.... Do you recall
12 letdown at that time?
13

14 ROSS: We did not have any indication by then. Letdown was a source of
15 problems all through this because we never determined what we had.
16

17 HUNTER: Give me the reason. See if you can key on letdown sometimes
18 and maybe we'll try to put it together.
19

20 ROSS: I think earlier in the morning we had letdown flow indication,
21 relatively low. And then later on we lost all indication. We felt we
22 had some letdown and sometime in that period of time we went ahead a
23 isolated the letdown and we saw the effect of the letdown relief valve
24
25

892 337

1 lifting back at the bleed tank. We actually had seen the flow spike.
2 At the time we couldn't determine whether or not we didn't have any
3 letdown flow or whether the instrument was screwed up. The instrument
4 would move every time it would look like the relief valve relieved or
5 lifted. It just continued to ... we did have indication, yeah, we did
6 have letdown but we were not able to ascertain how much it was.
7

8 HUNTER: Okay ,in the letdown relief lifting, did that go to bleed
9 tank?

10
11 ROSS: Yeah, it's a hard fight to the bleed tank.

12
13 HUNTER: Okay, could you tell that it was going to the bleed tank?
14

15 ROSS: Not for sure, there was no real way. We had indication that the
16 relief valve was lifting and that--
17

18 HUNTER: What about the bleed tank level?
19

20 ROSS: It went up some, I'm saying but that--
21

22 HUNTER: Yeah, I'm trying to make sure that the line actually went to
23 the bleed tank.
24

25
892 338

1
2
3
4
5
6
ROSS: Yeah, I wish I could say I could guarantee you that that's where
it went. We had indications that the bleed tank pressure went up,
which could have been just from the vent header, and also indications
that level did in fact go up in the bleed tank. So it could have come
from there, it should have come from there.

7
8
HUNTER: What was the letdown situation as you went on through the day?

9
10
11
12
13
14
15
16
17
18
ROSS: We continued trying to open bypasses and establish more letdown
to give us more control in the situation we were in--open some bypass
valves in the system that we could get to externally without giving
anybody a big dose. By then we had relatively firm HP control in areas
and they were all roped off and their was Scott airpack areas to get
into .. things like this. We continued trying to establish and wondering
why we couldn't get any flow indication. We tried somethings like
valving in other demineralizers, some experiment trying to get letdown
flow.

19
20
HUNTER: Did you end up with some?

21
22
ROSS: We also felt we had some, but we never ended up with any indication.

23
24
25
HUNTER: Okay, and that's were you left it?

892 339

1 HUNTER: The indication I'm talking about is actual flow indication in
2 the letdown line. We had indication we had letdown in that we could
3 control our level and our pressure somewhat but no indication of amount
4 of gallons.

5
6 HUNTER: What about the makeup tank?

7
8 ROSS: The makeup tank level told us we did have some letdown.

9
10 HUNTER: I'm trying to visualize.... Would you still have been using
11 the boron, the BWST, the Boric Acid, the Boron Water Storage Tank at
12 this time or would you be strictly on the volume control tank?

13
14 ROSS: Still strictly on the volume control tank and making up as
15 necessary from the BWST at that time.

16
17 HUNTER: Making up as necessary?

18
19 ROSS: Yeah. When the makeup tank get a little low, you open the valve,
20 suck a little water into the tanks.

21
22 HUNTER: Right. Where would it be going?

23
24
25 892 340

1 ROSS: Into the system, into the makeup tank.
2

3 HUNTER: Okay, the makeup tank is then being charged into, being added
4 the primary coolant system.
5

6 ROSS: Yeah, right.
7

8 HUNTER: Were you leaking anywhere at that time, that you were aware
9 of?
10

11 ROSS: Nothing we were aware of, and its kind of hard to ascertain the
12 fact that we were changing temperature and cooling down at the same
13 time. We had no reason to think we had any gross leaks anyplace, based
14 on what we had seen.
15

16 HUNTER: Okay, I think that I have got up to the point where we're at
17 15 hours into the event. The pump is on, things are fairly stable. This
18 is the first cut at our program to get your involvement. Are there any
19 areas you can think of--not times or anything--but any activities that
20 you were involved in that are significant--of course, I'm just trying
21 to lead you through it--that you feel that are significant that we
22 should discuss? Even if we don't, what will happen is, as we go to
23 other people, I'm sure we'll key back into you and try to cross-reference
24 your activities. But if there's something significant that we need to
25

1 get, that we need to look at, we don't want to miss anything. . .
2 concerning the high pressure injection. One thing that I might ask
3 that might key your thoughts, is that there are two boron samples that
4 we're dealing with, that was earlier-one was 400ppm and one was 700ppm.
5 Were you involved in that or ...?

6
7
8 ROSS: I heard the results of one of them, in the morning--

9
10 HUNTER: Which one did you hear?

11
12 ROSS: It was either 6 or 700.

13
14 HUNTER: Okay.

15
16 ROSS: Okay. I thought it was either. It was discounted in the control
17 room the first time, of course, as being an erroneous sample. I think
18 they had that piece of information--we had seen the spike on the source
19 range, I can't be sure of that. 'Cause at that point we said, "oh man,
20 maybe that sample is right. Let's..."

21
22 HUNTER: Did you get another sample at that time?

23 892 342
24
25

1
2 ROSS: There was two samples requested. I don't remember which can
3 first. But on doing the second sample, when Dick Dubiel got involved
4 and started isolating the building, I guess he had seen something,
5 activity wise radiation levels wise.

6 HUNTER: During the second sample, you said that's when the building
7 was...was Dick...

8
9 ROSS: No, Dubiel--let me rephrase that for you guys. Dick Dubiel is a
10 person.

11
12 HUNTER: No, I understand that. I knew that--

13
14 ROSS: I said building was isolated, and he was saying get the people
15 for sure out of the auxiliary buildings for both units, because he
16 wasn't sure what was going on.

17
18 HUNTER: Did he see something at that time?

19
20 ROSS: Radiation levels on the sample line, I think.

21
22
23 892 343
24
25

1 HUNTER: OK, so he was picking up something... to get a boron sample... again,
2 my understanding that that letdown sample would be on recirc through
3 the sample room.
4

5 ROSS: That's correct. And the sample room being located in Unit 1.
6

7 HUNTER: Then you would have the hot lines... Do you happen to know
8 what time that was? Do you have any feel for it?
9 Was there any...
10

11 ROSS: Before 7:00
12

13 HUNTER: Was there any event that happened that would key us to that
14 time? I guess maybe drawing the sample would key us to that time.
15

16 ROSS: Yeah.
17

18 HUNTER: OK, and I got this sample, the technician would log that he
19 drew a sample at time, I guess. Anything else?
20

21 ROSS: Radiation monitoring charts in Unit 1 possibly, in that the hot
22 machine shop lines pass through the Unit 1 monitors.
23
24
25

892 344

1
2 HUNTER: OK. We'll key into that. So were trying to see when we saw
3 the first radiation increase into the Units.

4
5 ROSS: I think Dubiel would have that time, 'cause he'd just come to
6 work.

7
8 HUNTER: Just a general area, just a general question--and I go through
9 the procedures of what you do when you trip the plant and try to understand--t's
10 my understanding that as soon as you tripped the plant there are chemistry
11 requirements this plant, that you have to get the chemistry, run
12 boron, and reduce some other chemistry, iodine, that type of thing. So
13 they would have put the letdown on recirc early, based on the fact that
14 they had--the operators do a shutdown margin calculation also.

15 ROSS: Right.

16
17 HUNTER: Is that based on the boron that was there when they tripped or
18 did they get a new boron sample?

19
20 ROSS: The first one's based on the boron at the time of the trip. Of
21 course, he was trying to make sure that we are shut down. He corrected
22 with actual borons in the plant.

23
24
25 892 345

1 HUNTER: How long does that normally take?
2

3 ROSS: It can vary. We are talking, probably by the time that the guy
4 gets down there and gets a sample, we are talking about an hour or two
5 hours, really, by the time the guy recircs it and gets the number back
6 to us.
7

8 HUNTER: Okay. But probably the normal time frame would be before they
9 turned the pumps off. That's at 7:00, that would mean you have three
10 hours?
11

12 ROSS: Yeah, I would think that they would have them by then.
13

14 HUNTER: Okay, any other area that we can key on, or particular actions?
15 Any comments?
16

17 ROSS: No comments, except that one of the big problems we had was
18 keeping track of time.
19

20 HUNTER: One of the Were things going on so heavy that you just
21 couldn't--
22

23 ROSS: Grasp it.
24
25

892 346

1
2 HUNTER: Grasp the time?

3
4 ROSS: Time went by and we found we spent 20 or 25 minutes on something
5 we thought we had spent 5 minutes on. I think if we knew that, that
6 would have helped us an awful lot.

7
8 HUNTER: What about the numbers of people in the control room? You
9 were in fairly early?

10
11 ROSS: Yeah, ECS moved twice throughout that incident. That added to
12 the confusion in the control room, but--

13
14 HUNTER: Where--they moved once? From where? Unit 1 to...?

15
16 ROSS: To Unit 2, to Unit 1 and back, and back again, as far as I know.

17
18 SHACKLETON: Mr. Ross, could you define ECS for people not familiar
19 with the terminology?

20
21 ROSS: ECS is a body of people, basically staff engineers, and it's
22 emergency control center. Their job is to take care of and mitigate the
23 offsite things, track offsite doses, predict offsite doses, communicate
24 with the State and the NRC and our consultants in any emergency.
25

892 347

1 HUNTER: Where was the emergency center first located?
2

3 ROSS: Part of the Unit 2, first.
4

5 HUNTER: And that is where?
6

7 ROSS: They were around the area of the shift supervisor's offices.
8

9 HUNTER: Okay, and then where did they move?
10

11 ROSS: They went to Unit 1, and I recollect it came back once for just
12 a few minutes, and then it was gone.
13

14 HUNTER: Numbers of people around the control board during the incident?
15

16 ROSS: Not excessive. One thing we did do, and probably increased the
17 number of people around the control board is, in the morning hours we
18 realized that we did in fact have at least a major plant problem at a
19 minimum. And we assigned an operator to every panel and a shift foreman,
20 a supervisor to back that guy up, allowing us to get back to the think
21 tank and try to recall people in and put a guy at each panel, basically.
22

23 892 348
24
25

1
2 HUNTER: How did that end up with Bill Zewe and...?

3
4 ROSS: Well, Bill is responsible for control room operations and plant
5 operations.

6
7 HUNTER: And did he have those people, both he and the foreman who were
8 assigned, did anybody else helping Bill, or was there anybody else
9 assigned to that particular position?

10 ROSS: Well, at that time Brian Mehler was also onsite to assist Bill.
11 He is another shift supervisor. But the idea was to get some supervision
12 down to a lower level and concentrate on each individual item so we
13 didn't miss something big.

14
15 HUNTER: Okay, and the foreman were assigned at the panel levels--that's
16 my understanding...

17
18 ROSS: Yeah, that's right. And an operator to each section, so we
19 should have 3 operators and it should have been a total of 3 supervisors.

20
21 HUNTER: What about the people back in the back, the numbers back in
22 the back...

23
24 892 349
25

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

ROSS: There were a lot of people back there but they mainly stayed out of the way. A lot of the operators were back because we had run them out of the auxiliary buildings and they were trying to stand by the control room to see if there was anything they could do.

HUNTER: Were you still able to communicate adequately with Bill Zewe and these other shift supervisors?

ROSS: Yes, I think so.

HUNTER: You weren't having any trouble getting the word to him when the think tank had a direction, that was to you, and as I understand, and then to Bill as the shift supervisor?

ROSS: Yes.

HUNTER: In the morning, sometime during the interviews, we picked up that an entry was made, at least one, and I believe Greg Hitz made an entry into the auxiliary building with an operator to look at the auxiliary waste panel. Were you aware of that or, involved in that?

ROSS: Yes, we were interested in ascertaining what was going on in the auxiliary building--was it under water, what was going on, what was the vent air pressures, etc.

1
2 HUNTER: What came out of that, anything significant?

3
4 ROSS: He reported approximately 3 inches of water in some areas. But
5 only at the peak sections, so in other words, the floors weren't totally,
6 and he reported no gross major leakage.

7
8 HUNTER: What about the auxiliary building sump? Obviously, then that
9 was full.

10 ROSS: Yeah, it was overflowing.

11
12 HUNTER: What about the miscellaneous drain tank?

13
14 ROSS: At that time he came back and I think he told us the level was,
15 in fact, not overflowing at that time.

16
17 HUNTER: The makeup bleed tanks are indicated in the control room.

18
19 ROSS: Yes, they are.

20
21 HUNTER: What was their status at that time, do you recall?

22
23 ROSS: It's hard to remember...

24 892 351
25

1 HUNTER: Were they normal or abnormal?
2

3 ROSS: I would think they were fairly normal at that time.
4

5 HUNTER: So at that particular time, then, it was your understanding
6 that you just had a few inches of water at the low points in the
7 drain.
8

9 ROSS: Three inches at the lowest points in the drains, backing up on
10 to the floors in some areas.
11

12 HUNTER: And that's all the questions I have.
13

14 SHACKLETON: We'll close the tape at this time. The time is now 4:46
15 and we will return in just a minute. The date is 4/25/79.
16

17 SHACKLETON: This is a continuation of the interview of Mr. Michael J.
18 Ross. The time is now 4:47 p.m., April 25, 1979.
19

20 KIRKPATRICK: All right, Mike, I would like to go back to some of the
21 earlier comments you made and try to get clarification on a few things.
22 At one time you said after you had decided to go solid that you noticed
23
24
25

892 352

1 a lot of water was going in. You thought--it surprised you. Were the
2 people in your think tank generally aware that the water level must
3 have been fairly low, prior to that time?
4

5 ROSS: The water level in the loops, I think so, in that the reactor
6 coolant pumps wouldn't pump I would say yes.
7

8 KIRKPATRICK: So that they did attribute the fact that they wouldn't
9 pump to the fact that the water probably was low.
10

11 ROSS: Yeah.
12

13 KIRKPATRICK: You also said that the manager had called and said it was
14 time to go solid. Had there been consideration of going solid prior to
15 that time?
16

17 ROSS: Well, basically, we spent most of that morning in that mode.
18 Most of the day in that mode.
19

20 KIRKPATRICK: In an attempt to get it to go solid?
21
22

23 892 353
24
25

1
2
3
4
ROSS: Yeah, we put it in the, all but letting it go out the code safety--we did increase pressure and, we maintained a high pressure, we maintained a high pressure injection.

5
6
7
KIRKPATRICK: What was the main reason that you couldn't get it to go solid?

8
9
10
ROSS: I think we never really let it go solid because we were worried about pushing water through the code safety valves.

11
12
13
KIRKPATRICK: I see. When you tried to pump it up, the pressure would go up? Is that right?

14
15
ROSS: Yeah.

16
17
18
KIRKPATRICK: Had there been any consideration to going ahead and opening up the code safety at the time you were pumping out?

19
20
21
22
ROSS: Just in passing. It was kicked back. I don't know who in B&W was talked to but we had talked about going flow through them, and nobody was real keen on that idea at the time.

23
24
25
KIRKPATRICK: So that you were hesitant to open them up?

1 ROSS: Not knowing whether it would ever reseal again, you know, once
2 you wash water through a steam safety valve.
3

4 KIRKPATRICK: I see. You could not get enough pressure reduction with
5 the normal electromatic relief valve in order to keep your pressure
6 down, is that right?
7

8 ROSS: That's correct.
9

10 KIRKPATRICK: So you were trying to raise the water level but when you
11 did that the pressure would go up.
12

13 ROSS: Right.
14

15 KIRKPATRICK: And you couldn't keep the pressure low enough with electro-
16 matic relief valves in order to add water?
17

18 ROSS: We ended up cycling the valve while adding water, is what we
19 ended up doing. The valve would actually open and shut.
20

21 KIRKPATRICK: I see. So you know you were low in water and while
22 trying to add water, you basically couldn't.
23
24
25

892 355

1
2
3
4
5
6
7
8
9
10
11
ROSS: I don't think we could ever fill the loops. That's what we would like to have done. We would like to have filled the loops but the loop system didn't seem to want to fill. The pressure went up and we had indications that we were headed, in fact, for solid and the pressure would go rapidly up. We'd opened the electromatic and flow it back, you know, to some level to keep injecting. Later in the day when we went in an attempt to go solid we did, in my opinion see a difference as we got up, you know, a few--15, 1600 hundred pounds--the pressure kind of held and everything was kind of filled, you know--it looked like to us.

12
13
14
KIRKPATRICK: Well, what was the main difference then that permitted you to go ahead and go solid?

15
16
17
18
19
20
ROSS: I think our Th temperatures were different, our Tc's--I think our plant temperature was different. We had washed a lot of high pressure injection water through the core at this time. That's my personal opinion. We had put quite a number of gallons through the system by then.

21
22
23
24
25
HUNTER: Did I hear you say that the Th, the hot leg temperatures and cold leg temperatures were different at that time?

892 356

1
2 ROSS: Yes.

3
4 HUNTER: Had they decreased, is that what you're saying?

5
6 ROSS: Yes. I think we had indications that we maybe had some flow
7 circulation through there by then. That's the way I remember it right
8 now.

9
10 KIRKPATRICK: Possibly could it have been also the steam--the fact that
11 the steam generators were filled up and gave you better cooling?

12
13 ROSS: No. I don't think, because the steam generators were filled
14 quite early. Very, very early. Hours and hours and hours before.

15
16 HUNTER: Were the--well, the steam generators were set near a full code
17 at low pressurizer, I guess, weren't they, at that time?

18
19 ROSS: Right.

20
21 KIRKPATRICK: That's all the questions I've got.

22
23 HUNTER: Mike, what would you , what would be, at this plant you are
24 better aware of some of the aspects of it than a lot of people. When
25 you looked for a natural circulation what were you looking for?

1
2
3
4
5
6
7
8
ROSS: What you are looking for is the fact the Th and Tc do circulate. You are looking for any indications of flow. What you're looking is some difference between Th and Tc, but no great total difference between them. You are looking for some delta T across the core, you are looking for some difference between the two, but you are looking for indications that you do in fact have a temperature transporting one loop to the other.

9
10
HUNTER: All right, have you seen natural circulation at this plant?

11
12
ROSS: On Unit 2, I haven't. I've seen it on Unit 1 years ago.

13
14
15
HUNTER: On Unit 1, was it during the preop testing when you actually saw the--

16
17
18
ROSS: Yeah, I think we did a preop natural circulation test over there.

19
20
HUNTER: Okay, I don't have any more questions. Don...?

21
22
23
24
25
KIRKPATRICK: How many people did you have in your think tank back there?

892 358

1
2 ROSS: Well, it would be B&W, Miller, me, or HP guy on and off, Logan
3 on and off, Kunder on and off.

4
5 KIRKPATRICK: All right thank you. I don't have any more.

6
7 HUNTER: Do you have any comments? Would you like to say anything?

8
9 ROSS: No.

10
11 HUNTER: We will, I can't promise you, but we will probably be getting
12 back with you because we will be trying to pull out more details. We
13 do appreciate your time.

14
15 SHACKLETON: Thank you very much Mr. Ross. The time is now 4:54 p.m.,
16 April 25, 1979.

17 892 359
18
19
20
21
22
23
24
25